



NOTES

- 1. Access road safety rules to be included on CDM sign.
- 2. Vehicle hazard lights and warning beacons must be switched on whilst driving on access road.
- 3. Vehicle speeds must not exceed 10mph.
- 4. 'Beware of Pedestrians' signage to be provided.
- 5. For additional health and safety information refer to construction method statements.
- 6. All CDM areas require agreement with National Grid SAP prior to establishment.
- 7. CDM areas are shown indicatively and may be developed as project progresses.
- 8. All works will be carried out in accordance with National Grid safety rules and procedures.
- 9. Segregated Access route to be provided for pedestrians from amenities to work areas.
- 10. Work areas must be segregated using suitable barriers.
- 11. Temporary earthing during construction to be agreed with National Grid SAP.
- 12. Extra care to be taken outside substation compound to ensure security of materials and equipment which are not to be left unattended. Welsh Government security is limited to road access and the site has a history of incidents involving salvaging and theft of materials.
- 13. Background information based on AutoCAD Bing maps (2020).
- 14. A working width of 3 m has been assumed for installation of underground services.

LEGEND

- CDM Work Area

Car Parking and Laydown Area

Welfare Area

Haulage Access Route

Proposed Access Route

Proposed Equipment

Existing Layout

Substation Access Gate

Electrical Palisade Fence(ISS Specification)
- Items Included Within CDM Area:

Fire Alarm

Fire Extinguisher

Muster Point

Skips

First Aid Facilities


Notice Board - Site Information

Notice Board - CDM Information

REFERENCE DRAWINGS

HAZARD PLAN	PDD-102592-LAY-0201
CIVIL LAYOUT	PDD-102592-LAY-0202
INDICATIVE POTABLE WATER CONNECTION ROUTE PLAN	PDD-102592-LAY-0203

JACOBS
FOR INFORMATION



P01	FIRST ISSUE	OG	NP	HA	01/04/25
P02	ROUTE UPDATED	OG	NP	HA	26/06/26
P03	UPDATED AS PER CLIENT COMMENTS	OG	NP	HA	28/07/26
Rev	Description	Created	Checked	Approved	Date

nationalgrid

Investment No:	Project No:	Site:
102592	102592	BAGLAN BAY 275KV SUBSTATION
Investment Name:		
BAGLAN BAY SITE SEPARATION		
Document Title:		
CDM PLAN		

Created by:	Date:	Checked by:	Date:	Approved by:	Date:
GG	28/07/26	NP	28/07/26	HA	28/07/26
Development Eng:	Document Type:	Scale:	Format:	Sheet(s):	Rev:
Bing Yang	DWG	1:1000	A0	1	P03

National Grid Drawing Number:
PDD-102592-LAY-0200
Originator Drawing Number:
B2441C36-JAC-14-XX-DR-C-0200