

NOTES:

THE DEVELOPER MUST SELF-VET AND CERTIFY THAT THE DESIGN CRITERIA, MATERIAL STANDARDS AND WORKMANSHIP SPECIFICATIONS FOR THE PROPOSED ADOPTABLE SEWERS ARE IN ACCORDANCE WITH THOSE SET OUT IN SEWERS FOR ADOPTION 7th EDITION AND THE REQUIREMENTS OF DWR CYMRU WELSH WATER AS THE STATUTORY SEWERAGE UNDERTAKER.

ALL HIGHWAY WORKS TO BE IN ACCORDANCE WITH 'NEATH PORT TALBOT COUNTY BOROUGH COUNCIL GUIDE TO THE LAYOUT OF DEVELOPMENT ROADS' & 'SPECIFICATION FOR THE CONSTRUCTION OF ROADS FOR ADOPTION'

Table 1

Access types	
Access Type	Application
Type 1	Man entry, depth 3-6 m
Type 2	Man entry, depth <3 m
Type 3	Non-entry, depth <3 m
Type 4	Non-entry, depth <2 m

All pipes entering the bottom of the manhole to have soffits level.

Table 2

Nominal diameter of largest pipe in manhole (mm)	Minimum nominal internal dimension of manhole (mm)
Less than 375	1200
375 - 450	1350
500 - 700	1500
750 - 900	1800
Greater than 900	Pipe diameter + 900

P02	13.11.19	NR/TW	DESIGN FINALISED
P01	30.10.19	NR/TW	ISSUED FOR APPROVAL
REV	DATE	DRAWN/CHK	REVISION INFO
STATUS:			

PRELIMINARY

PROJECT:

HERITAGE GATE
COED DARCY
PHASE 3

DRAWING TITLE:

STANDARD DRAINAGE CONSTRUCTION
DETAILS
SHEET 1 of 2

JOB NUMBER:
SE1649

SCALE AT A1:
NTS

REV. STATUS:
S2

IESISSTRUCTURES

LONDON 20 IRONMONGER LANE | LONDON | EC2V 8EP | UK
T: +44 (0)207 600 2912
BRISTOL 89-95 REDCLIFFE STREET | BRISTOL | BS1 6LU | UK
T: +44 (0)117 922 7039
MANCHESTER COMMERCIAL WHARF | 6 COMMERCIAL STREET
MANCHESTER, M15 4PZ | UK
www.iesisgroup.com T: +44 (0)845 643 2741

CLIENT:

HERITAGE GATE

DRAWING NUMBER:
COD-ISS-P2-XX-DR-C-3550

REVISION:
P02