



The design is based on the following light fixtures:

Luminaire Schedule				Isolines	
Symbol	Label	Picture	Description		
	X1		Holophane D-series DSX1.LA063.FW.C7 1 with Forward Throw light distribution 52W, 6572lm 2700K, IP65, RAL 7011 column mounted at 6m		0.5 lx
					1.0 lx
					2.0 lx
					5.0 lx
					15.0 lx
	X2		Kingfisher Quarto with Cycle optic 7.5W, 784lm 2700K, IP65, IK10, RAL 7016 bulkhead, mounted at 4m		

KEY PLAN

NOTES

- This drawing is to be read in conjunction with all relevant engineers' and service engineers' drawings and specifications. This drawing is copyright.
- All dimensions are to be checked on site before the commencement of works. Any discrepancies are to be reported to the Architect & Engineer for verification. Figured dimensions only are to be taken from this drawing.
- Lighting has been provided to meet lux levels stated in BS EN 12464-2 Lighting of Outdoor Work Places, for Medium Traffic parking areas of office buildings.

NOTES (CONTINUED)

REVISIONS (CONTINUED)

REVISIONS

REV	REVISION NOTES/COMMENTS					
	DRAWN BY	DATE	CHECKED BY	DATE	APPROVED BY	DATE
P04	A.KAWKA	14/04/20	A.MCEWAN	14/04/20	D.BEYNON	15/04/20
P03	A.KAWKA	14/04/20	A.MCEWAN	14/04/20	D.BEYNON	14/04/20
P02	T.DAVIES	25/03/20	A.MCEWAN	25/03/20	D.BEYNON	25/03/20
P01	T.DAVIES	06/03/20	A.MCEWAN	06/03/20	D.BEYNON	06/03/20



Castlebridge 5
5-19 Cowbridge Road East
Cardiff
CF11 9AB
t: +44(0)2920 023665
e: cardiff@hydrock.com

CLIENT
Morgan Sindall

PROJECT
Swansea Bay Technology Centre

TITLE
**Electrical Services
External Lighting**

HYDROCK PROJECT NO.
26X003

SCALE @ A1
1:400

STATUS DESCRIPTION S1 - For Coordination		STATUS S1
DRAWING NO. (PROJECT CODE-ORIGINATOR-ZONE-LEVEL-TYPE-ROLE-NUMBER) 26X003-HYD-XX-00-DR-E-63-0010		REVISION P04