

Tom Hopkins

From: Perry Rhodri <Rhodri.Perry@dwrcymru.com>
Sent: 03 February 2020 13:46
To: Alice Cox
Cc: Tombs Nicholas; Steve McCarthy
Subject: RE: Melyn Close - SAB Surface Water Discharge

Hi Alice,

I can confirm that we will (subject to SAB consent) accept surface water from proposed development site at a rate no greater than 1.9 l/s into the combined sewer,

I hope this is sufficient, if you need anything further please let me know.

Kind regards,

Rhodri



Rhodri Perry

Development Control Officer | Developer Services
Dŵr Cymru Welsh Water



W: dwrcymru.com



E: developer.services@dwrcymru.com



T: 0800 917 2652



A: PO Box 3146, Cardiff, CF30 0EH



Before you print please think about the ENVIRONMENT

If we've gone the extra mile to provide you with excellent service, let us know. You can nominate an individual or team for a Diolch award through our [website](#)

From: Alice Cox <alice.cox@quadconsult.co.uk>
Sent: 30 January 2020 09:48
To: Perry Rhodri <Rhodri.Perry@dwrcymru.com>
Cc: Tombs Nicholas <Nicholas.Tombs@dwrcymru.com>; Steve McCarthy <steve.mccarthy@quadconsult.co.uk>
Subject: RE: Melyn Close - SAB Surface Water Discharge

***** External Mail *****

Hi Rhodri,

Thank you for your response.

Please could you confirm in writing that connecting the Surface water drainage to the combined sewer is acceptable as this is required for the SAB application to be approved.

Thank you.