

Calculations for the Design of Standard 1750mm high 'L' Wall Units
with Standard Design Parameters

Note that the L wall units must form part of an overall retaining structure designed by a competent engineer, which includes a base slab of at least 200mm thickness to ensure sufficient anchorage for the dowel bars fixing the L unit base. This slab when considered together with the L wall units must be sufficient to resist the sliding and overturning on the whole retaining structure resulting from its function. This is likely to result in the need for a slab to extend significantly beyond either the toe or the heel (or both) of the L unit and have sufficient bending reinforcement in the top or bottom (or both) as dictated by the design and the site circumstances.

Contract Name: Standard Product Design

Contract Number: -

Client: -

Reference: -

In accordance with: BS EN 1992-1:2004
BS EN 1997-1:2004

Assumed parameters: Maximum soil/backfill density: 18.0 kN/m³
Minimum angle of internal friction: 32.5°
Maximum angle of slope: 30.0°
Maximum live load surcharge: 10.0 kN/m²

Design cases considered: Buried foot (toe in), zero slope + maximum surcharge
Exposed foot (toe out), zero slope + maximum surcharge
Buried foot (toe in), maximum slope + zero surcharge
Exposed foot (toe out), maximum slope + zero surcharge

Calculation By: S.J.H 06-Jan-17

Checked By: C.B. 09-Jan-17

C.M. Baker.

Rev	Description	By	Date

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.


SHEET: 2 of 20

1.0 Retaining Wall Design

Overall height (h)	1750 mm
Base length (L _{base})	875 mm
Stem thickness at top (t _{stem_top})	110 mm
Base thickness at end (t _{base_min})	120 mm
Unit width (w _u)	1000 mm
Distance to bolt 1 (from face)	438 mm
Distance to bolt 2 (from face)	N/A
Number of bolts / row (No.)	2 No.
Angle to rear face of stem (a1)	90.9°
Angle to top face of base (a2)	91.3°
Concrete Density (γ _c)	25.0 kN/m³
Average stem thickness (t _{stem})	123 mm
Average base thickness (t _{base})	130 mm
Stem height (h _{stem})	1620 mm
Toe length (L _{toe})	752 mm

Cover block (c)	45 mm
Cover deviation (ΔC _{dev})	5 mm

Height of retained soil (h _{ret})	1750 mm
Moist density (γ _{mr})	18.0 kN/m³
Char' eff' shear angle (φ' _{r,k})	32.5°
Char' wall friction angle (δ _{r,k})	21.7°
Angle of soil surface (β)	30.0°
Variable surcharge (Surcharge _G)	10.0 kN/m²



Depth to action of shear / moment (z)	500 mm
Additional shear force acting at z (V _z)	0.0 kN
Additional concentrated moment acting at z (M _z)	0.0 kNm

The following design is carried out in accordance with BS EN 1992-1:2004 & BS EN 1997-1:2004 at the ultimate limit state. Global Design (2.0) done on a per metre run basis and then pro-rated to the unit width, where not equal to a metre, in Design Values (2.6).

Partial Factors on Actions	Equilibrium (Table A.1)	Comb' 1 (Table A.3)	Comb' 2 (Table A.3)
Permanent unfavourable action (γ _G)	1.10	1.35	1.00
Permanent favourable action (γ _{Gf})	0.90	1.00	1.00
Variable unfavourable action (γ _Q)	1.50	1.50	1.30
Variable favourable action (γ _{Qf})	0.00	0.00	0.00
V _z partial factor (γ _{Vz})	1.50	1.50	1.30
M _z partial factor (γ _{Mz})	1.50	1.50	1.30

Partial Factors for Soil Parameters	Equilibrium (Table A.NA.2)	Comb' 1 (Table A.4)	Comb' 2 (Table A.4)
Angle of shearing resistance (γ _φ)	1.10	1.00	1.25
Effective cohesion (γ _c)	1.10	1.00	1.25
Weight density (γ _y)	1.00	1.00	1.00

Retained Soil Properties based on Coulomb	Equilibrium	Combination 1	Combination 2
Design eff' shear resistance angle (φ' _{r,d});	30.0°	32.5°	27.0°
Design wall friction angle (δ _{r,d});	19.9°	21.7°	17.7°
Level backfill active pressure coefficient (k _a);	0.304	0.276	0.341
Sloped backfill active pressure coefficient (k _a);	0.818	0.538	0.852

Soil Heights & Areas		Equilibrium		Combination 1		Combination 2	
		Rear (h_{eff1})	Front (h_{eff2})	Rear (h_{eff1})	Front (h_{eff2})	Rear (h_{eff1})	Front (h_{eff2})
Effective height of sloped soil (h_{eff})		2184 mm	1750 mm	2184 mm	1750 mm	2133 mm	1750 mm
Dimension properties (see diagram over page)	Property A	2.64354m	1.516m	2.506m	1.405m	2.823m	1.659m
	Property B	1.52625m	0.875m	1.447m	0.811m	1.630m	0.958m
	Property C	1.52625m	0.875m	1.596m	0.895m	1.439m	0.846m
	Property D	0.00000m	0.000m	-0.126m	-0.071m	0.170m	0.100m
	Property E	0.00000m	0.000m	-0.230m	-0.129m	0.278m	0.163m
	Property F	0.00000m	0.000m	-0.080m	-0.045m	0.087m	0.051m
Area of Soil (A)		0.000 m²	0.000 m²	-0.197 m²	-0.062 m²	0.253 m²	0.088 m²

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0


BY: S.J.H

CHK: C.B.

SHEET: 3 of 20


Additional Line Load

Method given in Reynolds (Table 21) to allow for the effect of the additional slope beyond the theoretical angle of repose




Sketch 1: Line load to rear of retaining wall

Sketch 2: Line load to front of retaining wall




Primary Critical Dimensions



Secondary Critical Dimensions


2.0 Retaining Wall Global Design

The global design determines a maximum overturning and sliding force on the retaining wall for each of the three combinations (EQU, Comb'1, Comb'2) in the two loading conditions (presented below) applied to the front and the back of the wall. All designs are done on a per/metre run basis.




Backfill to rear of wall (A)

**Loading
condition 1
Level fill with
surcharge**




Backfill to front of wall (B)



Backfill to rear of wall (C)

**Loading
condition 2
Sloped fill
without
surcharge**



Backfill to front of wall (D)

2.1 Global Forces at EQU

Loading condition 1 -Backfill to rear of wall with level fill and surcharge (A)

Surcharge Load;

$$F_{sur,h} = K_a \cdot \cos(\delta_{r,d} - (90 - \alpha)) \cdot \gamma_Q \cdot \text{Surcharge}_Q \cdot h_{ret};$$

$$0.304 \cdot 0.935 \cdot 1.5 \cdot 10 \cdot 1.75 =$$

7.5 kN

Lever Arm

Moment

0.875 m

6.5 kNm

Active Pressure;

$$F_{ret,h} = \gamma_G \cdot K_a \cdot \cos(\delta_{r,d} - (90 - \alpha)) \cdot \gamma_{mr} \cdot h_{ret}^2 / 2;$$

$$1.1 \cdot 0.304 \cdot 0.935 \cdot 18 \cdot 1.75^2 / 2 =$$

8.6 kN

0.583 m

5.0 kNm

Additional shear load acting at z;

$$F_z = V_z \cdot \gamma_{Vz}$$

$$0 \cdot 1.5 =$$

0.0 kN

1.250 m

0.0 kNm

Horizontal Force (H):

16.1 kN

M_H :

11.6 kNm

Weight of wall stem;

$$F_{stem} = \gamma_{Gf} \cdot h_{stem} \cdot t_{stem} \cdot \gamma_{stem};$$

$$0.9 \cdot 1.62 \cdot 0.123 \cdot 25 =$$

4.5kN

0.062 m

0.3 kNm

Weight of base;

$$F_{base} = \gamma_{Gf} \cdot L_{base} \cdot t_{base} \cdot \gamma_{base};$$

$$0.9 \cdot 0.875 \cdot 0.13 \cdot 25 =$$

2.6kN

0.438 m

1.1 kNm

Retained Soil;

$$F_{ret} = \gamma_{Gf} \cdot (h_{ret} \cdot t_{base}) \cdot L_{toe} \cdot \gamma_{mr};$$

$$0.9 \cdot 1.62 \cdot 0.752 \cdot 18 =$$

19.7kN

0.499 m

9.8 kNm

Friction on virtual Back of wall;

$$F_{wall\ frict} = \gamma_{Gf} \cdot K_A \cdot \sin \delta_{r,d} \cdot \gamma_{mr} \cdot h_{ret}^2 / 2;$$

$$0.9 \cdot 0.304 \cdot 0.34 \cdot 18 \cdot 1.75^2 / 2 =$$

2.6kN

0.875 m

2.2 kNm

Vertical Force (V):

29.3 kN

M_V :

13.5 kNm

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 4 of 20

Loading condition 1 -Backfill to front of wall with level fill and surcharge (B)

Lever Arm Moment

Surcharge Load;

$$F_{sur,h}=K_a \cdot \cos(\delta_{r,d}) \cdot \gamma_Q \cdot \text{Surcharge}_Q \cdot h_{ref}; \quad 0.304 \cdot 0.94 \cdot 1.5 \cdot 10 \cdot 1.75 = 7.5 \text{ kN} \quad 0.875 \text{ m} \quad 6.6 \text{ kNm}$$

Active Pressure;

$$F_{ret,h}=\gamma_G \cdot K_a \cdot \cos(\delta_{r,d}) \cdot \gamma_{mr} \cdot h_{ref}^2/2; \quad 1.1 \cdot 0.304 \cdot 0.94 \cdot 18 \cdot 1.75^2/2 = 8.7 \text{ kN} \quad 0.583 \text{ m} \quad 5.1 \text{ kNm}$$

Additional shear load acting at z;

$$F_z=V_z \cdot \gamma_{Vz} \quad 0 \cdot 1.5 = 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 16.2 \text{ kN} \quad M_H; \quad 11.6 \text{ kNm}$$

Weight of wall stem;

$$F_{stem}=\gamma_{Gf} \cdot h_{stem} \cdot t_{stem} \cdot \gamma_{stem}; \quad 0.9 \cdot 1.62 \cdot 0.123 \cdot 25 = 4.5 \text{ kN} \quad 0.814 \text{ m} \quad 3.6 \text{ kNm}$$

Weight of base;

$$F_{base}=\gamma_{Gf} \cdot L_{base} \cdot t_{base} \cdot \gamma_{base}; \quad 0.9 \cdot 0.875 \cdot 0.13 \cdot 25 = 2.6 \text{ kN} \quad 0.438 \text{ m} \quad 1.1 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{wall\text{ frict}}=\gamma_{Gf} \cdot K_A \cdot \sin\delta_{r,d} \cdot \gamma_{mr} \cdot h_{ref}^2/2; \quad 0.9 \cdot 0.304 \cdot 0.34 \cdot 18 \cdot 1.75^2/2 = 2.6 \text{ kN} \quad 0.875 \text{ m} \quad 2.2 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 9.6 \text{ kN} \quad M_V; \quad 7.0 \text{ kNm}$$

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (C)

Lever Arm Moment

Active Pressure;

$$F_{ret,h}=\gamma_G \cdot K_a \cdot \cos(\delta_{r,d} \cdot (90-\alpha)) \cdot \gamma_{mr} \cdot h_{eff1}^2/2; \quad 1.1 \cdot 0.818 \cdot 0.935 \cdot 18 \cdot 2.184^2/2 = 36.1 \text{ kN} \quad 0.728 \text{ m} \quad 26.3 \text{ kNm}$$

Additional Point Load

$$F_{x,h}=\gamma_G \cdot \gamma_{mr} \cdot \sin(\varphi'_{r,d}) \cdot \cos(\varphi'_{r,d}) \cdot A; \quad 1.1 \cdot 18 \cdot 0.5 \cdot 0.866 \cdot 0 = 0.0 \text{ kN} \quad 1.750 \text{ m} \quad 0.0 \text{ kNm}$$

Additional shear load acting at z;

$$F_z=V_z \cdot \gamma_{Vz} \quad 0 \cdot 1.5 = 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 36.1 \text{ kN} \quad M_H; \quad 26.3 \text{ kNm}$$

Weight of wall stem;

$$F_{stem}=\gamma_{Gf} \cdot h_{stem} \cdot t_{stem} \cdot \gamma_{stem}; \quad 0.9 \cdot 1.62 \cdot 0.123 \cdot 25 = 4.5 \text{ kN} \quad 0.062 \text{ m} \quad 0.3 \text{ kNm}$$

Weight of base;

$$F_{base}=\gamma_{Gf} \cdot L_{base} \cdot t_{base} \cdot \gamma_{base}; \quad 0.9 \cdot 0.875 \cdot 0.13 \cdot 25 = 2.6 \text{ kN} \quad 0.438 \text{ m} \quad 1.1 \text{ kNm}$$

Retained Soil;

$$F_{ret}=\gamma_{Gf} \cdot ((h_{ret} \cdot t_{base}) + (L_{toe} \cdot \tan(\beta)/2)) \cdot L_{toe} \cdot \gamma_{mr}; \quad 0.9 \cdot (1.62 + (0.752 \cdot 0.577/2)) \cdot 0.752 \cdot 18 = 22.4 \text{ kN} \quad 0.499 \text{ m} \quad 11.2 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{wall\text{ frict}}=\gamma_{Gf} \cdot K_A \cdot \sin\delta_{r,d} \cdot \gamma_{mr} \cdot h_{eff1}^2/2; \quad 0.9 \cdot 0.818 \cdot 0.34 \cdot 18 \cdot 2.184^2/2 = 10.8 \text{ kN} \quad 0.875 \text{ m} \quad 9.4 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 40.2 \text{ kN} \quad M_V; \quad 22.0 \text{ kNm}$$

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (D)

Lever Arm Moment

Active Pressure;

$$F_{ret,h}=\gamma_G \cdot K_a \cdot \cos(\delta_{r,d}) \cdot \gamma_{mr} \cdot h_{eff2}^2/2; \quad 1.1 \cdot 0.818 \cdot 0.94 \cdot 18 \cdot 1.75^2/2 = 23.3 \text{ kN} \quad 0.583 \text{ m} \quad 13.6 \text{ kNm}$$

Additional Point Load

$$F_{x,h}=\gamma_G \cdot \gamma_{mr} \cdot \sin(\varphi'_{r,d}) \cdot \cos(\varphi'_{r,d}) \cdot A; \quad 1.1 \cdot 18 \cdot 0.5 \cdot 0.866 \cdot 0 = 0.0 \text{ kN} \quad 1.750 \text{ m} \quad 0.0 \text{ kNm}$$

Additional shear load acting at z;

$$F_z=V_z \cdot \gamma_{Vz} \quad 0 \cdot 1.5 = 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 23.3 \text{ kN} \quad M_H; \quad 13.6 \text{ kNm}$$

Weight of wall stem;

$$F_{stem}=\gamma_{Gf} \cdot h_{stem} \cdot t_{stem} \cdot \gamma_{stem}; \quad 0.9 \cdot 1.62 \cdot 0.123 \cdot 25 = 4.5 \text{ kN} \quad 0.814 \text{ m} \quad 3.6 \text{ kNm}$$

Weight of base;

$$F_{base}=\gamma_{Gf} \cdot L_{base} \cdot t_{base} \cdot \gamma_{base}; \quad 0.9 \cdot 0.875 \cdot 0.13 \cdot 25 = 2.6 \text{ kN} \quad 0.438 \text{ m} \quad 1.1 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{wall\text{ frict}}=\gamma_{Gf} \cdot K_A \cdot \sin\delta_{r,d} \cdot \gamma_{mr} \cdot h_{eff2}^2/2; \quad 0.9 \cdot 0.818 \cdot 0.34 \cdot 18 \cdot 1.75^2/2 = 6.9 \text{ kN} \quad 0.875 \text{ m} \quad 6.0 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 13.9 \text{ kN} \quad M_V; \quad 10.8 \text{ kNm}$$

1750mm Standard L-Wall
with Standard Design Parameters

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 5 of 20

2.2 Global Forces at Combination 1

Loading condition 1 -Backfill to rear of wall with level fill and surcharge (A)

Lever Arm Moment

Surcharge Load;

$$F_{sur,h} = K_a \cdot \cos(\delta_{r,d} - (90 - \alpha)) \cdot \gamma_Q \cdot \text{Surcharge}_Q \cdot h_{ret}; \quad 0.276 \cdot 0.923 \cdot 1.5 \cdot 10 \cdot 1.75 = 6.7 \text{ kN} \quad 0.875 \text{ m} \quad 5.9 \text{ kNm}$$

Active Pressure;

$$F_{ret,h} = \gamma_G \cdot K_a \cdot \cos(\delta_{r,d} - (90 - \alpha)) \cdot \gamma_{mr} \cdot h_{ret}^2 / 2; \quad 1.35 \cdot 0.276 \cdot 0.923 \cdot 18 \cdot 1.75^2 / 2 = 9.5 \text{ kN} \quad 0.583 \text{ m} \quad 5.5 \text{ kNm}$$

Additional shear load acting at z;

$$F_z = V_z \cdot \gamma_{Vz} \quad 0 \cdot 1.5 = 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 16.2 \text{ kN} \quad M_H: \quad 11.4 \text{ kNm}$$

Weight of wall stem;

$$F_{stem} = \gamma_{Gf} \cdot h_{stem} \cdot t_{stem} \cdot \gamma_{stem}; \quad 1 \cdot 1.62 \cdot 0.123 \cdot 25 = 5.0 \text{ kN} \quad 0.062 \text{ m} \quad 0.3 \text{ kNm}$$

Weight of base;

$$F_{base} = \gamma_{Gf} \cdot L_{base} \cdot t_{base} \cdot \gamma_{base}; \quad 1 \cdot 0.875 \cdot 0.13 \cdot 25 = 2.8 \text{ kN} \quad 0.438 \text{ m} \quad 1.2 \text{ kNm}$$

Retained Soil;

$$F_{ret} = \gamma_{Gf} \cdot (h_{ret} \cdot t_{base}) \cdot L_{toe} \cdot \gamma_{mr}; \quad 1 \cdot 1.62 \cdot 0.752 \cdot 18 = 21.9 \text{ kN} \quad 0.499 \text{ m} \quad 10.9 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{wall \text{ frict}} = \gamma_{Gf} \cdot K_A \cdot \sin \delta_{r,d} \cdot \gamma_{mr} \cdot h_{ret}^2 / 2; \quad 1 \cdot 0.276 \cdot 0.37 \cdot 18 \cdot 1.75^2 / 2 = 2.8 \text{ kN} \quad 0.875 \text{ m} \quad 2.5 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 32.6 \text{ kN} \quad M_V: \quad 15.0 \text{ kNm}$$

Loading condition 1 -Backfill to front of wall with level fill and surcharge (B)

Lever Arm Moment

Surcharge Load;

$$F_{sur,h} = K_a \cdot \cos(\delta_{r,d}) \cdot \gamma_Q \cdot \text{Surcharge}_Q \cdot h_{ret}; \quad 0.276 \cdot 0.929 \cdot 1.5 \cdot 10 \cdot 1.75 = 6.7 \text{ kN} \quad 0.875 \text{ m} \quad 5.9 \text{ kNm}$$

Active Pressure;

$$F_{ret,h} = \gamma_G \cdot K_a \cdot \cos(\delta_{r,d}) \cdot \gamma_{mr} \cdot h_{ret}^2 / 2; \quad 1.35 \cdot 0.276 \cdot 0.929 \cdot 18 \cdot 1.75^2 / 2 = 9.5 \text{ kN} \quad 0.583 \text{ m} \quad 5.6 \text{ kNm}$$

Additional shear load acting at z;

$$F_z = V_z \cdot \gamma_{Vz} \quad 0 \cdot 1.5 = 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 16.3 \text{ kN} \quad M_H: \quad 11.5 \text{ kNm}$$

Weight of wall stem;

$$F_{stem} = \gamma_{Gf} \cdot h_{stem} \cdot t_{stem} \cdot \gamma_{stem}; \quad 1 \cdot 1.62 \cdot 0.123 \cdot 25 = 5.0 \text{ kN} \quad 0.814 \text{ m} \quad 4.1 \text{ kNm}$$

Weight of base;

$$F_{base} = \gamma_{Gf} \cdot L_{base} \cdot t_{base} \cdot \gamma_{base}; \quad 1 \cdot 0.875 \cdot 0.13 \cdot 25 = 2.8 \text{ kN} \quad 0.438 \text{ m} \quad 1.2 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{wall \text{ frict}} = \gamma_{Gf} \cdot K_A \cdot \sin \delta_{r,d} \cdot \gamma_{mr} \cdot h_{ret}^2 / 2; \quad 1 \cdot 0.276 \cdot 0.37 \cdot 18 \cdot 1.75^2 / 2 = 2.8 \text{ kN} \quad 0.875 \text{ m} \quad 2.5 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 10.6 \text{ kN} \quad M_V: \quad 7.8 \text{ kNm}$$

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (C)

Lever Arm Moment

Active Pressure;

$$F_{ret,h} = \gamma_G \cdot K_a \cdot \cos(\delta_{r,d} - (90 - \alpha)) \cdot \gamma_{mr} \cdot h_{eff1}^2 / 2; \quad 1.35 \cdot 0.538 \cdot 0.923 \cdot 18 \cdot 2.184^2 / 2 = 28.8 \text{ kN} \quad 0.728 \text{ m} \quad 20.9 \text{ kNm}$$

Additional Point Load

$$F_{x,h} = \gamma_G \cdot \gamma_{mr} \cdot \sin(\phi'_{r,d}) \cdot \cos(\phi'_{r,d}) \cdot A; \quad 1.35 \cdot 18 \cdot 0.537 \cdot 0.843 \cdot -0.197 = -2.2 \text{ kN} \quad 1.750 \text{ m} \quad -3.8 \text{ kNm}$$

Additional shear load acting at z;

$$F_z = V_z \cdot \gamma_{Vz} \quad 0 \cdot 1.5 = 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 26.6 \text{ kN} \quad M_H: \quad 17.2 \text{ kNm}$$

Weight of wall stem;

$$F_{stem} = \gamma_{Gf} \cdot h_{stem} \cdot t_{stem} \cdot \gamma_{stem}; \quad 1 \cdot 1.62 \cdot 0.123 \cdot 25 = 5.0 \text{ kN} \quad 0.062 \text{ m} \quad 0.3 \text{ kNm}$$

Weight of base;

$$F_{base} = \gamma_{Gf} \cdot L_{base} \cdot t_{base} \cdot \gamma_{base}; \quad 1 \cdot 0.875 \cdot 0.13 \cdot 25 = 2.8 \text{ kN} \quad 0.438 \text{ m} \quad 1.2 \text{ kNm}$$

Retained Soil;

$$F_{ret} = \gamma_{Gf} \cdot ((h_{ret} \cdot t_{base}) + (L_{toe} \cdot \tan(\beta) / 2)) \cdot L_{toe} \cdot \gamma_{mr}; \quad 1 \cdot (1.62 + (0.752 \cdot 0.577 / 2)) \cdot 0.752 \cdot 18 = 24.9 \text{ kN} \quad 0.499 \text{ m} \quad 12.4 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{wall \text{ frict}} = \gamma_{Gf} \cdot K_A \cdot \sin \delta_{r,d} \cdot \gamma_{mr} \cdot h_{eff1}^2 / 2; \quad 1 \cdot 0.538 \cdot 0.37 \cdot 18 \cdot 2.184^2 / 2 = 8.5 \text{ kN} \quad 0.875 \text{ m} \quad 7.5 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 41.2 \text{ kN} \quad M_V: \quad 21.4 \text{ kNm}$$

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 6 of 20

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (D)

Lever Arm Moment

Active Pressure;

$$F_{\text{ret,h}} = Y_G \cdot K_a \cdot \cos(\delta_{r,d}) \cdot Y_{mr} \cdot h_{\text{eff}2}^2 / 2; \quad 1.35 \cdot 0.538 \cdot 0.929 \cdot 18 \cdot 1.75^2 / 2 = \quad 18.6 \text{ kN} \quad 0.583 \text{ m} \quad 10.8 \text{ kNm}$$

Additional Point Load

$$F_{x,h} = Y_G \cdot Y_{mr} \cdot \sin(\phi'_{r,d}) \cdot \cos(\phi'_{r,d}) \cdot A; \quad 1.35 \cdot 18 \cdot 0.537 \cdot 0.843 \cdot -0.197 = \quad -0.7 \text{ kN} \quad 1.750 \text{ m} \quad -1.2 \text{ kNm}$$

Additional shear load acting at z;

$$F_z = V_z \cdot Y_{Vz} \quad 0 \cdot 1.5 = \quad 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 17.9 \text{ kN} \quad M_H; \quad 9.7 \text{ kNm}$$

Weight of wall stem;

$$F_{\text{stem}} = Y_{Gf} \cdot h_{\text{stem}} \cdot t_{\text{stem}} \cdot Y_{\text{stem}}; \quad 1 \cdot 1.62 \cdot 0.123 \cdot 25 = \quad 5.0 \text{ kN} \quad 0.814 \text{ m} \quad 4.1 \text{ kNm}$$

Weight of base;

$$F_{\text{base}} = Y_{Gf} \cdot L_{\text{base}} \cdot t_{\text{base}} \cdot Y_{\text{base}}; \quad 1 \cdot 0.875 \cdot 0.13 \cdot 25 = \quad 2.8 \text{ kN} \quad 0.438 \text{ m} \quad 1.2 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{\text{wall friction}} = Y_{Gf} \cdot K_A \cdot \sin \delta_{r,d} \cdot Y_{mr} \cdot h_{\text{eff}2}^2 / 2; \quad 1 \cdot 0.538 \cdot 0.37 \cdot 18 \cdot 1.75^2 / 2 = \quad 5.5 \text{ kN} \quad 0.875 \text{ m} \quad 4.8 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 13.3 \text{ kN} \quad M_V; \quad 10.1 \text{ kNm}$$

2.3 Global Forces at Combination 2

Loading condition 1 - Backfill to rear of wall with level fill and surcharge (A)

Lever Arm Moment

Surcharge Load;

$$F_{\text{sur,h}} = K_a \cdot \cos(\delta_{r,d} - (90 - \alpha)) \cdot Y_Q \cdot \text{Surcharge}_Q \cdot h_{\text{ret}}; \quad 0.341 \cdot 0.948 \cdot 1.3 \cdot 10 \cdot 1.75 = \quad 7.4 \text{ kN} \quad 0.875 \text{ m} \quad 6.4 \text{ kNm}$$

Active Pressure;

$$F_{\text{ret,h}} = Y_G \cdot K_a \cdot \cos(\delta_{r,d} - (90 - \alpha)) \cdot Y_{mr} \cdot h_{\text{ret}}^2 / 2; \quad 1 \cdot 0.341 \cdot 0.948 \cdot 18 \cdot 1.75^2 / 2 = \quad 8.9 \text{ kN} \quad 0.583 \text{ m} \quad 5.2 \text{ kNm}$$

Additional shear load acting at z;

$$F_z = V_z \cdot Y_{Vz} \quad 0 \cdot 1.3 = \quad 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 16.3 \text{ kN} \quad M_H; \quad 11.6 \text{ kNm}$$

Weight of wall stem;

$$F_{\text{stem}} = Y_{Gf} \cdot h_{\text{stem}} \cdot t_{\text{stem}} \cdot Y_{\text{stem}}; \quad 1 \cdot 1.62 \cdot 0.123 \cdot 25 = \quad 5.0 \text{ kN} \quad 0.062 \text{ m} \quad 0.3 \text{ kNm}$$

Weight of base;

$$F_{\text{base}} = Y_{Gf} \cdot L_{\text{base}} \cdot t_{\text{base}} \cdot Y_{\text{base}}; \quad 1 \cdot 0.875 \cdot 0.13 \cdot 25 = \quad 2.8 \text{ kN} \quad 0.438 \text{ m} \quad 1.2 \text{ kNm}$$

Retained Soil;

$$F_{\text{ret}} = Y_{Gf} \cdot (h_{\text{ret}} - t_{\text{base}}) \cdot L_{\text{toe}} \cdot Y_{mr}; \quad 1 \cdot 1.62 \cdot 0.752 \cdot 18 = \quad 21.9 \text{ kN} \quad 0.499 \text{ m} \quad 10.9 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{\text{wall friction}} = Y_{Gf} \cdot K_A \cdot \sin \delta_{r,d} \cdot Y_{mr} \cdot h_{\text{ret}}^2 / 2; \quad 1 \cdot 0.341 \cdot 0.303 \cdot 18 \cdot 1.75^2 / 2 = \quad 2.9 \text{ kN} \quad 0.875 \text{ m} \quad 2.5 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 32.6 \text{ kN} \quad M_V; \quad 15.0 \text{ kNm}$$

Loading condition 1 - Backfill to front of wall with level fill and surcharge (B)

Lever Arm Moment

Surcharge Load;

$$F_{\text{sur,h}} = K_a \cdot \cos(\delta_{r,d}) \cdot Y_Q \cdot \text{Surcharge}_Q \cdot h_{\text{ret}}; \quad 0.341 \cdot 0.953 \cdot 1.3 \cdot 10 \cdot 1.75 = \quad 7.4 \text{ kN} \quad 0.875 \text{ m} \quad 6.5 \text{ kNm}$$

Active Pressure;

$$F_{\text{ret,h}} = Y_G \cdot K_a \cdot \cos(\delta_{r,d}) \cdot Y_{mr} \cdot h_{\text{ret}}^2 / 2; \quad 1 \cdot 0.341 \cdot 0.953 \cdot 18 \cdot 1.75^2 / 2 = \quad 9.0 \text{ kN} \quad 0.583 \text{ m} \quad 5.2 \text{ kNm}$$

Additional shear load acting at z;

$$F_z = V_z \cdot Y_{Vz} \quad 0 \cdot 1.3 = \quad 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 16.3 \text{ kN} \quad M_H; \quad 11.7 \text{ kNm}$$

Weight of wall stem;

$$F_{\text{stem}} = Y_{Gf} \cdot h_{\text{stem}} \cdot t_{\text{stem}} \cdot Y_{\text{stem}}; \quad 1 \cdot 1.62 \cdot 0.123 \cdot 25 = \quad 5.0 \text{ kN} \quad 0.814 \text{ m} \quad 4.1 \text{ kNm}$$

Weight of base;

$$F_{\text{base}} = Y_{Gf} \cdot L_{\text{base}} \cdot t_{\text{base}} \cdot Y_{\text{base}}; \quad 1 \cdot 0.875 \cdot 0.13 \cdot 25 = \quad 2.8 \text{ kN} \quad 0.438 \text{ m} \quad 1.2 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{\text{wall friction}} = Y_{Gf} \cdot K_A \cdot \sin \delta_{r,d} \cdot Y_{mr} \cdot h_{\text{ret}}^2 / 2; \quad 1 \cdot 0.341 \cdot 0.303 \cdot 18 \cdot 1.75^2 / 2 = \quad 2.9 \text{ kN} \quad 0.875 \text{ m} \quad 2.5 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 10.7 \text{ kN} \quad M_V; \quad 7.8 \text{ kNm}$$

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 7 of 20

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (C)

Lever Arm Moment

Active Pressure;

$$F_{\text{ret,h}} = \gamma_G \cdot K_a \cdot \cos(\delta_{r,d} - (90 - \alpha)) \cdot \gamma_{mr} \cdot h_{\text{eff1}}^2 / 2; \quad 1 \cdot 0.852 \cdot 0.948 \cdot 18 \cdot 2.133^2 / 2 = 33.1 \text{ kN} \quad 0.711 \text{ m} \quad 23.5 \text{ kNm}$$

Additional Point Load

$$F_{x,h} = \gamma_G \cdot \gamma_{mr} \cdot \sin(\phi'_{r,d}) \cdot \cos(\phi'_{r,d}) \cdot A; \quad 1 \cdot 18 \cdot 0.454 \cdot 0.891 \cdot 0.253 = 1.8 \text{ kN} \quad 1.750 \text{ m} \quad 3.2 \text{ kNm}$$

Additional shear load acting at z;

$$F_z = V_z \cdot \gamma_{Vz} \quad 0 \cdot 1.3 = 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 34.9 \text{ kN} \quad M_H; \quad 26.7 \text{ kNm}$$

Weight of wall stem;

$$F_{\text{stem}} = \gamma_{Gf} \cdot h_{\text{stem}} \cdot t_{\text{stem}} \cdot \gamma_{\text{stem}}; \quad 1 \cdot 1.62 \cdot 0.123 \cdot 25 = 5.0 \text{ kN} \quad 0.062 \text{ m} \quad 0.3 \text{ kNm}$$

Weight of base;

$$F_{\text{base}} = \gamma_{Gf} \cdot L_{\text{base}} \cdot t_{\text{base}} \cdot \gamma_{\text{base}}; \quad 1 \cdot 0.875 \cdot 0.13 \cdot 25 = 2.8 \text{ kN} \quad 0.438 \text{ m} \quad 1.2 \text{ kNm}$$

Retained Soil;

$$F_{\text{ret}} = \gamma_{Gf} \cdot ((h_{\text{ret}} - t_{\text{base}}) + (L_{\text{toe}} \cdot \tan(\beta) / 2)) \cdot L_{\text{toe}} \cdot \gamma_{mr}; \quad 1 \cdot (1.62 + (0.752 \cdot 0.577 / 2)) \cdot 0.752 \cdot 18 = 24.9 \text{ kN} \quad 0.499 \text{ m} \quad 12.4 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{\text{wall frict}} = \gamma_{Gf} \cdot K_A \cdot \sin \delta_{r,d} \cdot \gamma_{mr} \cdot h_{\text{eff1}}^2 / 2; \quad 1 \cdot 0.852 \cdot 0.303 \cdot 18 \cdot 2.133^2 / 2 = 10.6 \text{ kN} \quad 0.875 \text{ m} \quad 9.3 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 43.3 \text{ kN} \quad M_V; \quad 23.2 \text{ kNm}$$

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (D)

Lever Arm Moment

Active Pressure;

$$F_{\text{ret,h}} = \gamma_G \cdot K_a \cdot \cos(\delta_{r,d}) \cdot \gamma_{mr} \cdot h_{\text{eff2}}^2 / 2; \quad 1 \cdot 0.852 \cdot 0.953 \cdot 18 \cdot 1.75^2 / 2 = 22.4 \text{ kN} \quad 0.583 \text{ m} \quad 13.1 \text{ kNm}$$

Additional Point Load

$$F_{x,h} = \gamma_G \cdot \gamma_{mr} \cdot \sin(\phi'_{r,d}) \cdot \cos(\phi'_{r,d}) \cdot A; \quad 1 \cdot 18 \cdot 0.454 \cdot 0.891 \cdot 0.088 = 0.6 \text{ kN} \quad 1.750 \text{ m} \quad 1.1 \text{ kNm}$$

Additional shear load acting at z;

$$F_z = V_z \cdot \gamma_{Vz} \quad 0 \cdot 1.3 = 0.0 \text{ kN} \quad 1.250 \text{ m} \quad 0.0 \text{ kNm}$$

$$\text{Horizontal Force (H):} \quad 23.0 \text{ kN} \quad M_H; \quad 14.2 \text{ kNm}$$

Weight of wall stem;

$$F_{\text{stem}} = \gamma_{Gf} \cdot h_{\text{stem}} \cdot t_{\text{stem}} \cdot \gamma_{\text{stem}}; \quad 1 \cdot 1.62 \cdot 0.123 \cdot 25 = 5.0 \text{ kN} \quad 0.814 \text{ m} \quad 4.1 \text{ kNm}$$

Weight of base;

$$F_{\text{base}} = \gamma_{Gf} \cdot L_{\text{base}} \cdot t_{\text{base}} \cdot \gamma_{\text{base}}; \quad 1 \cdot 0.875 \cdot 0.13 \cdot 25 = 2.8 \text{ kN} \quad 0.438 \text{ m} \quad 1.2 \text{ kNm}$$

Friction on virtual Back of wall;

$$F_{\text{wall frict}} = \gamma_{Gf} \cdot K_A \cdot \sin \delta_{r,d} \cdot \gamma_{mr} \cdot h_{\text{eff2}}^2 / 2; \quad 1 \cdot 0.852 \cdot 0.303 \cdot 18 \cdot 1.75^2 / 2 = 7.1 \text{ kN} \quad 0.875 \text{ m} \quad 6.2 \text{ kNm}$$

$$\text{Vertical Force (V):} \quad 14.9 \text{ kN} \quad M_V; \quad 11.5 \text{ kNm}$$

2.4 Summary of forces and moments on wall

Equilibrium	H	M _H	V	M _V
A: LC1 - Backfill to rear:	16.1 kN	11.6 kNm	29.3 kN	13.5 kNm
B: LC1 - Backfill to front:	16.2 kN	11.6 kNm	9.6 kN	7.0 kNm
C: LC2 - Backfill to rear:	36.1 kN	26.3 kNm	40.2 kN	22.0 kN
D: LC2 - Backfill to front:	23.3 kN	13.6 kNm	13.9 kN	10.8 kN
Combination 1	H	M _H	V	M _V
A: LC1 - Backfill to rear:	16.2 kN	11.4 kNm	32.6 kN	15.0 kNm
B: LC1 - Backfill to front:	16.3 kN	11.5 kNm	10.6 kN	7.8 kNm
C: LC2 - Backfill to rear:	26.6 kN	17.2 kNm	41.2 kN	21.4 kN
D: LC2 - Backfill to front:	17.9 kN	9.7 kNm	13.3 kN	10.1 kN
Combination 2	H	M _H	V	M _V
A: LC1 - Backfill to rear:	16.3 kN	11.6 kNm	32.6 kN	15.0 kNm
B: LC1 - Backfill to front:	16.3 kN	11.7 kNm	10.7 kN	7.8 kNm
C: LC2 - Backfill to rear:	34.9 kN	26.7 kNm	43.3 kN	23.2 kN
D: LC2 - Backfill to front:	23.0 kN	14.2 kNm	14.9 kN	11.5 kN

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 8 of 20

2.5 Resultant actions

Sliding force

Assuming the characteristic base friction (μ) is equal to the vertical force multiplied by **0.4**

		<u>Equilibrium</u>	<u>Combination 1</u>	<u>Combination 2</u>
V• μ -H	LC1 - Backfill to rear:	4.3 kN 0.73 ULS Ratio	3.1 kN 0.81 ULS Ratio	3.2 kN 0.80 ULS Ratio
	LC1 - Backfill to front:	12.3 kN 0.24 ULS Ratio	12.0 kN 0.26 ULS Ratio	12.1 kN 0.26 ULS Ratio
	LC2 - Backfill to rear:	20.0 kN 0.45 ULS Ratio	10.1 kN 0.62 ULS Ratio	17.6 kN 0.50 ULS Ratio
	LC2 - Backfill to front:	17.7 kN 0.24 ULS Ratio	12.6 kN 0.30 ULS Ratio	17.0 kN 0.26 ULS Ratio

Resultant moment *Positive values indicate a stabilising moment and negative values indicate a destabilising moment

		<u>Equilibrium</u>	<u>Combination 1</u>	<u>Combination 2</u>
M_V - M_H	LC1 - Backfill to rear:	1.9 kNm 1.17 ULS Ratio	3.6 kNm 1.31 ULS Ratio	3.4 kNm 1.29 ULS Ratio
	LC1 - Backfill to front:	-4.6 kNm 0.60 ULS Ratio	-3.7 kNm 0.68 ULS Ratio	-3.9 kNm 0.67 ULS Ratio
	LC2 - Backfill to rear:	-4.3 kNm 0.84 ULS Ratio	4.3 kNm 1.25 ULS Ratio	-3.5 kNm 0.87 ULS Ratio
	LC2 - Backfill to front:	-2.8 kNm 0.79 ULS Ratio	0.4 kNm 1.05 ULS Ratio	-2.6 kNm 0.81 ULS Ratio

2.6 Design Values

The stability of the structure is defined by the EQU load combination and therefore the stability of the foundation design should be based upon the following maximum values which relate to this specific load combination. These values are pro-rated to take account of the width of the retaining wall. The loading condition will determine the direction of the sliding force and whether the moments are clockwise or anti-clockwise.

Resultant sliding force; 20.0 kN/m - Loading condition 2 (Backfill to the rear)
Vertical load; 40.2 kN/m - Loading condition 2 (Backfill to the rear)
Resultant destabilising moment; 4.6 kNm/m - Loading condition 1 (Backfill to the front)

The structural design of the retaining wall is based upon the following maximum pro-rated values from Combinations 1 & 2.

Resultant sliding force; 17.6 kN/m - Combination 2 with loading condition 2 (Backfill to the rear)
Resultant anti-clockwise destabilising moment; 3.5 kNm/m - Combination 2 with loading condition 2 (Backfill to the rear)
Resultant clockwise destabilising moment; 3.9 kNm/m - Combination 2 with loading condition 1 (Backfill to the front)

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0


BY: S.J.H

CHK: C.B.

SHEET: 9 of 20

3.1 Analysis Height 1

Analysis height 1 (S1) 500 mm
Soil depth at S1 500 mm



Area Related to Additional Line Load	Comb' 1	Comb' 2
Property A	0.401m	0.474m
Property B	0.232m	0.274m
Property C	0.256m	0.242m
Property D	-0.020m	0.029m
Property E	-0.037m	0.047m
Property F	-0.013m	0.015m
Area of Soil (A)	-0.005 m ²	0.007 m ²

Loading condition 1 -Backfill to rear of wall with level fill and surcharge (combination 1) (A)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.276 \cdot 0.923 \cdot 1.5 \cdot 10 \cdot 0.5 =$	1.9 kN	0.250 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.276 \cdot 0.923 \cdot 18 \cdot 0.5^2 / 2 =$	0.8 kN	0.167 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$	$0.0 =$	0.0 kN	0.000 m
Horizontal Force (H):		2.7 kN	$M_H:$	0.6 kNm

Loading condition 1 -Backfill to front of wall with level fill and surcharge (combination 1) (B)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.276 \cdot 0.929 \cdot 1.5 \cdot 10 \cdot 0.5 =$	1.9 kN	0.250 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.276 \cdot 0.929 \cdot 18 \cdot 0.5^2 / 2 =$	0.8 kN	0.167 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$	$0.0 =$	0.0 kN	0.000 m
Horizontal Force (H):		2.7 kN	$M_H:$	0.6 kNm

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (combination 1) (C)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.538 \cdot 0.923 \cdot 18 \cdot 0.5^2 / 2 =$	1.5kN	0.167 m
Additional Point Load	$F_{x_h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1.35 \cdot 18 \cdot 0.537 \cdot 0.843 \cdot -0.005 =$	-0.1kN	0.500 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$	$0.0 =$	0.0 kN	0.000 m
Horizontal Force (H):		1.5 kN	$M_H:$	0.2 kNm

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (combination 1) (D)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.538 \cdot 0.929 \cdot 18 \cdot 0.5^2 / 2 =$	1.5kN	0.167 m
Additional Point Load	$F_{x_h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1.35 \cdot 18 \cdot 0.537 \cdot 0.843 \cdot -0.005 =$	-0.1kN	0.500 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$	$0.0 =$	0.0 kN	0.000 m
Horizontal Force (H):		1.5 kN	$M_H:$	0.2 kNm

Loading condition 1 -Backfill to rear of wall with level fill and surcharge (combination 2) (A)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.341 \cdot 0.948 \cdot 1.3 \cdot 10 \cdot 0.5 =$	2.1 kN	0.250 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.341 \cdot 0.948 \cdot 18 \cdot 0.5^2 / 2 =$	0.7 kN	0.167 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$	$0.0 =$	0.0 kN	0.000 m
Horizontal Force (H):		2.8 kN	$M_H:$	0.6 kNm

Loading condition 1 -Backfill to front of wall with level fill and surcharge (combination 2) (B)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.341 \cdot 0.953 \cdot 1.3 \cdot 10 \cdot 0.5 =$	2.1 kN	0.250 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.341 \cdot 0.953 \cdot 18 \cdot 0.5^2 / 2 =$	0.7 kN	0.167 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$	$0.0 =$	0.0 kN	0.000 m
Horizontal Force (H):		2.8 kN	$M_H:$	0.6 kNm

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (combination 2) (C)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.852 \cdot 0.948 \cdot 18 \cdot 0.5^2 / 2 =$	1.8kN	0.167 m
Additional Point Load	$F_{x_h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1 \cdot 18 \cdot 0.454 \cdot 0.891 \cdot 0.007 =$	0.1kN	0.500 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$	$0.0 =$	0.0 kN	0.000 m
Horizontal Force (H):		1.9 kN	$M_H:$	0.3 kNm

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (combination 2) (D)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.852 \cdot 0.953 \cdot 18 \cdot 0.5^2 / 2 =$	1.8kN	0.167 m
Additional Point Load	$F_{x_h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1 \cdot 18 \cdot 0.454 \cdot 0.891 \cdot 0.007 =$	0.1kN	0.500 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$	$0.0 =$	0.0 kN	0.000 m
Horizontal Force (H):		1.9 kN	$M_H:$	0.3 kNm

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H


CHK: C.B.

SHEET: 10 of 20

3.2 Analysis Height 2

Analysis height 2 (S2) 1155 mm
Soil depth at S2 1155 mm

Area Related to Additional Line Load	Comb' 1	Comb' 2
Property A	0.927m	1.095m
Property B	0.535m	0.632m
Property C	0.591m	0.558m
Property D	-0.047m	0.066m
Property E	-0.085m	0.108m
Property F	-0.030m	0.034m
Area of Soil (A)	-0.027 m ²	0.038 m ²



Loading condition 1 -Backfill to rear of wall with level fill and surcharge (combination 1) (A)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d - (90 - \alpha)) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.276 \cdot 0.923 \cdot 1.5 \cdot 10 \cdot 1.155 =$	4.4 kN	0.578 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - \alpha)) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.276 \cdot 0.923 \cdot 18 \cdot 1.155^2 / 2 =$	4.1 kN	0.385 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.655 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		8.5 kN	$M_H:$	4.1 kNm

Loading condition 1 -Backfill to front of wall with level fill and surcharge (combination 1) (B)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.276 \cdot 0.929 \cdot 1.5 \cdot 10 \cdot 1.155 =$	4.4 kN	0.578 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.276 \cdot 0.929 \cdot 18 \cdot 1.155^2 / 2 =$	4.2 kN	0.385 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.655 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		8.6 kN	$M_H:$	4.2 kNm

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (combination 1) (C)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - \alpha)) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.538 \cdot 0.923 \cdot 18 \cdot 1.155^2 / 2 =$	8.0kN	0.385 m
Additional Point Load	$F_{x,h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1.35 \cdot 18 \cdot 0.537 \cdot 0.843 \cdot -0.027 =$	-0.3kN	1.155 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.655 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		7.8 kN	$M_H:$	2.8 kNm

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (combination 1) (D)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.538 \cdot 0.929 \cdot 18 \cdot 1.155^2 / 2 =$	8.1kN	0.385 m
Additional Point Load	$F_{x,h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1.35 \cdot 18 \cdot 0.537 \cdot 0.843 \cdot -0.027 =$	-0.3kN	1.155 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.655 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		7.8 kN	$M_H:$	2.8 kNm

Loading condition 1 -Backfill to rear of wall with level fill and surcharge (combination 2) (A)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d - (90 - \alpha)) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.341 \cdot 0.948 \cdot 1.3 \cdot 10 \cdot 1.155 =$	4.9 kN	0.578 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - \alpha)) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.341 \cdot 0.948 \cdot 18 \cdot 1.155^2 / 2 =$	3.9 kN	0.385 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.655 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		8.7 kN	$M_H:$	4.3 kNm

Loading condition 1 -Backfill to front of wall with level fill and surcharge (combination 2) (B)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.341 \cdot 0.953 \cdot 1.3 \cdot 10 \cdot 1.155 =$	4.9 kN	0.578 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.341 \cdot 0.953 \cdot 18 \cdot 1.155^2 / 2 =$	3.9 kN	0.385 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.655 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		8.8 kN	$M_H:$	4.3 kNm

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (combination 2) (C)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - \alpha)) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.852 \cdot 0.948 \cdot 18 \cdot 1.155^2 / 2 =$	9.7kN	0.385 m
Additional Point Load	$F_{x,h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1 \cdot 18 \cdot 0.454 \cdot 0.891 \cdot 0.038 =$	0.3kN	1.155 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.655 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		10.0 kN	$M_H:$	4.1 kNm

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (combination 2) (D)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.852 \cdot 0.953 \cdot 18 \cdot 1.155^2 / 2 =$	9.7kN	0.385 m
Additional Point Load	$F_{x,h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1 \cdot 18 \cdot 0.454 \cdot 0.891 \cdot 0.038 =$	0.3kN	1.155 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.655 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		10.0 kN	$M_H:$	4.1 kNm

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H


CHK: C.B.

SHEET: 11 of 20

3.3 Analysis Height 3

Analysis height 3 (S3) 1515 mm
Soil depth at S3 1515 mm

Area Related to Additional Line Load	Comb' 1	Comb' 2
Property A	1.216m	1.436m
Property B	0.702m	0.829m
Property C	0.775m	0.732m
Property D	-0.061m	0.087m
Property E	-0.112m	0.141m
Property F	-0.039m	0.044m
Area of Soil (A)	-0.046 m ²	0.066 m ²



Loading condition 1 -Backfill to rear of wall with level fill and surcharge (combination 1) (A)

Surcharge Load	$F_{sur_h}=K_a \cdot \cos(\delta r.d-(90-a)) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.276 \cdot 0.923 \cdot 1.5 \cdot 10 \cdot 1.515=$	5.8 kN	0.758 m	4.4 kNm
Active Pressure	$F_{ret_h}=\gamma G \cdot K_a \cdot \cos(\delta r.d-(90-a)) \cdot \gamma m r \cdot h^2/2;$	$1.35 \cdot 0.276 \cdot 0.923 \cdot 18 \cdot 1.515^2/2=$	7.1 kN	0.505 m	3.6 kNm
Shear at z	$F_z=V_z \cdot \gamma V_z$	$0 \cdot 1.5=$	0.0 kN	1.015 m	0.0 kNm
Moment at z	$M_z=M_z \cdot \gamma M_z$		0.0 kN	0.000 m	0.0 kNm
Horizontal Force (H):			12.9 kN	$M_H:$	8.0 kNm

Loading condition 1 -Backfill to front of wall with level fill and surcharge (combination 1) (B)

Surcharge Load	$F_{sur_h}=K_a \cdot \cos(\delta r.d) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.276 \cdot 0.929 \cdot 1.5 \cdot 10 \cdot 1.515 =$	5.8 kN	0.758 m	4.4 kNm
Active Pressure	$F_{ret_h}=\gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2/2;$	$1.35 \cdot 0.276 \cdot 0.929 \cdot 18 \cdot 1.515^2/2 =$	7.2 kN	0.505 m	3.6 kNm
Shear at z	$F_z=V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	1.015 m	0.0 kNm
Moment at z	$M_z=M_z \cdot \gamma M_z$		0.0 kN	0.000 m	0.0 kNm
Horizontal Force (H):			13.0 kN	$M_H:$	8.0 kNm

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (combination 1) (C)

Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.538 \cdot 0.923 \cdot 18 \cdot 1.515^2 / 2 =$	13.8kN	0.505 m	7.0 kNm
Additional Point Load	$F_{x,h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1.35 \cdot 18 \cdot 0.537 \cdot 0.843 \cdot -0.046 =$	-0.5kN	1.515 m	-0.8 kNm
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	1.015 m	0.0 kNm
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m	0.0 kNm
Horizontal Force (H):			13.3 kN	$M_H:$	6.2 kNm

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (combination 1) (D)

Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.538 \cdot 0.929 \cdot 18 \cdot 1.515^2 / 2 =$	13.9kN	0.505 m	7.0 kNm
Additional Point Load	$F_{x,h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1.35 \cdot 18 \cdot 0.537 \cdot 0.843 \cdot -0.046 =$	-0.5kN	1.515 m	-0.8 kNm
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	1.015 m	0.0 kNm
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m	0.0 kNm
Horizontal Force (H):			13.4 kN	$M_H:$	6.3 kNm

Loading condition 1 -Backfill to rear of wall with level fill and surcharge (combination 2) (A)

Surcharge Load	$F_{sur_h}=K_a \cdot \cos(\delta r.d-(90-a)) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.341 \cdot 0.948 \cdot 1.3 \cdot 10 \cdot 1.515=$	6.4 kN	0.758 m	4.8 kNm
Active Pressure	$F_{ret_h}=\gamma G \cdot K_a \cdot \cos(\delta r.d-(90-a)) \cdot \gamma m r \cdot h^2/2;$	$1 \cdot 0.341 \cdot 0.948 \cdot 18 \cdot 1.515^2/2=$	6.7 kN	0.505 m	3.4 kNm
Shear at z	$F_z=V_z \cdot \gamma V_z$	$0 \cdot 1.3=$	0.0 kN	1.015 m	0.0 kNm
Moment at z	$M_z=M_z \cdot \gamma M_z$		0.0 kN	0.000 m	0.0 kNm
		Horizontal Force (H):	13.0 kN	$M_H:$	8.2 kNm

Loading condition 1 -Backfill to front of wall with level fill and surcharge (combination 2) (B)

Surcharge Load	$F_{sur_h}=K_a \cdot \cos(\delta r.d) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.341 \cdot 0.953 \cdot 1.3 \cdot 10 \cdot 1.515=$	6.4 kN	0.758 m	4.8 kNm
Active Pressure	$F_{ret_h}=\gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2/2;$	$1 \cdot 0.341 \cdot 0.953 \cdot 18 \cdot 1.515^2/2=$	6.7 kN	0.505 m	3.4 kNm
Shear at z	$F_z=V_z \cdot \gamma V_z$	$0 \cdot 1.3=$	0.0 kN	1.015 m	0.0 kNm
Moment at z	$M_z=M_z \cdot \gamma M_z$		0.0 kN	0.000 m	0.0 kNm
Horizontal Force (H):			13.1 kN	$M_H:$	8.2 kNm

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (combination 2) (C)

Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90-a)) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.852 \cdot 0.948 \cdot 18 \cdot 1.515^2 / 2 =$	16.7kN	0.505 m	8.4 kNm
Additional Point Load	$F_{x,h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1 \cdot 18 \cdot 0.454 \cdot 0.891 \cdot 0.066 =$	0.5kN	1.515 m	0.7 kNm
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	1.015 m	0.0 kNm
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m	0.0 kNm
Horizontal Force (H):			17.2 kN	$M_H:$	9.2 kNm

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (combination 2) (D)

Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.852 \cdot 0.953 \cdot 18 \cdot 1.515^2 / 2 =$	16.8kN	0.505 m	8.5 kNm
Additional Point Load	$F_{x,h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1 \cdot 18 \cdot 0.454 \cdot 0.891 \cdot 0.066 =$	0.5kN	1.515 m	0.7 kNm
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	1.015 m	0.0 kNm
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m	0.0 kNm
Horizontal Force (H):			17.3 kN	$M_H:$	9.2 kNm

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0


BY: S.J.H

CHK: C.B.

SHEET: 12 of 20

3.3 Analysis Height Z

Height - Variable z (Sz) 500 mm
Soil depth at Sz 500 mm



Area Related to Additional Line Load	Comb' 1	Comb' 2
Property A	0.401m	0.474m
Property B	0.232m	0.274m
Property C	0.256m	0.242m
Property D	-0.020m	0.029m
Property E	-0.037m	0.047m
Property F	-0.013m	0.015m
Area of Soil (A)	-0.005 m ²	0.007 m ²

Loading condition 1 -Backfill to rear of wall with level fill and surcharge (combination 1) (A)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.276 \cdot 0.923 \cdot 1.5 \cdot 10 \cdot 0.5 =$	1.9 kN	0.250 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.276 \cdot 0.923 \cdot 18 \cdot 0.5^2 / 2 =$	0.8 kN	0.167 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		2.7 kN	$M_H:$	0.6 kNm

Loading condition 1 -Backfill to front of wall with level fill and surcharge (combination 1) (B)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.276 \cdot 0.929 \cdot 1.5 \cdot 10 \cdot 0.5 =$	1.9 kN	0.250 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.276 \cdot 0.929 \cdot 18 \cdot 0.5^2 / 2 =$	0.8 kN	0.167 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		2.7 kN	$M_H:$	0.6 kNm

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (combination 1) (C)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.538 \cdot 0.923 \cdot 18 \cdot 0.5^2 / 2 =$	1.5kN	0.167 m
Additional Point Load	$F_{x_h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1.35 \cdot 18 \cdot 0.537 \cdot 0.843 \cdot -0.005 =$	-0.1kN	0.500 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		1.5 kN	$M_H:$	0.2 kNm

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (combination 1) (D)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1.35 \cdot 0.538 \cdot 0.929 \cdot 18 \cdot 0.5^2 / 2 =$	1.5kN	0.167 m
Additional Point Load	$F_{x_h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1.35 \cdot 18 \cdot 0.537 \cdot 0.843 \cdot -0.005 =$	-0.1kN	0.500 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.5 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		1.5 kN	$M_H:$	0.2 kNm

Loading condition 1 -Backfill to rear of wall with level fill and surcharge (combination 2) (A)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.341 \cdot 0.948 \cdot 1.3 \cdot 10 \cdot 0.5 =$	2.1 kN	0.250 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.341 \cdot 0.948 \cdot 18 \cdot 0.5^2 / 2 =$	0.7 kN	0.167 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		2.8 kN	$M_H:$	0.6 kNm

Loading condition 1 -Backfill to front of wall with level fill and surcharge (combination 2) (B)

			Lever Arm	Moment
Surcharge Load	$F_{sur_h} = K_a \cdot \cos(\delta r.d) \cdot \gamma Q \cdot \text{Surcharge} Q \cdot h;$	$0.341 \cdot 0.953 \cdot 1.3 \cdot 10 \cdot 0.5 =$	2.1 kN	0.250 m
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.341 \cdot 0.953 \cdot 18 \cdot 0.5^2 / 2 =$	0.7 kN	0.167 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		2.8 kN	$M_H:$	0.6 kNm

Loading condition 2 - Backfill to rear of wall with sloped fill and without surcharge (combination 2) (C)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d - (90 - a)) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.852 \cdot 0.948 \cdot 18 \cdot 0.5^2 / 2 =$	1.8kN	0.167 m
Additional Point Load	$F_{x_h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1 \cdot 18 \cdot 0.454 \cdot 0.891 \cdot 0.007 =$	0.1kN	0.500 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		1.9 kN	$M_H:$	0.3 kNm

Loading condition 2 - Backfill to front of wall with sloped fill and without surcharge (combination 2) (D)

			Lever Arm	Moment
Active Pressure	$F_{ret_h} = \gamma G \cdot K_a \cdot \cos(\delta r.d) \cdot \gamma m r \cdot h^2 / 2;$	$1 \cdot 0.852 \cdot 0.953 \cdot 18 \cdot 0.5^2 / 2 =$	1.8kN	0.167 m
Additional Point Load	$F_{x_h} = \gamma G \cdot \gamma m r \cdot \sin(\phi' r.d) \cdot \cos(\phi' r.d) \cdot A;$	$1 \cdot 18 \cdot 0.454 \cdot 0.891 \cdot 0.007 =$	0.1kN	0.500 m
Shear at z	$F_z = V_z \cdot \gamma V_z$	$0 \cdot 1.3 =$	0.0 kN	0.000 m
Moment at z	$M_z = M_z \cdot \gamma M_z$		0.0 kN	0.000 m
Horizontal Force (H):		1.9 kN	$M_H:$	0.3 kNm

1750mm Standard L-Wall
with Standard Design Parameters

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 13 of 20

3.4 Summary of forces and moments on wall

These values are pro-rated to take account of the width of the retaining wall.

Combination 1	Analysis 1 @ 500		Analysis 2 @ 1155		Analysis 3 @ 1515		Analysis z @ 500	
	H	M _H	H	M _H	H	M _H	H	M _H
Rear level fill & surcharge (A)	2.7 kN	0.6 kNm	8.5 kN	4.1 kNm	12.9 kN	8.0 kNm	2.7 kN	0.6 kNm
Front level fill & surcharge (B)	2.7 kN	0.6 kNm	8.6 kN	4.2 kNm	13.0 kN	8.0 kNm	2.7 kN	0.6 kNm
Rear sloped fill without surcharge (C)	1.5 kN	0.2 kNm	7.8 kN	2.8 kNm	13.3 kN	6.2 kNm	1.5 kN	0.2 kNm
Front sloped fill without surcharge (D)	1.5 kN	0.2 kNm	7.8 kN	2.8 kNm	13.4 kN	6.3 kNm	1.5 kN	0.2 kNm
Combination 2	H	M _H	H	M _H	H	M _H	H	M _H
Rear level fill & surcharge (A)	2.8 kN	0.6 kNm	8.7 kN	4.3 kNm	13.0 kN	8.2 kNm	2.8 kN	0.6 kNm
Front level fill & surcharge (B)	2.8 kN	0.6 kNm	8.8 kN	4.3 kNm	13.1 kN	8.2 kNm	2.8 kN	0.6 kNm
Rear sloped fill without surcharge (C)	1.9 kN	0.3 kNm	10.0 kN	4.1 kNm	17.2 kN	9.2 kNm	1.9 kN	0.3 kNm
Front sloped fill without surcharge (D)	1.9 kN	0.3 kNm	10.0 kN	4.1 kNm	17.3 kN	9.2 kNm	1.9 kN	0.3 kNm

Back face is in tension values	Analysis 1 @ 500		Analysis 2 @ 1155		Analysis 3 @ 1515		Analysis z @ 500	
	H	M _H	H	M _H	H	M _H	H	M _H
Max sloped & horizontal comb' 1 & 2	2.8 kN	0.3 kNm	10.0 kN	4.1 kNm	17.2 kN	9.2 kNm	1.9 kN	0.3 kNm

Front face is in tension values	Analysis 1 @ 500		Analysis 2 @ 1155		Analysis 3 @ 1515		Analysis z @ 500	
	H	M _H	H	M _H	H	M _H	H	M _H
Max sloped & horizontal comb' 1 & 2	2.8 kN	0.6 kNm	10.0 kN	4.3 kNm	17.3 kN	9.2 kNm	2.8 kN	0.6 kNm

1750mm Standard L-Wall
with Standard Design Parameters

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 14 of 20


4.0 Wall Base Design

Analysis of the wall base is carried out at the following lengths (measured from the stem face of the wall):


Analysis length 1 (B1)	235 mm
Analysis length 2 (B2)	595 mm
Analysis length 3 (B3)	830 mm

The number of rows of bolts will determine how the forces are distributed in the base.
This design is done on the basis of an anchor system using: **1 rows of bolts**

Since the overturning forces must be balanced by the force in the anchors there can be no rotation at the pivot point. Therefore the base can be modelled as having a fixed support at the pivot point as shown below.



Anti-Clockwise rotation (two Anchor system)



Clockwise rotation (two Anchor system)

Forces in single row anchor system

$$M = FS_1 \cdot lb_1$$

Forces in two row anchor system

$$M = FS_1 \cdot lb_1 + FS_2 \cdot lb_2 \quad (1)$$

$$FS_1 / lb_1 = FS_2 / lb_2 \quad (2)$$

$$FS_1 = lb_1 \cdot FS_2 / lb_2$$

Rearrange (2)

$$M = (lb_1^2) \cdot FS_2 / lb_2 + FS_2 \cdot lb_2$$

Substituting into (1)

$$FS_2 = M / [(lb_1^2) / lb_2 + lb_2]$$

Factorise & rearrange

4.1 Anchored Anticlockwise Rotation


Maximum overturning moment	3.5 kNm
Lever arm to closest anchor (lb1)	438 mm
Lever arm to furthest anchor (lb2)	N/A

From the above equations:

$$\text{Tension force in closest anchors (FS1)} = 8.0 \text{ kN}$$

$$\text{Tension force in furthest anchors (FS2)} = 0.0 \text{ kN}$$

	X:	235mm	595mm	830mm
Tension Moment Top face:		1.6 kNm	0.0 kNm	0.0 kNm
Shear:		8.0 kN	0.0 kN	0.0 kN



4.2 Anchored Clockwise Rotation


Maximum overturning moment	3.9 kNm
Lever arm to closest anchor (lb1)	437 mm
Lever arm to furthest anchor (lb2)	N/A

From the above equations:

$$\text{Tension force in closest anchors (FS1)} = 8.9 \text{ kN}$$

$$\text{Tension force in furthest anchors (FS2)} = 0.0 \text{ kN}$$

	X:	235mm	595mm	830mm
Tension Moment Top face:		0.0 kNm	1.4 kNm	3.5 kNm
Shear:		0.0 kN	8.9 kN	8.9 kN



**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H


CHK: C.B.

SHEET: 15 of 20

5.0 Anchor Design

The anchor design, shown right, is considered for the effects of tension and shear. The dowel connections in the first row (closest to the face) and the second row are checked independently at ultimate limit state.

Char' ultimate tensile strength of dowel (f_{uk});	550 N/mm²
Dowel bar diameter(ϕ)	16 mm
Height of Shims	20 mm
Standard Embedment Length	150 mm
First Row: Dowel Bar Length (D_L)	275 mm
First Row: Effective Depth In Precast (h_{eff1});	105 mm
First Row: Effective Depth In Foundation (h_{eff2});	150 mm
Second Row: Dowel Bar Length (D_L)	N/A
Second Row: Effective Depth In Precast (h_{eff1});	N/A
Second Row: Effective Depth In Foundation (h_{eff2});	N/A



Determination of the bond resistance of grout

Conbextra GP grout has been tested in tension by the manufacturer in accordance with EN1504 Part 6 - Anchoring of reinforcing steel bar yielding the following results:

	Deformation 75kN	Maximum Load ($N_{u,m}$)
Dry test	0.49 mm	92.8 kN
Wet Test	0.44 mm	106.3 kN

Contact area of 16mm diameter test bar with 150mm embedment is equal to: 7540mm²

From the results of the tension tests in dry conditions the average bond resistance is calculated according to the following equation.

Average bond resistance;
 $f_{bm} = N_{u,m} / A;$
 $92.8 / 7540 = 12.3 \text{ N/mm}^2$

5.1 Anchorage in Precast

5.1.1 Resistance to Tension Loads

The resistance to tension loads in the pre-cast base shall be defined by the point of steel failure and the initial basic resistance of the anchor to pull-out. The design assumes that concrete cone failure and splitting failure cannot occur in the base due to the reinforcement cage used. The resistance to tension loads in the foundation is based on test data.

Maximum Tensile Load per Anchor (N);	First Row	Second Row
$N = \text{Max}\{\text{Clockwise Force, Anticlockwise Force}\} / \text{No.}$	$\text{Max}\{8,0\} / 2 = 4.5 \text{ kN}$	N/A

5.1.1.1 Steel Failure

Area of steel;	
$A_s = \pi \cdot \phi^2 / 4;$	$\pi \cdot 16^2 / 4 = 201 \text{ mm}^2$
Characteristic resistance of an anchor in the case of steel failure;	
$N_{Rk,s} = A_s \cdot f_{uk};$	$201 \cdot 550 / 1000 = 110.6 \text{ kN}$
Design resistance of an anchor in the case of steel failure;	
$N_{Rd,s} = N_{Rk,s} / \gamma_{Ms};$	$110.6 / 1.15 = 96.1 \text{ kN}$

Ratio between design action and design resistance	First Row	Second Row
$\beta_N = N / N_{Rd,s}$	$4.5 / 96.1 = 0.05$	N/A

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 16 of 20

5.1.1.2 Pull-Out Failure to Pre-Cast Base

Characteristic resistance to pull-out;

$$N_{Rk,p} = \pi \cdot \phi \cdot H_{eff} \cdot f_{dm}$$

First Row
 $\pi \cdot 16 \cdot 105 \cdot 12.3 = 64.9 \text{ kN}$

Second Row
N/A

Design tension capacity of anchorage;

$$N_{Rd,p} = N_{Rk,p} / \gamma_{grout}$$

$64.9/3 = 21.6 \text{ kN}$

N/A

Ratio between design action and design resistance

$$\beta_N = N / N_{Rd,s}$$

$4.5/21.6 = 0.21$

N/A

5.1.2 Resistance to Shear Loads

The resistance to shear loads is defined by the point of steel failure. The design assumes that the shear load acts at the failure surface and therefore there is no lever arm and that concrete pry out failure or edge failure cannot occur in the pre-cast base due to the reinforcement cage used.

Maximum shearing force per anchor;

$$V = \text{Max Shear Force} / \text{No. Dowels}$$

$17.6 / (2 \cdot 1) = 8.8 \text{ kN}$

5.1.2.1 Steel Failure, Shear Load without Lever Arm

Area of steel;

$$A_s = \pi \cdot \phi^2 / 4$$

$\pi \cdot 16^2 / 4 = 201 \text{ mm}^2$

Characteristic resistance of an anchor in the case of steel failure;

$$V_{Rk,s} = 0.5 \cdot A_s \cdot f_{yk}$$

$0.5 \cdot 201 \cdot 550 / 1000 = 55.3 \text{ kN}$

Design resistance of an anchor in the case of steel failure;

$$V_{Rd,s} = V_{Rk,s} / \gamma_{Ms}$$

$55.3 / 1.15 = 48.1 \text{ kN}$

Ratio between design action and design resistance

$$\beta_V = V / V_{Rd,s}$$

First Row
 $8.8 / 48.1 = 0.18$

Second Row
N/A

5.1.3 Resistance to combined tension and shear loads

$$(N_{ED} / N_{RD,Dowel})^{1.5} + (V_{Ed} / V_{Rd,dowel})^{1.5} < 1.0;$$

First Row
0.09

Second Row
N/A

$$(N_{ED} / N_{RD})^{1.5} + (V_{Ed} / V_{Rd})^{1.5} < 1.0;$$

0.17

N/A

$$(N_{ED} / N_{RD}) + (V_{Ed} / V_{Rd}) < 1.2;$$

0.39

N/A

5.1 Anchorage in Foundation

From Sika Technical information - Characteristic resistance to pull-out of deformed bar;

$$N_{Rk,p} = 30 \text{ kN}$$

30.0 kN

Design tension capacity of anchorage;

$$N_{Rd,p} = N_{Rk,p} / \gamma_{resin}$$

$30/3 = 10.0 \text{ kN}$

Ratio between design action and design resistance

$$\beta_N = N / N_{Rd,s}$$

First Row
 $4.5/10 = 0.45$

Second Row
N/A

Anchorage provided is adequate

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 17 of 20

6.0 Reinforcement Design


All the standard retaining walls have different reinforcement cages, however, they follow one of two patterns. The 1000mm and 1500mm are a type one and 1750mm and above are of a type 2, these are shown (right). A reinforcement check is then done on the three heights of the stem and three lengths of the base which are located to give the maximum moment and shear force with the minimum reinforcement.

Cage Provided

This retaining wall has a Type 2 cage.

Reinforcement Provided


	Diameter	Spacing	As,prov
Bar Mark 1	10.00	200	393
Bar Mark 2	10.00	200	393
Bar Mark 3	10.00	200	393



6.1 Section Analysis

Analysis height 1 (500mm)


Depth @ S1 (hS1)	118 mm
hS1 - Depth to rein' (d1)	50 mm



	As,prov	Eff' Depth	As',prov	Eff' Depth
Back face in tension	393	68	0	0
Front face in tension	393	50	0	0

Analysis height 2 (1155mm)


Depth @ S2 (hS2)	129 mm
hS2 - Depth to rein' (d1)	50 mm
hS2 - Depth to rein' (d2)	79 mm



	As,prov	Eff' Depth	As',prov	Eff' Depth
Back face in tension	393	79	393	50
Front face in tension	393	79	393	50

Analysis height 3 (1515mm)


Depth @ S3 (hS3)	135 mm
hS3 - Depth to rein' (d1)	50 mm
hS3 - Depth to rein' (d2)	85 mm
hS3 - Depth to rein' (d3)	85 mm



	As,prov	Eff' Depth	As',prov	Eff' Depth
Back face in tension	393	85	785	50
Front face in tension	785	85	393	50

Analysis height z (500mm)

Depth @ Sz (hSz)	118 mm
Depth to rein' (d1)	50 mm



	As,prov	Eff' Depth	As',prov	Eff' Depth
Back face in tension	393	68	0	0
Front face in tension	393	50	0	0

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0


BY: S.J.H

CHK: C.B.


SHEET: 18 of 20

Analysis length 1 (235mm)

Depth @ B1 (hB1)	135 mm
hB1 - Depth to rein' (d1)	85 mm
hB1 - Depth to rein' (d2)	85 mm
hB1 - Depth to rein' (d3)	50 mm



Configuration Type 1




Configuration Type 2


	As,prov	Eff' Depth	As',prov	Eff' Depth
Top face in tension	393	85	785	50
Bottom face in tension	785	85	393	50

Analysis length 2 (595mm)

Depth @ B2 (hB2)	127 mm
hB2 - Depth to rein' (d1)	0 mm
hB2 - Depth to rein' (d2)	77 mm
hB2 - Depth to rein' (d3)	50 mm



Configuration Type 1




Configuration Type 2


	As,prov	Eff' Depth	As',prov	Eff' Depth
Top face in tension	393	77	393	50
Bottom face in tension	393	77	393	50

Analysis length 3 (830mm)

Depth @ B3 (hB3)	121 mm
hB3 - Depth to rein' (d1)	0 mm
hB3 - Depth to rein' (d2)	71 mm
hB3 - Depth to rein' (d3)	50 mm



Configuration Type 1



Configuration Type 2

	As,prov	Eff' Depth	As',prov	Eff' Depth
Top face in tension	393	71	393	50
Bottom face in tension	393	71	393	50

6.2 Concrete Properties

Concrete details & design

Concrete strength class
 Characteristic compressive cylinder strength
 Characteristic compressive cube strength
 Mean value of compressive cylinder strength
 Mean value of axial tensile strength
 5% fractile of axial tensile strength
 Secant modulus of elasticity
 Partial modulus of elasticity of concrete
 Compressive strength coefficient - cl.3.1.6(1)
 Design compressive concrete strength - cl.3.1.6(1)
 Maximum aggregate size
 Deviation
 Required concrete class
 Maximum concrete strut capacity
 Minimum concrete strut capacity

Pre-Cast

C45/55

$$\begin{aligned}
 f_{ck} &= 45 \text{ N/mm}^2 \\
 f_{ck,cube} &= 55 \text{ N/mm}^2 \\
 f_{cm} &= 53 \text{ N/mm}^2 \\
 f_{ctm} &= 4 \text{ N/mm}^2 \\
 f_{ctk,0.05} &= 3 \text{ N/mm}^2 \\
 E_{cm} &= 22 \cdot (f_{cm}/10)^{0.3} = 36283 \text{ N/mm}^2 \\
 \gamma_c &= 1.50 \\
 \alpha_{cc} &= 0.85 \\
 f_{cd} &= \alpha_{cc} \cdot f_{ck} / \gamma_c = 25.5 \text{ N/mm}^2 \\
 h_{agg} &= 20 \text{ mm} \\
 \Delta C_{dev} &= 5 \text{ mm} \\
 \text{Class} &= \mathbf{XC3/4} \\
 VRd, \max(\cot(\theta) = 2.5) &= 5.08 \\
 VRd, \max(\cot(\theta) = 1.0) &= 7.38
 \end{aligned}$$

Reinforcement details

Characteristic yield strength of reinforcement
 Modulus of elasticity of reinforcement
 Partial factor for reinforcing steel - Table 2.1N
 Design yield strength of reinforcement

$$\begin{aligned}
 f_{yk} &= 500 \text{ N/mm}^2 \\
 E_s &= 210000 \text{ N/mm}^2 \\
 \gamma_s &= 1.15 \\
 f_{yd} &= f_{yk} / \gamma_s = 435 \text{ N/mm}^2
 \end{aligned}$$

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 19 of 20

6.3 Stem Reinforcement Design

	Back face in Tension			
Moment	h_1	h_2	h_3	h_Z
Moment capacity of section	9.4 kNm	11.3 kNm	12.1 kNm	9.4 kNm
Design Bending Moment	0.3 kNm	4.1 kNm	9.2 kNm	0.3 kNm
Area of tension reinforcement provided	393 mm ²	393 mm ²	393 mm ²	393 mm ²
Area of compression reinforcement provided	0 mm ²	393 mm ²	785 mm ²	0 mm ²
Effective depth to tension rein' (d _{n1})=d-Δc;	58 mm	69 mm	75 mm	58 mm
K Factor =M/(b•d _{n1} ² •fck);	0.002	0.019	0.036	0.002
Limiting k Factor = 0.5986-0.1862-0.21;	0.208	0.208	0.208	0.208
Lever arm (z) =Min(0.95•d _{n1} ,d _{n1} /2•(1+√(1-3.53k)));	55 mm	66 mm	71 mm	55 mm
Area of rein' reqd for bending (A _{s,req,b}) =M/(f _{yd} •z);	14 mm ²	141 mm ²	296 mm ²	14 mm ²
Min area reqd (A _{s,min}) = max(0.26•(f _{ctm} /f _{yk}),0.0013)•b•d _{n1} ;	115 mm ²	136 mm ²	148 mm ²	115 mm ²
where k>k' Lever arm (z) =d _{n1} /2•(1+√(1-3.53k'));				
Depth to compression reinforcement (d _{n2})=d-Δc;				
Compression Moment (M')=b•d _{n1} ² •f _{ck} •(k-K');				
Compression reinforcement reqd (A _{s'})=M'/(f _{yd} •(d _{n1} -d _{n2}));				
Tension reinforcement required (A _s) =(M-M')/f _{yd} •z+As';				
Tension reinforcement required at section (A _{s,req})	115 mm ²	141 mm ²	296 mm ²	115 mm ²
Compression reinforcement required at section (A _{s',req})	0 mm ²	0 mm ²	0 mm ²	0 mm ²
	Pass (3.4)	Pass (2.7)	Pass (1.3)	Pass (3.4)
Shear				
Shear resistance constant (C _{Rd,c}) =0.18/γ _c ;	0.1N/mm ²	0.1N/mm ²	0.1N/mm ²	0.1N/mm ²
Effective Depth Factor (k) =min(2.0,1+√(200/dn1));	2.0000	2.0000	2.0000	2.0000
Reinforcement Ratio (ρ ₁) =min(0.02,A _s /b•d _{n1});	0.0070	0.0060	0.0050	0.0070
Minimum shear resistance (V _{Rd,c,min})= 0.035•k ^{1.5} •f _{ck} ^{0.5} •b•d _{n1} ;	38.7 kN	45.9 kN	49.8 kN	38.7 kN
Shear resistance (V _{Rd,c,1}) = max(V _{Rd,c,min} ,C _{Rd,c} •k•(100•ρ ₁ •(f _{ck} /1))0.333•b•d _{n1});	44.1 kN	49.7 kN	50.8 kN	44.1 kN
Shear resistance required (V)	2.8 kN	10.0 kN	17.2 kN	1.9 kN
	Pass (9.9)	Pass (4.9)	Pass (2.9)	Pass (9.9)

	Front face in Tension			
Moment	h_1	h_2	h_3	h_Z
Moment capacity of section	6.5 kNm	11.3 kNm	24.3 kNm	6.5 kNm
Design Bending Moment	0.6 kNm	4.3 kNm	9.2 kNm	0.6 kNm
Area of tension reinforcement provided	393 mm ²	393 mm ²	785 mm ²	393 mm ²
Area of compression reinforcement provided	0 mm ²	393 mm ²	393 mm ²	0 mm ²
Effective depth to tension rein' (d _{n1})=d-Δc;	40 mm	69 mm	75 mm	40 mm
K Factor =M/(b•dn12•fck);	0.009	0.020	0.036	0.009
Limiting k Factor = 0.5986-0.1862-0.21;	0.208	0.208	0.208	0.208
Lever arm (z) =Min(0.95•d _{n1} ,d _{n1} /2•(1+√(1-3.53k)));	38 mm	66 mm	71 mm	38 mm
Area of rein' reqd for bending (A _{s,req,b}) =M/(f _{yd} •z);	39 mm ²	150 mm ²	298 mm ²	39 mm ²
Min area reqd (A _{s,min}) = max(0.26•(f _{ctm} /f _{yk}),0.0013)•b•d _{n1} ;	79 mm ²	136 mm ²	148 mm ²	79 mm ²
where k>k' Lever arm (z) =d _{n1} /2•(1+√(1-3.53k'));				
Depth to compression reinforcement (d _{n2})=d-Δc;				
Compression Moment (M')=b•d _{n1} ² •f _{ck} •(k-K');				
Compression reinforcement reqd (A _{s'})=M'/(f _{yd} •(d _{n1} -d _{n2}));				
Tension reinforcement required (A _s) =(M-M')/f _{yd} •z+As';				
Tension reinforcement required at section (A _{s,req})	79 mm ²	150 mm ²	298 mm ²	79 mm ²
Compression reinforcement required at section (A _{s',req})	0 mm ²	0 mm ²	0 mm ²	0 mm ²
	Pass (4.9)	Pass (2.6)	Pass (2.6)	Pass (4.9)
Shear				
Shear resistance constant (C _{Rd,c}) =0.18/γ _c ;	0.1N/mm ²	0.1N/mm ²	0.1N/mm ²	0.1N/mm ²
Effective Depth Factor (k) =min(2.0,1+√(200/dn1));	2.0000	2.0000	2.0000	2.0000
Reinforcement Ratio (ρ ₁) =min(0.02,A _s /b•d _{n1});	0.0100	0.0060	0.0100	0.0100
Minimum shear resistance (V _{Rd,c,min})= 0.035•k ^{1.5} •f _{ck} ^{0.5} •b•d _{n1} ;	26.6 kN	45.9 kN	49.8 kN	26.6 kN
Shear resistance (V _{Rd,c,1}) = max(V _{Rd,c,min} ,C _{Rd,c} •k•(100•ρ ₁ •(f _{ck} /1))0.333•b•d _{n1});	34.1 kN	49.7 kN	63.9 kN	34.1 kN
Shear resistance required (V)	2.8 kN	10.0 kN	17.3 kN	2.8 kN
	Pass (9.9)	Pass (4.9)	Pass (3.7)	Pass (9.9)

**1750mm Standard L-Wall
with Standard Design Parameters**

06-Jan-17

REV: 0

BY: S.J.H

CHK: C.B.

SHEET: 20 of 20

6.4 Base Reinforcement Design

	Top face in Tension		
	L_1	L_2	L_3
<u>Moment</u>			
Moment capacity of section	12.1 kNm	10.8 kNm	9.9 kNm
Design Bending Moment	1.6 kNm	1.4 kNm	3.5 kNm
Area of tension reinforcement provided	393 mm ²	393 mm ²	393 mm ²
Area of compression reinforcement provided	785 mm ²	393 mm ²	393 mm ²
Effective depth to tension rein' (d _{n1})=d-Δc;	75 mm	67 mm	61 mm
K Factor =M/(b•dn1 ² •fck);	0.006	0.007	0.021
Limiting k Factor = 0.5986-0.1862-0.21;	0.208	0.208	0.208
Lever arm (z) =Min(0.95•d _{n1} ,d _{n1} /2•(1+√(1-3.53k)));	71 mm	63 mm	58 mm
Area of rein' reqd for bending (A _{s,req,b}) =M/(f _{yd} •z);	53 mm ²	51 mm ²	138 mm ²
Min area reqd (A _{s,min}) = max(0.26•(f _{ctm} /f _{yk}),0.0013)•b•d _{n1} ;	148 mm ²	132 mm ²	121 mm ²
where k>k' Lever arm (z) =d _{n1} /2•(1+√(1-3.53k'));			
Depth to compression reinforcement (d _{n2})=d-Δc;			
Compression Moment (M')=b•d _{n1} ² •f _{ck} •(k-K');			
Compression reinforcement reqd (A _{s'})=M'/(f _{yd} •(d _{n1} -d _{n2}));			
Tension reinforcement required (A _s) =(M-M')/f _{yd} •z+As';			
Tension reinforcement required at section (A _{s,req})	148 mm ²	132 mm ²	138 mm ²
Compression reinforcement required at section (A _{s',req})	0 mm ²	0 mm ²	0 mm ²
	Pass (2.6)	Pass (2.9)	Pass (2.8)
<u>Shear</u>			
Shear resistance constant (C _{Rd,c}) =0.18/γ _c ;	0.1N/mm ²	0.1N/mm ²	0.1N/mm ²
Effective Depth Factor (k) =min(2.0,1+√(200/dn1));	2.0000	2.0000	2.0000
Reinforcement Ratio (ρ ₁) =min(0.02,A _s /b•d _{n1});	0.0050	0.0060	0.0060
Minimum shear resistance (V _{Rd,c,min})= 0.035•k ^{1.5} •f _{ck} ^{0.5} •b•d _{n1} ;	49.8 kN	44.2 kN	40.5 kN
Shear resistance (V _{Rd,c,1}) = max(V _{Rd,c,min} ,C _{Rd,c} •k•(100•ρ ₁ •(f _{ck} /1))0.333•b•d _{n1});	50.8 kN	47.9 kN	43.9 kN
Shear resistance required (V)	8.0 kN	8.9 kN	8.9 kN
	Pass (6.3)	Pass (5.3)	Pass (4.9)

	Bottom face in Tension		
	L_1	L_2	L_3
Moment capacity of section	24.3 kNm	10.8 kNm	9.9 kNm
Design Bending Moment	0.0 kNm	0.0 kNm	0.0 kNm
Area of tension reinforcement provided	785 mm ²	393 mm ²	393 mm ²
Area of compression reinforcement provided	393 mm ²	393 mm ²	393 mm ²
Effective depth to tension rein' (d _{n1})=d-Δc;	75 mm	67 mm	61 mm
K Factor =M/(b•dn1 ² •fck);	0.000	0.000	0.000
Limiting k Factor = 0.5986-0.1862-0.21;	0.208	0.208	0.208
Lever arm (z) =Min(0.95•d _{n1} ,d _{n1} /2•(1+√(1-3.53k)));	71 mm	63 mm	58 mm
Area of rein' reqd for bending (A _{s,req,b}) =M/(f _{yd} •z);	0 mm ²	0 mm ²	0 mm ²
Min area reqd (A _{s,min}) = max(0.26•(f _{ctm} /f _{yk}),0.0013)•b•d _{n1} ;	148 mm ²	132 mm ²	121 mm ²
where k>k' Lever arm (z) =d _{n1} /2•(1+√(1-3.53k'));			
Depth to compression reinforcement (d _{n2})=d-Δc;			
Compression Moment (M')=b•d _{n1} ² •f _{ck} •(k-K');			
Compression reinforcement reqd (A _{s'})=M'/(f _{yd} •(d _{n1} -d _{n2}));			
Tension reinforcement required (A _s) =(M-M')/f _{yd} •z+As';			
Tension reinforcement required at section (A _{s,req})	148 mm ²	132 mm ²	121 mm ²
Compression reinforcement required at section (A _{s',req})	0 mm ²	0 mm ²	0 mm ²
	Pass (5.3)	Pass (2.9)	Pass (3.2)
<u>Shear</u>			
Shear resistance constant (C _{Rd,c}) =0.18/γ _c ;	0.1N/mm ²	0.1N/mm ²	0.1N/mm ²
Effective Depth Factor (k) =min(2.0,1+√(200/dn1));	2.0000	2.0000	2.0000
Reinforcement Ratio (ρ ₁) =min(0.02,A _s /b•d _{n1});	0.0100	0.0060	0.0060
Minimum shear resistance (V _{Rd,c,min})= 0.035•k ^{1.5} •f _{ck} ^{0.5} •b•d _{n1} ;	49.8 kN	44.2 kN	40.5 kN
Shear resistance (V _{Rd,c,1}) = max(V _{Rd,c,min} ,C _{Rd,c} •k•(100•ρ ₁ •(f _{ck} /1))0.333•b•d _{n1});	63.9 kN	47.9 kN	43.9 kN
Shear resistance required (V)	8.0 kN	8.9 kN	8.9 kN
	Pass (7.9)	Pass (5.3)	Pass (4.9)

Concrete section is sufficiently reinforced