

Rhodri Griffiths

From: Emily Thorne <Emily@gjplanning.co.uk>
Sent: 28 April 2021 15:38
To: Rhodri Griffiths
Subject: RE: Application number - P2021/0027 - Welfare Hall, Maes y Parc, Glynneath. Reconsultation.
Attachments: CPHSP (amended 28.04.21).docx
Importance: High

Hi Rhodri,

Thanks for your time on the phone today. As discussed, please find the updated Construction Phase Health and Safety Plan, which now includes the relevant IAQM Guidance within Appendix 7.

I would appreciate if this could be passed onto Mr. Hooper to review as part of application P2021/0027. If any further information is required, please don't hesitate to get in touch.

Thanks,
Emily

Emily Thorne
Planner
Geraint John Planning Ltd

**PLEASE NOTE THAT WE AT GJP ARE WORKING REMOTELY
PLEASE CALL ON THE MOBILE NO. BELOW. THANKS**

Mob : 07807800272
DD Tel: 02920 105366
Tel : 02920 105360
Email: Emily@gjplanning.co.uk
Ad : Office 16 (House1, 2nd Floor), The Maltings, East Tyndall Street, Cardiff, CF24 5EA



www.geraintjohnplanning.co.uk

🌱 Before printing, think about the environment

From: Rhodri Griffiths <r.griffiths2@npt.gov.uk>
Sent: 28 April 2021 15:01
To: Emily Thorne <Emily@gjplanning.co.uk>
Subject: FW: Application number - P2021/0027 - Welfare Hall, Maes y Parc, Glynneath. Reconsultation.

[Fyi please see below](#)

From: Martin J. Hooper <m.hooper@npt.gov.uk>
Sent: 28 April 2021 14:05
To: Rhodri Griffiths <r.griffiths2@npt.gov.uk>
Cc: Calum Lewis <c.lewis6@npt.gov.uk>
Subject: RE: Application number - P2021/0027 - Welfare Hall, Maes y Parc, Glynneath. Reconsultation.

Hi Rhodri,

I have had a look at the Construction Phase Health & Safety Plan. There are some good measures contained in section 8.9a, which could effectively control dust if carried out correctly e.g. dust suppression, wheelwash etc.

However, I would still prefer to have the IAQM issues listed below to feature in this document.

I note Calum's comment regarding the discharge of condition 7. However, I am not sure if they relate to the current document or a previous one, so you will need to contact Calum to clarify.

Thanks

Martin

From: Martin J. Hooper

Sent: 02 February 2021 09:45

To: Rhodri Griffiths <r.griffiths2@npt.gov.uk>

Subject: Application number - P2021/0027 - Welfare Hall, Maes y Parc, Glynneath.

Hi,

There are a few nearby residences, so I would recommend the following points from the IAQM guidance be included in a dust management plan which shall be subject to agreement with the Council.

1. Display the name and contact details of person(s) accountable for air quality and dust issues on the site boundary. This may be the environment manager/engineer or the site manager.
2. Display the head or regional office contact information
3. Record all dust and air quality complaints, identify cause(s), take appropriate measures to reduce emissions in a timely manner, and record the measures taken.
4. Make the complaints log available to the local authority when asked.
5. Record any exceptional incidents that cause dust and/or air emissions, either on or off-site, and the action taken to resolve the situation in the log book.
6. Undertake daily on-site and off-site inspection, where receptors (including roads) are nearby, to monitor dust, record inspection results, and make the log available to the local authority when asked.
7. Appropriate dust mitigation measures should be used when abrasive cutting is employed e.g. wet abatement.

Thanks

Martin

We welcome correspondence in Welsh and will deal with Welsh and English correspondence to the same standards and timescales.

Croesewir gohebiaeth yn y Gymraeg a byddwn yn ymdrin â gohebiaeth Gymraeg a Saesneg i'r un safonau ac amserlenni

If you would like to use Welsh when dealing with the Council please click [here](#)

Os hoffech ddefnyddio'r Gymraeg wrth ddelio â'r Cyngor os gwelwch yn dda cliciwch [yma](#)

This message has been scanned for malware by Forcepoint. www.forcepoint.com

Click [here](#) to report this email as spam.