

Neath Port Talbot County Borough Council
The Quays
Brunel Way
Baglan Energy Park
Neath
SA11 2GG

Date: 19/04/2021
Our Ref: PLA0055977
Your Ref: P2021/0327

Dear Sir/Madam

Grid Ref: SN832101 284725 210475
Site: Powys & Onllwyn Distribution Centre, Neath
Development: Development of a Global Centre of Rail Excellence

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

In respect of the aforementioned planning application, we can confirm that Dwr Cymru Welsh Water have been previously informed of the proposed development and consulted, as a 'Specialist Consultee', in accordance with Schedule 1C Article 2D of the Town & Country Planning (Development Management Procedure) (Wales) (Amendment) Order 2016. We note that our consultation response (Ref: PPA0005167) has been acknowledged and included at Appendix 20 of the accompanying Pre-Application Consultation (PAC) Report which highlights the site is in an unsewered area. However, this response refers to our consultation to the planning development boundary outlined red in the administrative area of Powys County Council.

With respect to the planning development boundary within Neath Port Talbot County Borough Council, outlined red on the accompanying 'Site Location Plan (Neath Port Talbot)' (Drawing No. 001), we responded to a preceding pre-application consultation and advised that foul flows can communicate to the existing combined sewer crossing the development site albeit that no building shall be permitted within the protection zones of sewers measured 3 metres either side of the centreline. With respect to the submitted illustrative masterplan and parameters plan it does not appear there are any buildings within the protection zones, albeit there are also watermain assets within the site boundary and we recommend a conditions in relation to the protection of our assets as well as a foul water drainage scheme. In addition, the accompanying 'Drainage Strategy Report' and 'Surface Water Features and Flood Risk' (No. 264904) indicates proposals to dispose surface water flows to a surface water body and in principle we offer no objection albeit would advise the development is subject to Schedule 3 of the Flood and Water Management Act 2010 and therefore requires SAB consent.

Accordingly, if you are minded to grant planning permission for the above development, we would request that the following **Condition and Advisory Notes** are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets:

Condition

No development shall commence until a foul water drainage scheme for the site has been submitted to and approved in writing by the local planning authority. The scheme shall provide for the disposal of foul water flows and thereafter implemented in accordance with the approved details prior to the occupation of the development.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

No development shall commence until details of a method statement and risk assessment for the protection of the structural condition of the public sewers and watermain crossing the site has been submitted to and approved in writing by the Local Planning Authority. The approved protection measures shall be implemented in full before any other development hereby permitted has commenced, and shall be retained at all times for the duration of the approved operations including the restoration works.

Reason: To ensure that the proposed development does not affect the integrity of the public sewerage and water supply system in the interests of public health and safety.

Advisory Notes

As of 7th January 2019, this proposed development is subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore requires approval of Sustainable Drainage Systems (SuDS) features, in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. It is therefore recommended that the developer engage in consultation with Neath Port Talbot and Powys County Council, as the determining SuDS Approval Bodies (SABs), in relation to their proposals for SuDS features. Please note, Dwr Cymru Welsh Water is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation.

The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water Industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of www.dwrcymru.com.



The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water to establish the location and status of the apparatus. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

If the development will give rise to a new discharge (or alter an existing discharge) of trade effluent, directly or indirectly to the public sewerage system, then a Discharge Consent under Section 118 of the Water Industry Act 1991 is required from Dwr Cymru / Welsh Water. Please note that the issuing of a Discharge Consent is independent of the planning process and a consent may be refused although planning permission is granted.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Sion Jones
Development Control Officer
Developer Services




Welsh Water is owned by Glas Cymru – a ‘not-for-profit’ company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni ‘nid-er-elw’.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.



LEGEND(Representative of most common features)

Waste network:	Foul chamber	Surface water chamber	Outfall
Combined chamber	Combined sewer overflow	Special purpose chamber	Storm Overflow
Treatment works	Pumping station	Private sewer	Private sewer subject to Sect. 104 adoption agreement
NB: Sewer symbol colour indicates the type.	RED - Combined	GREEN - Surface Water	BROWN - Foul
Purple - Former S24 sewers (for indicative purposes only)	Private Sewer Transfer	Lateral Drain	Inspection Chamber

Notes:

Whilst every reasonable effort has been taken to correctly record the pipe material of DCWW assets, there is a possibility that in some cases pipe material (other than Asbestos Cement or Pitch Fibre) may be found to be asbestos cement (AC) or Pitch Fibre (PF). It is therefore advisable that the possible presence of AC or PF pipes be anticipated and considered as part of any risk assessment prior to excavation.

Dŵr Cymru Cyfyngedig ('the Company') gives this information as to the position of its underground apparatus by way of general guidance only and on the strict understanding that it is based on the best information available and no warranty as to its correctness is relied upon in the event of excavations or other works made in the vicinity of the company's apparatus. The onus of locating apparatus before carrying out any excavations rests entirely on you. The information which is supplied by the Company, is done so in accordance with statutory requirements of sections 198 and 199 of the Water Industry Act 1991 which is based upon the best information available and, in particular, but without prejudice to the generality of the foregoing, it should be noted that the records that are available to the Company may not disclose the existence of a water main, service pipe, sewer, lateral drain or disposal main and any associated apparatus laid before 1 September 1989, or, if they do, the particulars thereof including their position underground may not be accurate. It must be understood that the furnishing of this information is entirely without prejudice to the provision of the New Roads and Street Works Act 1991 and the Company's right to be compensated for any damage to its apparatus.

Service pipes are not generally shown but their presence should be anticipated.

**EXACT LOCATIONS OF ALL APPARATUS
TO BE DETERMINED ON SITE.**

Reproduced by permission of the Ordnance Survey on behalf of
HMSO. © Crown copyright and database right 2017.
All rights reserved.
Ordnance Survey Licence number 100019534

Map Ref: 284725,210476
Map scale: 1:5000
Printed by: Sion Jones
Printed on: 19 Apr 2021