

PLEASE NOTE:
All drawings are to be read in conjunction with all other Holder Mathias drawings and specifications and all other consultants information including but not limited to:

- Fire
- Structural / Civil
- Mechanical and electrical

Leisure Centre Target U-Values
as per Hydrock information

Input Parameter	Value
Wall U-value [W/m ² K]	0.15
Floor U-value [W/m ² K]	0.15
Roof U-value [W/m ² K]	0.15
Air Permeability [m ³ /m ² .h @ 50Pa]	4.00
Window U-value [W/m ² K]	1.40
Window G-value	0.40
Gym window G-value	0.25 (0.3max)

Retail & Library Target U-Values

External Walls:	0.26W/m ² K
Ground Floor:	0.22W/m ² K
Pitched Roof:	0.14W/m ² K
Flat Roof:	0.14W/m ² K
Glazing:	1.6W/m ² K

