

The wall box charger will just be an outlet socket, similar to image below:



As for the future provision, drawing ref.2330-01(04)101 notes that:

Summary of the electricity connection requirements

52.no low voltage single phase domestic connections with an ADMD of 5KVA

connections have been design to accommodate 3KVA generator
this offer does not give formal approval for any specific generation
installation(s), which must be applied for separately and in accordance
with energy networks associated engineering

Summary of the electricity of the reinforcement required

Offer subject to reinforcement of WPD network at Melincrythan North
56/20566 and diverted HV cable under customer ref 4155156