

FAR Structures Ltd
Consulting Structural Engineers

Wayside, 30 Brynfield Road
Langland
Swansea
SA3 4SX

m: +44(0)7703 043 608
e: andrew@farstructures.uk

STRUCTURAL CALCULATIONS

For

EXTERNAL RETAINING WALLS

at

**PLOT 36
FOREST LODGE LANE
CWMAVON
PORT TALBOT**

Project No: 22028

Date: May 2022

FAR Structures Ltd

Consulting Structural Engineers

Wayside, 30 Brynfield Road
Langland
Swansea
SA3 4SX

m: +44(0)7703 043 608
e: andrew@farstructures.uk

STRUCTURAL DESIGN PHILOSOPHY

The following structural design calculations relate to the construction of reinforced masonry retaining walls around Plot 36, Forest Lodge Lane, Cwmavon, Port Talbot.


Due to varying ground levels, three different height retaining walls have been calculated. This allows the most appropriate retaining wall construction depending on retained levels as the wall travels around the site.

Please refer to FAR Structures Ltd Drawing Number 22028-01 & 02 for retaining wall section details and plan layout.

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall			Start page no./Revision 2	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

RETAINING WALL ANALYSIS (BS 8002:1994)

TEDDS calculation version 1.2.01.08



Wall details

Retaining wall type
Height of retaining wall stem
Thickness of wall stem
Length of toe
Length of heel
Overall length of base
Thickness of base
Depth of downstand
Position of downstand
Thickness of downstand
Height of retaining wall
Depth of cover in front of wall
Depth of unplanned excavation
Height of ground water behind wall
Height of saturated fill above base
Density of wall construction
Density of base construction
Angle of rear face of wall
Angle of soil surface behind wall
Effective height at virtual back of wall

Unpropped cantilever

$h_{\text{stem}} = 2600$ mm
 $t_{\text{wall}} = 350$ mm
 $l_{\text{toe}} = 1200$ mm
 $l_{\text{heel}} = 600$ mm
 $l_{\text{base}} = l_{\text{toe}} + l_{\text{heel}} + t_{\text{wall}} = 2150$ mm
 $t_{\text{base}} = 250$ mm
 $d_{\text{ds}} = 600$ mm
 $l_{\text{ds}} = 0$ mm
 $t_{\text{ds}} = 450$ mm
 $h_{\text{wall}} = h_{\text{stem}} + t_{\text{base}} + d_{\text{ds}} = 3450$ mm
 $d_{\text{cover}} = 200$ mm
 $d_{\text{exc}} = 200$ mm
 $h_{\text{water}} = 0$ mm
 $h_{\text{sat}} = \max(h_{\text{water}} - t_{\text{base}} - d_{\text{ds}}, 0 \text{ mm}) = 0$ mm
 $\gamma_{\text{wall}} = 23.6$ kN/m³
 $\gamma_{\text{base}} = 23.6$ kN/m³
 $\alpha = 90.0$ deg
 $\beta = 20.0$ deg
 $h_{\text{eff}} = h_{\text{wall}} + l_{\text{heel}} \times \tan(\beta) = 3668$ mm

Retained material details

Mobilisation factor
Moist density of retained material

$M = 1.5$
 $\gamma_m = 18.0$ kN/m³

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall			Start page no./Revision 3	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Saturated density of retained material $\gamma_s = 21.0 \text{ kN/m}^3$

Design shear strength $\phi' = 27.5 \text{ deg}$

Angle of wall friction $\delta = 21.3 \text{ deg}$

Base material details

Moist density $\gamma_{mb} = 18.0 \text{ kN/m}^3$

Design shear strength $\phi'_b = 27.5 \text{ deg}$

Design base friction $\delta_b = 21.3 \text{ deg}$

Allowable bearing pressure $P_{\text{bearing}} = 100 \text{ kN/m}^2$

Using Coulomb theory

Active pressure coefficient for retained material

$$K_a = \sin(\alpha + \phi')^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta) \times [1 + \sqrt{(\sin(\phi' + \delta) \times \sin(\phi' - \beta) / (\sin(\alpha - \delta) \times \sin(\alpha + \beta)))})]^2) = 0.474$$

Passive pressure coefficient for base material

$$K_p = \sin(90 - \phi'_b)^2 / (\sin(90 - \delta_b) \times [1 - \sqrt{(\sin(\phi'_b + \delta_b) \times \sin(\phi'_b) / (\sin(90 + \delta_b)))})]^2) = 5.571$$

At-rest pressure

At-rest pressure for retained material $K_0 = 1 - \sin(\phi') = 0.538$

Loading details

Surcharge load on plan Surcharge = **1.5 kN/m²**

Applied vertical dead load on wall $W_{\text{dead}} = 0.0 \text{ kN/m}$


Applied vertical live load on wall $W_{\text{live}} = 0.0 \text{ kN/m}$

Position of applied vertical load on wall $l_{\text{load}} = 0 \text{ mm}$

Applied horizontal dead load on wall $F_{\text{dead}} = 0.0 \text{ kN/m}$

Applied horizontal live load on wall $F_{\text{live}} = 0.0 \text{ kN/m}$

Height of applied horizontal load on wall $h_{\text{load}} = 0 \text{ mm}$



Loads shown in kN/m, pressures shown in kN/m²

Vertical forces on wall

Wall stem $w_{\text{wall}} = h_{\text{stem}} \times t_{\text{wall}} \times \gamma_{\text{wall}} = 21.5 \text{ kN/m}$

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall			Start page no./Revision 4	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Wall base

$$W_{base} = l_{base} \times t_{base} \times \gamma_{base} = \mathbf{12.7 \text{ kN/m}}$$

Wall downstand

$$W_{ds} = d_{ds} \times t_{ds} \times \gamma_{base} = \mathbf{6.4 \text{ kN/m}}$$

Surcharge

$$W_{sur} = \text{Surcharge} \times l_{heel} = \mathbf{0.9 \text{ kN/m}}$$

Moist backfill to top of wall

$$W_{m_w} = l_{heel} \times (h_{stem} - h_{sat}) \times \gamma_m = \mathbf{28.1 \text{ kN/m}}$$

Moist backfill above top of wall

$$W_{m_s} = 0.5 \times l_{heel}^2 \times \tan(\beta) \times \gamma_m = \mathbf{1.2 \text{ kN/m}}$$

Soil in front of wall

$$W_p = l_{toe} \times d_{cover} \times \gamma_{mb} = \mathbf{4.3 \text{ kN/m}}$$

Total vertical load

$$W_{total} = W_{wall} + W_{base} + W_{ds} + W_{sur} + W_{m_w} + W_{m_s} + W_p = \mathbf{75 \text{ kN/m}}$$

Horizontal forces on wall

Surcharge

$$F_{sur} = K_a \times \cos(90 - \alpha + \delta) \times \text{Surcharge} \times h_{eff} = \mathbf{2.4 \text{ kN/m}}$$

Moist backfill above water table

$$F_{m_a} = 0.5 \times K_a \times \cos(90 - \alpha + \delta) \times \gamma_m \times (h_{eff} - h_{water})^2 = \mathbf{53.5 \text{ kN/m}}$$

Total horizontal load

$$F_{total} = F_{sur} + F_{m_a} = \mathbf{55.9 \text{ kN/m}}$$

Calculate stability against sliding

Passive resistance of soil in front of wall

$$F_p = 0.5 \times K_p \times \cos(\delta_b) \times (d_{cover} + t_{base} + d_{ds} - d_{exc})^2 \times \gamma_{mb} = \mathbf{33.7 \text{ kN/m}}$$

Resistance to sliding

$$F_{res} = F_p + W_{total} \times \tan(\delta_b) = \mathbf{63.0 \text{ kN/m}}$$

PASS - Resistance force is greater than sliding force

Overturning moments

Surcharge

$$M_{sur} = F_{sur} \times (h_{eff} - 2 \times d_{ds}) / 2 = \mathbf{3 \text{ kNm/m}}$$

Moist backfill above water table

$$M_{m_a} = F_{m_a} \times (h_{eff} + 2 \times h_{water} - 3 \times d_{ds}) / 3 = \mathbf{33.3 \text{ kNm/m}}$$

Soil in front of wall

$$M_{p_o} = F_p \times [2 \times d_{ds} - t_{base} - d_{cover} + d_{exc}] / 3 = \mathbf{10.7 \text{ kNm/m}}$$

Total overturning moment

$$M_{ot} = M_{sur} + M_{m_a} + M_{p_o} = \mathbf{47 \text{ kNm/m}}$$

Restoring moments

Wall stem

$$M_{wall} = W_{wall} \times (l_{toe} + t_{wall} / 2) = \mathbf{29.5 \text{ kNm/m}}$$

Wall base

$$M_{base} = W_{base} \times l_{base} / 2 = \mathbf{13.6 \text{ kNm/m}}$$

Wall downstand

$$M_{ds} = W_{ds} \times (l_{ds} + t_{ds} / 2) = \mathbf{1.4 \text{ kNm/m}}$$

Surcharge

$$M_{sur_r} = W_{sur} \times (l_{base} - l_{heel} / 2) = \mathbf{1.7 \text{ kNm/m}}$$

Moist backfill

$$M_{m_r} = (W_{m_w} \times (l_{base} - l_{heel} / 2) + W_{m_s} \times (l_{base} - l_{heel} / 3)) = \mathbf{54.2 \text{ kNm/m}}$$

Soil in front of wall

$$M_{p_r} = W_p \times l_{toe} / 2 = \mathbf{2.6 \text{ kNm/m}}$$

Total restoring moment

$$M_{rest} = M_{wall} + M_{base} + M_{ds} + M_{sur_r} + M_{m_r} + M_{p_r} = \mathbf{103.1 \text{ kNm/m}}$$

Check stability against overturning

Total overturning moment

$$M_{ot} = \mathbf{47.0 \text{ kNm/m}}$$

Total restoring moment

$$M_{rest} = \mathbf{103.1 \text{ kNm/m}}$$

PASS - Restoring moment is greater than overturning moment

Check bearing pressure

Total moment for bearing

$$M_{total} = M_{rest} - M_{ot} = \mathbf{56.1 \text{ kNm/m}}$$

Total vertical reaction

$$R = W_{total} = \mathbf{75.0 \text{ kN/m}}$$

Distance to reaction

$$X_{bar} = M_{total} / R = \mathbf{748 \text{ mm}}$$

Eccentricity of reaction

$$e = \text{abs}((l_{base} / 2) - X_{bar}) = \mathbf{327 \text{ mm}}$$

Reaction acts within middle third of base

Bearing pressure at toe

$$p_{toe} = (R / l_{base}) + (6 \times R \times e / l_{base}^2) = \mathbf{66.7 \text{ kN/m}^2}$$

Bearing pressure at heel

$$p_{heel} = (R / l_{base}) - (6 \times R \times e / l_{base}^2) = \mathbf{3.1 \text{ kN/m}^2}$$

PASS - Maximum bearing pressure is less than allowable bearing pressure

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot				Job no. 22028	
	Calcs for External Retaining Wall				Start page no./Revision 5	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by	Approved date

RETAINING WALL DESIGN (BS 8002:1994)

TEDDS calculation version 1.2.01.08

Ultimate limit state load factors

Dead load factor	$\gamma_{f_d} = 1.4$
Live load factor	$\gamma_{f_l} = 1.6$
Earth and water pressure factor	$\gamma_{f_e} = 1.4$

Factored vertical forces on wall

Wall stem	$W_{wall_f} = \gamma_{f_d} \times h_{stem} \times t_{wall} \times \gamma_{wall} = 30.1 \text{ kN/m}$
Wall base	$W_{base_f} = \gamma_{f_d} \times l_{base} \times t_{base} \times \gamma_{base} = 17.8 \text{ kN/m}$
Wall downstand	$W_{ds_f} = \gamma_{f_d} \times d_{ds} \times t_{ds} \times \gamma_{base} = 8.9 \text{ kN/m}$
Surcharge	$W_{sur_f} = \gamma_{f_l} \times \text{Surcharge} \times l_{heel} = 1.4 \text{ kN/m}$
Moist backfill to top of wall	$W_{m_w_f} = \gamma_{f_d} \times l_{heel} \times (h_{stem} - h_{sat}) \times \gamma_m = 39.3 \text{ kN/m}$
Moist backfill above top of wall	$W_{m_s_f} = \gamma_{f_d} \times 0.5 \times l_{heel}^2 \times \tan(\beta) \times \gamma_m = 1.7 \text{ kN/m}$
Soil in front of wall	$W_{p_f} = \gamma_{f_d} \times l_{toe} \times d_{cover} \times \gamma_{mb} = 6 \text{ kN/m}$
Total vertical load kN/m	$W_{total_f} = W_{wall_f} + W_{base_f} + W_{ds_f} + W_{sur_f} + W_{m_w_f} + W_{m_s_f} + W_{p_f} = 105.2$

Factored horizontal at-rest forces on wall

Surcharge	$F_{sur_f} = \gamma_{f_l} \times K_0 \times \text{Surcharge} \times h_{eff} = 4.7 \text{ kN/m}$
Moist backfill above water table	$F_{m_a_f} = \gamma_{f_e} \times 0.5 \times K_0 \times \gamma_m \times (h_{eff} - h_{water})^2 = 91.3 \text{ kN/m}$
Total horizontal load	$F_{total_f} = F_{sur_f} + F_{m_a_f} = 96 \text{ kN/m}$
Passive resistance of soil in front of wall kN/m	$F_{p_f} = \gamma_{f_e} \times 0.5 \times K_p \times \cos(\delta_b) \times (d_{cover} + t_{base} + d_{ds} - d_{exc})^2 \times \gamma_{mb} = 47.2$

Factored overturning moments

Surcharge	$M_{sur_f} = F_{sur_f} \times (h_{eff} - 2 \times d_{ds}) / 2 = 5.8 \text{ kNm/m}$
Moist backfill above water table	$M_{m_a_f} = F_{m_a_f} \times (h_{eff} + 2 \times h_{water} - 3 \times d_{ds}) / 3 = 56.8 \text{ kNm/m}$
Soil in front of wall	$M_{p_o_f} = F_{p_f} \times [2 \times d_{ds} - t_{base} - d_{cover} + d_{exc}] / 3 = 15 \text{ kNm/m}$
Total overturning moment	$M_{ot_f} = M_{sur_f} + M_{m_a_f} + M_{p_o_f} = 77.7 \text{ kNm/m}$

Restoring moments

Wall stem	$M_{wall_f} = W_{wall_f} \times (l_{toe} + t_{wall} / 2) = 41.3 \text{ kNm/m}$
Wall base	$M_{base_f} = W_{base_f} \times l_{base} / 2 = 19.1 \text{ kNm/m}$
Wall downstand	$M_{ds_f} = W_{ds_f} \times (l_{ds} + t_{ds} / 2) = 2 \text{ kNm/m}$
Surcharge	$M_{sur_r_f} = W_{sur_f} \times (l_{base} - l_{heel} / 2) = 2.7 \text{ kNm/m}$
Moist backfill	$M_{m_r_f} = (W_{m_w_f} \times (l_{base} - l_{heel} / 2) + W_{m_s_f} \times (l_{base} - l_{heel} / 3)) = 75.9 \text{ kNm/m}$
Soil in front of wall	$M_{p_r_f} = W_{p_f} \times l_{toe} / 2 = 3.6 \text{ kNm/m}$
Total restoring moment	$M_{rest_f} = M_{wall_f} + M_{base_f} + M_{ds_f} + M_{sur_r_f} + M_{m_r_f} + M_{p_r_f} = 144.7 \text{ kNm/m}$

Factored bearing pressure

Total moment for bearing	$M_{total_f} = M_{rest_f} - M_{ot_f} = 67 \text{ kNm/m}$
Total vertical reaction	$R_f = W_{total_f} = 105.2 \text{ kN/m}$
Distance to reaction	$x_{bar_f} = M_{total_f} / R_f = 637 \text{ mm}$
Eccentricity of reaction	$e_f = \text{abs}((l_{base} / 2) - x_{bar_f}) = 438 \text{ mm}$

Reaction acts outside middle third of base

Bearing pressure at toe	$p_{toe_f} = R_f / (1.5 \times x_{bar_f}) = 110.1 \text{ kN/m}^2$
Bearing pressure at heel	$p_{heel_f} = 0 \text{ kN/m}^2 = 0 \text{ kN/m}^2$
Rate of change of base reaction	$\text{rate} = p_{toe_f} / (3 \times x_{bar_f}) = 57.58 \text{ kN/m}^2/\text{m}$

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall			Start page no./Revision 6	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Bearing pressure at stem / toe

$$p_{\text{stem_toe_f}} = \max(p_{\text{toe_f}} - (\text{rate} \times l_{\text{toe}}), 0 \text{ kN/m}^2) = \mathbf{41 \text{ kN/m}^2}$$

Bearing pressure at mid stem

$$p_{\text{stem_mid_f}} = \max(p_{\text{toe_f}} - (\text{rate} \times (l_{\text{toe}} + t_{\text{wall}} / 2)), 0 \text{ kN/m}^2) = \mathbf{30.9 \text{ kN/m}^2}$$

Bearing pressure at stem / heel

$$p_{\text{stem_heel_f}} = \max(p_{\text{toe_f}} - (\text{rate} \times (l_{\text{toe}} + t_{\text{wall}})), 0 \text{ kN/m}^2) = \mathbf{20.8 \text{ kN/m}^2}$$

Design of reinforced concrete retaining wall toe (BS 8002:1994)

Material properties

Characteristic strength of concrete

$$f_{\text{cu}} = \mathbf{35 \text{ N/mm}^2}$$

Characteristic strength of reinforcement

$$f_y = \mathbf{500 \text{ N/mm}^2}$$

Base details

Minimum area of reinforcement

$$k = \mathbf{0.13 \%}$$

Cover to reinforcement in toe

$$c_{\text{toe}} = \mathbf{40 \text{ mm}}$$

Calculate shear for toe design

Shear from bearing pressure

$$V_{\text{toe_bear}} = (p_{\text{toe_f}} + p_{\text{stem_toe_f}}) \times l_{\text{toe}} / 2 = \mathbf{90.6 \text{ kN/m}}$$

Shear from weight of base

$$V_{\text{toe_wt_base}} = \gamma_{\text{f_d}} \times \gamma_{\text{base}} \times l_{\text{toe}} \times t_{\text{base}} = \mathbf{9.9 \text{ kN/m}}$$

Shear from weight of downstand

$$V_{\text{toe_wt_ds}} = \gamma_{\text{f_d}} \times \gamma_{\text{base}} \times d_{\text{ds}} \times t_{\text{ds}} = \mathbf{8.9 \text{ kN/m}}$$

Total shear for toe design

$$V_{\text{toe}} = V_{\text{toe_bear}} - V_{\text{toe_wt_base}} - V_{\text{toe_wt_ds}} = \mathbf{71.8 \text{ kN/m}}$$

Calculate moment for toe design

Moment from bearing pressure

$$M_{\text{toe_bear}} = (2 \times p_{\text{toe_f}} + p_{\text{stem_mid_f}}) \times (l_{\text{toe}} + t_{\text{wall}} / 2)^2 / 6 = \mathbf{79.1 \text{ kNm/m}}$$

Moment from weight of base


$$M_{\text{toe_wt_base}} = (\gamma_{\text{f_d}} \times \gamma_{\text{base}} \times t_{\text{base}} \times (l_{\text{toe}} + t_{\text{wall}} / 2)^2 / 2) = \mathbf{7.8 \text{ kNm/m}}$$

Moment from weight of downstand

$$M_{\text{toe_wt_ds}} = \gamma_{\text{f_d}} \times \gamma_{\text{base}} \times d_{\text{ds}} \times t_{\text{ds}} \times (l_{\text{toe}} - l_{\text{ds}} + (t_{\text{wall}} - t_{\text{ds}}) / 2) = \mathbf{10.3 \text{ kNm/m}}$$

Total moment for toe design

$$M_{\text{toe}} = M_{\text{toe_bear}} - M_{\text{toe_wt_base}} - M_{\text{toe_wt_ds}} = \mathbf{61 \text{ kNm/m}}$$



Check toe in bending

Width of toe

$$b = \mathbf{1000 \text{ mm/m}}$$

Depth of reinforcement

$$d_{\text{toe}} = t_{\text{base}} - c_{\text{toe}} - (\phi_{\text{toe}} / 2) = \mathbf{205.0 \text{ mm}}$$

Constant

$$K_{\text{toe}} = M_{\text{toe}} / (b \times d_{\text{toe}}^2 \times f_{\text{cu}}) = \mathbf{0.041}$$

Compression reinforcement is not required

Lever arm

$$z_{\text{toe}} = \min(0.5 + \sqrt{(0.25 - (\min(K_{\text{toe}}, 0.225) / 0.9))}, 0.95) \times d_{\text{toe}}$$

$$z_{\text{toe}} = \mathbf{195 \text{ mm}}$$

Area of tension reinforcement required

$$A_{\text{s_toe_des}} = M_{\text{toe}} / (0.87 \times f_y \times z_{\text{toe}}) = \mathbf{720 \text{ mm}^2/\text{m}}$$

Minimum area of tension reinforcement

$$A_{\text{s_toe_min}} = k \times b \times t_{\text{base}} = \mathbf{325 \text{ mm}^2/\text{m}}$$

Area of tension reinforcement required

$$A_{\text{s_toe_req}} = \text{Max}(A_{\text{s_toe_des}}, A_{\text{s_toe_min}}) = \mathbf{720 \text{ mm}^2/\text{m}}$$

Reinforcement provided

B785 mesh

Area of reinforcement provided

$$A_{\text{s_toe_prov}} = \mathbf{785 \text{ mm}^2/\text{m}}$$

PASS - Reinforcement provided at the retaining wall toe is adequate

Check shear resistance at toe

Design shear stress

$$v_{\text{toe}} = V_{\text{toe}} / (b \times d_{\text{toe}}) = \mathbf{0.350 \text{ N/mm}^2}$$

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall			Start page no./Revision 7	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Allowable shear stress

$$v_{adm} = \min(0.8 \times \sqrt{f_{cu}} / 1 \text{ N/mm}^2, 5) \times 1 \text{ N/mm}^2 = \mathbf{4.733 \text{ N/mm}^2}$$

PASS - Design shear stress is less than maximum shear stress

From BS8110:Part 1:1997 – Table 3.8

Design concrete shear stress

$$v_{c_toe} = \mathbf{0.607 \text{ N/mm}^2}$$

$v_{toe} < v_{c_toe}$ - No shear reinforcement required

Design of reinforced concrete retaining wall heel (BS 8002:1994)

Material properties

Characteristic strength of concrete

$$f_{cu} = \mathbf{35 \text{ N/mm}^2}$$

Characteristic strength of reinforcement

$$f_y = \mathbf{500 \text{ N/mm}^2}$$

Base details

Minimum area of reinforcement

$$k = \mathbf{0.13 \%}$$

Cover to reinforcement in heel

$$c_{heel} = \mathbf{40 \text{ mm}}$$

Calculate shear for heel design

Shear from bearing pressure

$$V_{heel_bear} = p_{stem_heel_f} \times ((3 \times x_{bar_f}) - l_{toe} - t_{wall}) / 2 = \mathbf{3.8 \text{ kN/m}}$$

Shear from weight of base

$$V_{heel_wt_base} = \gamma_{fd} \times \gamma_{base} \times l_{heel} \times t_{base} = \mathbf{5 \text{ kN/m}}$$

Shear from weight of moist backfill

$$V_{heel_wt_m} = w_{m_w_f} + w_{m_s_f} = \mathbf{41 \text{ kN/m}}$$

Shear from surcharge

$$V_{heel_sur} = w_{sur_f} = \mathbf{1.4 \text{ kN/m}}$$

Total shear for heel design

$$V_{heel} = -V_{heel_bear} + V_{heel_wt_base} + V_{heel_wt_m} + V_{heel_sur} = \mathbf{43.6 \text{ kN/m}}$$

Calculate moment for heel design

Moment from bearing pressure

$$M_{heel_bear} = p_{stem_mid_f} \times ((3 \times x_{bar_f}) - l_{toe} - t_{wall} / 2)^2 / 6 = \mathbf{1.5 \text{ kNm/m}}$$

Moment from weight of base

$$M_{heel_wt_base} = (\gamma_{fd} \times \gamma_{base} \times t_{base} \times (l_{heel} + t_{wall} / 2)^2 / 2) = \mathbf{2.5 \text{ kNm/m}}$$

Moment from weight of moist backfill

$$M_{heel_wt_m} = w_{m_w_f} \times (l_{heel} + t_{wall}) / 2 + w_{m_s_f} \times (2 \times l_{heel} / 3 + t_{wall} / 2) =$$


19.6 kNm/m

Moment from surcharge

$$M_{heel_sur} = w_{sur_f} \times (l_{heel} + t_{wall}) / 2 = \mathbf{0.7 \text{ kNm/m}}$$

Total moment for heel design

$$M_{heel} = -M_{heel_bear} + M_{heel_wt_base} + M_{heel_wt_m} + M_{heel_sur} = \mathbf{21.3 \text{ kNm/m}}$$



Check heel in bending

Width of heel

$$b = \mathbf{1000 \text{ mm/m}}$$

Depth of reinforcement

$$d_{heel} = t_{base} - c_{heel} - (\phi_{heel} / 2) = \mathbf{205.0 \text{ mm}}$$

Constant

$$K_{heel} = M_{heel} / (b \times d_{heel}^2 \times f_{cu}) = \mathbf{0.014}$$

Compression reinforcement is not required

Lever arm

$$z_{heel} = \min(0.5 + \sqrt{(0.25 - (\min(K_{heel}, 0.225) / 0.9))}, 0.95) \times d_{heel}$$

$$z_{heel} = \mathbf{195 \text{ mm}}$$

Area of tension reinforcement required

$$A_{s_heel_des} = M_{heel} / (0.87 \times f_y \times z_{heel}) = \mathbf{251 \text{ mm}^2/\text{m}}$$

Minimum area of tension reinforcement

$$A_{s_heel_min} = k \times b \times t_{base} = \mathbf{325 \text{ mm}^2/\text{m}}$$

Area of tension reinforcement required

$$A_{s_heel_req} = \text{Max}(A_{s_heel_des}, A_{s_heel_min}) = \mathbf{325 \text{ mm}^2/\text{m}}$$

Reinforcement provided

A393 mesh

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot				Job no. 22028	
	Calcs for External Retaining Wall				Start page no./Revision 8	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by	Approved date

Area of reinforcement provided

$$A_{s_heel_prov} = 393 \text{ mm}^2/\text{m}$$

PASS - Reinforcement provided at the retaining wall heel is adequate

Check shear resistance at heel

Design shear stress

$$v_{heel} = V_{heel} / (b \times d_{heel}) = 0.213 \text{ N/mm}^2$$

Allowable shear stress

$$v_{adm} = \min(0.8 \times \sqrt{f_{cu}} / 1 \text{ N/mm}^2, 5) \times 1 \text{ N/mm}^2 = 4.733 \text{ N/mm}^2$$

PASS - Design shear stress is less than maximum shear stress

From BS8110:Part 1:1997 – Table 3.8

Design concrete shear stress

$$v_{c_heel} = 0.482 \text{ N/mm}^2$$

$v_{heel} < v_{c_heel}$ - No shear reinforcement required

Design of reinforced concrete retaining wall downstand (BS 8002:1994)

Material properties

Characteristic strength of concrete

$$f_{cu} = 35 \text{ N/mm}^2$$

Characteristic strength of reinforcement

$$f_y = 500 \text{ N/mm}^2$$

Base details

Minimum area of reinforcement

$$k = 0.13 \%$$

Cover to reinforcement in downstand

$$c_{ds} = 40 \text{ mm}$$

Calculate shear for downstand design


Total shear for downstand design

$$V_{down} = \gamma_{f_e} \times K_p \times \cos(\delta_b) \times \gamma_m \times d_{ds} \times (d_{cover} + t_{base} + d_{ds} / 2) = 58.9 \text{ kN/m}$$

Calculate moment for downstand design

Total moment for downstand design

$$M_{down} = \gamma_{f_e} \times K_p \times \cos(\delta_b) \times \gamma_m \times d_{ds} \times [(d_{cover} + t_{base}) \times (t_{base} + d_{ds}) + d_{ds} \times (t_{base} / 2 + 2 \times d_{ds} / 3)] / 2 = 27.4 \text{ kNm/m}$$



Check downstand in bending

Width of downstand

$$b = 1000 \text{ mm/m}$$

Depth of reinforcement

$$d_{down} = t_{ds} - c_{ds} - (\phi_{down} / 2) = 404.0 \text{ mm}$$

Constant

$$K_{down} = M_{down} / (b \times d_{down}^2 \times f_{cu}) = 0.005$$

Compression reinforcement is not required

Lever arm

$$z_{down} = \text{Min}(0.5 + \sqrt{(0.25 - (\min(K_{down}, 0.225) / 0.9))}, 0.95) \times d_{down}$$

$$z_{down} = 384 \text{ mm}$$

Area of tension reinforcement required

$$A_{s_down_des} = M_{down} / (0.87 \times f_y \times z_{down}) = 164 \text{ mm}^2/\text{m}$$

Minimum area of tension reinforcement

$$A_{s_down_min} = k \times b \times t_{ds} = 585 \text{ mm}^2/\text{m}$$

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall			Start page no./Revision 9	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Area of tension reinforcement required

$$A_{s_down_req} = \text{Max}(A_{s_down_des}, A_{s_down_min}) = 585 \text{ mm}^2/\text{m}$$

Reinforcement provided

12 mm dia.bars @ 150 mm centres

Area of reinforcement provided

$$A_{s_down_prov} = 754 \text{ mm}^2/\text{m}$$

PASS - Reinforcement provided at the retaining wall downstand is adequate

Check shear resistance at downstand

Design shear stress

$$v_{down} = V_{down} / (b \times d_{down}) = 0.146 \text{ N/mm}^2$$

Allowable shear stress

$$v_{adm} = \min(0.8 \times \sqrt{f_{cu}} / 1 \text{ N/mm}^2, 5) \times 1 \text{ N/mm}^2 = 4.733 \text{ N/mm}^2$$

PASS - Design shear stress is less than maximum shear stress


From BS8110:Part 1:1997 – Table 3.8

Design concrete shear stress

$$v_{c_down} = 0.404 \text{ N/mm}^2$$

$v_{down} < v_{c_down}$ - No shear reinforcement required

Design of cavity reinforced masonry retaining wall stem - BS5628-2:2000



Wall details

Thickness of outer leaf of wall

$$t_{outer} = 100 \text{ mm}$$

Thickness of inner leaf of wall

$$t_{inner} = 100 \text{ mm}$$

Thickness of reinforced cavity

$$t_{cavity} = t_{wall} - t_{outer} - t_{inner} = 150 \text{ mm}$$

Depth of stem reinforcement

$$d_{stem} = 225 \text{ mm}$$

Masonry details

Masonry type

Aggregate concrete blocks no voids

Compressive strength of units

$$p_{unit} = 7.3 \text{ N/mm}^2$$

Mortar designation

(ii)

Category of manufacturing control of units

Category I

Partial safety factor for material strength

$$\gamma_{mm} = 2.0$$

Characteristic compressive strength of masonry

Least horizontal dimension of masonry units

$$b_{unit} = 100.0 \text{ mm}$$

Height of masonry units

$$h_{unit} = 215.0 \text{ mm}$$

Ratio of height to least horizontal dimension

$$\text{ratio} = h_{unit} / b_{unit} = 2.2$$

From BS5628:2 Table 3d, mortar ii

Characteristic compressive strength

$$f_k = 6.4 \text{ N/mm}^2$$

Factored horizontal at-rest forces on stem

Surcharge

$$F_{s_sur_f} = \gamma_{f_l} \times K_0 \times \text{Surcharge} \times (h_{eff} - t_{base} - d_{ds}) = 3.6 \text{ kN/m}$$

Moist backfill above water table

$$F_{s_m_a_f} = 0.5 \times \gamma_{f_e} \times K_0 \times \gamma_m \times (h_{eff} - t_{base} - d_{ds} - h_{sat})^2 = 53.9 \text{ kN/m}$$

Calculate shear for stem design

Shear at base of stem

$$V_{stem} = F_{s_sur_f} + F_{s_m_a_f} = 57.5 \text{ kN/m}$$

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot		Job no. 22028	
	Calcs for External Retaining Wall		Start page no./Revision 10	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022
		Approved by	Approved date	

Calculate moment for stem design

Surcharge

$$M_{s_sur} = F_{s_sur_f} \times (h_{stem} + t_{base}) / 2 = 5.2 \text{ kNm/m}$$

Moist backfill above water table

$$M_{s_m_a} = F_{s_m_a_f} \times (2 \times h_{sat} + h_{eff} - d_{ds} + t_{base} / 2) / 3 = 57.3 \text{ kNm/m}$$

Total moment for stem design

$$M_{stem} = M_{s_sur} + M_{s_m_a} = 62.5 \text{ kNm/m}$$

Check maximum design moment for wall stem

Width of wall

$$b = 1000 \text{ mm/m}$$

Maximum design moment

$$M_{d_stem} = 0.4 \times f_k \times b \times d_{stem}^2 / \gamma_{mm} = 64.8 \text{ kNm/m}$$

PASS - Applied moment is less than maximum design moment

Check wall stem in bending

Moment of resistance factor

$$Q = M_{stem} / d_{stem}^2 = 1.235 \text{ N/mm}^2$$

$$Q = 2 \times c \times (1 - c) \times f_k / \gamma_{mm}$$

Lever arm factor

$$c = 0.739$$

Lever arm

$$z_{stem} = \min(0.95, c) \times d_{stem} = 166.2 \text{ mm}$$

Area of tension reinforcement required

$$A_{s_stem_des} = M_{stem} \times \gamma_{ms} / (f_y \times z_{stem}) = 865 \text{ mm}^2/\text{m}$$

Minimum area of tension reinforcement

$$A_{s_stem_min} = k \times b \times t_{wall} = 455 \text{ mm}^2/\text{m}$$

Area of tension reinforcement required

$$A_{s_stem_req} = \text{Max}(A_{s_stem_des}, A_{s_stem_min}) = 865 \text{ mm}^2/\text{m}$$

Reinforcement provided

B1131 mesh

Area of reinforcement provided

$$A_{s_stem_prov} = \pi \times \phi_{stem}^2 / (4 \times s_{stem}) = 1131 \text{ mm}^2/\text{m}$$

PASS - Reinforcement provided at the retaining wall stem is adequate

Check shear resistance at wall stem

Design shear stress

$$v_{stem} = V_{stem} / (b \times d_{stem}) = 0.256 \text{ N/mm}^2$$

Basic characteristic shear strength of masonry

$$f_{vbas} = \min[0.35 + (17.5 \times A_{s_stem_prov} / (b \times d_{stem})), 0.7] \times 1 \text{ N/mm}^2$$

$$f_{vbas} = 0.438 \text{ N/mm}^2$$

Shear span

$$a = M_{stem} / V_{stem} = 1087.3 \text{ mm}$$

Characteristic shear strength of masonry

$$f_v = \text{Min}(f_{vbas} \times \max(2.5 - 0.25 \times (a / d_{stem}), 1), 1.75 \text{ N/mm}^2)$$

$$f_v = 0.566 \text{ N/mm}^2$$

Allowable shear stress

$$v_{adm} = f_v / \gamma_{mv} = 0.283 \text{ N/mm}^2$$

PASS - Design shear stress is less than maximum shear stress

Check limiting dimensions

Limiting span/effective depth ratio

$$\text{ratio}_{max} = 18.00$$

Actual span/effective depth ratio

$$\text{ratio}_{act} = (h_{stem} + d_{stem} / 2) / d_{stem} = 12.06$$

PASS - Span to depth ratio is acceptable

Axial load check

Factored axial load on wall

$$N_{wall} = ([t_{wall} \times h_{stem} \times \gamma_{wall} + W_{dead}] \times \gamma_{t_d}) + (W_{live} \times \gamma_{t_l}) = 30.1 \text{ kN/m}$$


Limiting axial load

$$N_{limit} = 0.1 \times f_k \times t_{wall} = 224.0 \text{ kN/m}$$

Applied axial load may be ignored - calculations valid

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall			Start page no./Revision 11	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Indicative retaining wall reinforcement diagram




Toe mesh - B785 - (785 mm²/m)
Heel mesh - A393 - (393 mm²/m)
Downstand bars - 12 mm dia.@ 150 mm centres - (754 mm²/m)
Stem mesh - B1131 - (1131 mm²/m)

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1500mm High			Start page no./Revision 12	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

RETAINING WALL ANALYSIS (BS 8002:1994)

TEDDS calculation version 1.2.01.08



Wall details

Retaining wall type
Height of retaining wall stem
Thickness of wall stem
Length of toe
Length of heel
Overall length of base
Thickness of base
Depth of downstand
Position of downstand
Thickness of downstand
Height of retaining wall
Depth of cover in front of wall
Depth of unplanned excavation
Height of ground water behind wall
Height of saturated fill above base
Density of wall construction
Density of base construction
Angle of rear face of wall
Angle of soil surface behind wall
Effective height at virtual back of wall

Unpropped cantilever

$h_{\text{stem}} = 1700 \text{ mm}$
 $t_{\text{wall}} = 350 \text{ mm}$
 $l_{\text{toe}} = 1100 \text{ mm}$
 $l_{\text{heel}} = 350 \text{ mm}$
 $l_{\text{base}} = l_{\text{toe}} + l_{\text{heel}} + t_{\text{wall}} = 1800 \text{ mm}$
 $t_{\text{base}} = 250 \text{ mm}$
 $d_{\text{ds}} = 0 \text{ mm}$
 $l_{\text{ds}} = 0 \text{ mm}$
 $t_{\text{ds}} = 250 \text{ mm}$
 $h_{\text{wall}} = h_{\text{stem}} + t_{\text{base}} + d_{\text{ds}} = 1950 \text{ mm}$
 $d_{\text{cover}} = 200 \text{ mm}$
 $d_{\text{exc}} = 200 \text{ mm}$
 $h_{\text{water}} = 0 \text{ mm}$
 $h_{\text{sat}} = \max(h_{\text{water}} - t_{\text{base}} - d_{\text{ds}}, 0 \text{ mm}) = 0 \text{ mm}$
 $\gamma_{\text{wall}} = 23.6 \text{ kN/m}^3$
 $\gamma_{\text{base}} = 23.6 \text{ kN/m}^3$
 $\alpha = 90.0 \text{ deg}$
 $\beta = 20.0 \text{ deg}$
 $h_{\text{eff}} = h_{\text{wall}} + l_{\text{heel}} \times \tan(\beta) = 2077 \text{ mm}$

Retained material details

Mobilisation factor
Moist density of retained material

$M = 1.5$
 $\gamma_m = 18.0 \text{ kN/m}^3$

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1500mm High			Start page no./Revision 13	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Saturated density of retained material $\gamma_s = 21.0 \text{ kN/m}^3$

Design shear strength $\phi' = 27.5 \text{ deg}$

Angle of wall friction $\delta = 21.3 \text{ deg}$

Base material details

Moist density $\gamma_{mb} = 18.0 \text{ kN/m}^3$

Design shear strength $\phi'_b = 27.5 \text{ deg}$

Design base friction $\delta_b = 21.3 \text{ deg}$

Allowable bearing pressure $P_{\text{bearing}} = 100 \text{ kN/m}^2$

Using Coulomb theory

Active pressure coefficient for retained material

$$K_a = \sin(\alpha + \phi')^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta) \times [1 + \sqrt{(\sin(\phi' + \delta) \times \sin(\phi' - \beta) / (\sin(\alpha - \delta) \times \sin(\alpha + \beta)))})^2] = 0.474$$

Passive pressure coefficient for base material

$$K_p = \sin(90 - \phi'_b)^2 / (\sin(90 - \delta_b) \times [1 - \sqrt{(\sin(\phi'_b + \delta_b) \times \sin(\phi'_b) / (\sin(90 + \delta_b)))})^2] = 5.571$$

At-rest pressure

At-rest pressure for retained material $K_0 = 1 - \sin(\phi') = 0.538$

Loading details

Surcharge load on plan Surcharge = **1.5 kN/m²**

Applied vertical dead load on wall $W_{\text{dead}} = 0.0 \text{ kN/m}$


Applied vertical live load on wall $W_{\text{live}} = 0.0 \text{ kN/m}$

Position of applied vertical load on wall $l_{\text{load}} = 0 \text{ mm}$

Applied horizontal dead load on wall $F_{\text{dead}} = 0.0 \text{ kN/m}$

Applied horizontal live load on wall $F_{\text{live}} = 0.0 \text{ kN/m}$

Height of applied horizontal load on wall $h_{\text{load}} = 0 \text{ mm}$



Loads shown in kN/m, pressures shown in kN/m²

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1500mm High			Start page no./Revision 14	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Vertical forces on wall

Wall stem	$W_{wall} = h_{stem} \times t_{wall} \times \gamma_{wall} = 14 \text{ kN/m}$
Wall base	$W_{base} = l_{base} \times t_{base} \times \gamma_{base} = 10.6 \text{ kN/m}$
Surcharge	$W_{sur} = \text{Surcharge} \times l_{heel} = 0.5 \text{ kN/m}$
Moist backfill to top of wall	$W_{m_w} = l_{heel} \times (h_{stem} - h_{sat}) \times \gamma_m = 10.7 \text{ kN/m}$
Moist backfill above top of wall	$W_{m_s} = 0.5 \times l_{heel}^2 \times \tan(\beta) \times \gamma_m = 0.4 \text{ kN/m}$
Soil in front of wall	$W_p = l_{toe} \times d_{cover} \times \gamma_{mb} = 4 \text{ kN/m}$
Total vertical load	$W_{total} = W_{wall} + W_{base} + W_{sur} + W_{m_w} + W_{m_s} + W_p = 40.3 \text{ kN/m}$

Horizontal forces on wall

Surcharge	$F_{sur} = K_a \times \cos(90 - \alpha + \delta) \times \text{Surcharge} \times h_{eff} = 1.4 \text{ kN/m}$
Moist backfill above water table	$F_{m_a} = 0.5 \times K_a \times \cos(90 - \alpha + \delta) \times \gamma_m \times (h_{eff} - h_{water})^2 = 17.1 \text{ kN/m}$
Total horizontal load	$F_{total} = F_{sur} + F_{m_a} = 18.5 \text{ kN/m}$

Calculate stability against sliding

Passive resistance of soil in front of wall	$F_p = 0.5 \times K_p \times \cos(\delta_b) \times (d_{cover} + t_{base} + d_{ds} - d_{exc})^2 \times \gamma_{mb} = 2.9 \text{ kN/m}$
Resistance to sliding	$F_{res} = F_p + W_{total} \times \tan(\delta_b) = 18.6 \text{ kN/m}$

PASS - Resistance force is greater than sliding force

Overturning moments

Surcharge	$M_{sur} = F_{sur} \times (h_{eff} - 2 \times d_{ds}) / 2 = 1.4 \text{ kNm/m}$
Moist backfill above water table	$M_{m_a} = F_{m_a} \times (h_{eff} + 2 \times h_{water} - 3 \times d_{ds}) / 3 = 11.9 \text{ kNm/m}$
Total overturning moment	$M_{ot} = M_{sur} + M_{m_a} = 13.3 \text{ kNm/m}$

Restoring moments

Wall stem	$M_{wall} = W_{wall} \times (l_{toe} + t_{wall} / 2) = 17.9 \text{ kNm/m}$
Wall base	$M_{base} = W_{base} \times l_{base} / 2 = 9.6 \text{ kNm/m}$
Surcharge	$M_{sur_r} = W_{sur} \times (l_{base} - l_{heel} / 2) = 0.9 \text{ kNm/m}$
Moist backfill	$M_{m_r} = (W_{m_w} \times (l_{base} - l_{heel} / 2) + W_{m_s} \times (l_{base} - l_{heel} / 3)) = 18.1 \text{ kNm/m}$
Soil in front of wall	$M_{p_r} = W_p \times l_{toe} / 2 = 2.2 \text{ kNm/m}$
Total restoring moment	$M_{rest} = M_{wall} + M_{base} + M_{sur_r} + M_{m_r} + M_{p_r} = 48.6 \text{ kNm/m}$

Check stability against overturning

Total overturning moment	$M_{ot} = 13.3 \text{ kNm/m}$
Total restoring moment	$M_{rest} = 48.6 \text{ kNm/m}$

PASS - Restoring moment is greater than overturning moment

Check bearing pressure

Total moment for bearing	$M_{total} = M_{rest} - M_{ot} = 35.3 \text{ kNm/m}$
Total vertical reaction	$R = W_{total} = 40.3 \text{ kN/m}$
Distance to reaction	$X_{bar} = M_{total} / R = 876 \text{ mm}$
Eccentricity of reaction	$e = \text{abs}((l_{base} / 2) - X_{bar}) = 24 \text{ mm}$

Reaction acts within middle third of base

Bearing pressure at toe	$p_{toe} = (R / l_{base}) + (6 \times R \times e / l_{base}^2) = 24.2 \text{ kN/m}^2$
Bearing pressure at heel	$p_{heel} = (R / l_{base}) - (6 \times R \times e / l_{base}^2) = 20.6 \text{ kN/m}^2$

PASS - Maximum bearing pressure is less than allowable bearing pressure

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot				Job no. 22028	
	Calcs for External Retaining Wall - 1500mm High				Start page no./Revision 15	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by	Approved date

RETAINING WALL DESIGN (BS 8002:1994)

TEDDS calculation version 1.2.01.08

Ultimate limit state load factors

Dead load factor	$\gamma_{f_d} = 1.4$
Live load factor	$\gamma_{f_l} = 1.6$
Earth and water pressure factor	$\gamma_{f_e} = 1.4$

Factored vertical forces on wall

Wall stem	$W_{wall_f} = \gamma_{f_d} \times h_{stem} \times t_{wall} \times \gamma_{wall} = 19.7 \text{ kN/m}$
Wall base	$W_{base_f} = \gamma_{f_d} \times l_{base} \times t_{base} \times \gamma_{base} = 14.9 \text{ kN/m}$
Surcharge	$W_{sur_f} = \gamma_{f_l} \times \text{Surcharge} \times l_{heel} = 0.8 \text{ kN/m}$
Moist backfill to top of wall	$W_{m_w_f} = \gamma_{f_d} \times l_{heel} \times (h_{stem} - h_{sat}) \times \gamma_m = 15 \text{ kN/m}$
Moist backfill above top of wall	$W_{m_s_f} = \gamma_{f_d} \times 0.5 \times l_{heel}^2 \times \tan(\beta) \times \gamma_m = 0.6 \text{ kN/m}$
Soil in front of wall	$W_{p_f} = \gamma_{f_d} \times l_{toe} \times d_{cover} \times \gamma_{mb} = 5.5 \text{ kN/m}$
Total vertical load	$W_{total_f} = W_{wall_f} + W_{base_f} + W_{sur_f} + W_{m_w_f} + W_{m_s_f} + W_{p_f} = 56.5 \text{ kN/m}$

Factored horizontal at-rest forces on wall

Surcharge	$F_{sur_f} = \gamma_{f_l} \times K_0 \times \text{Surcharge} \times h_{eff} = 2.7 \text{ kN/m}$
Moist backfill above water table	$F_{m_a_f} = \gamma_{f_e} \times 0.5 \times K_0 \times \gamma_m \times (h_{eff} - h_{water})^2 = 29.3 \text{ kN/m}$
Total horizontal load	$F_{total_f} = F_{sur_f} + F_{m_a_f} = 32 \text{ kN/m}$
Passive resistance of soil in front of wall kN/m	$F_{p_f} = \gamma_{f_e} \times 0.5 \times K_p \times \cos(\delta_b) \times (d_{cover} + t_{base} + d_{ds} - d_{exc})^2 \times \gamma_{mb} = 4.1$

Factored overturning moments

Surcharge	$M_{sur_f} = F_{sur_f} \times (h_{eff} - 2 \times d_{ds}) / 2 = 2.8 \text{ kNm/m}$
Moist backfill above water table	$M_{m_a_f} = F_{m_a_f} \times (h_{eff} + 2 \times h_{water} - 3 \times d_{ds}) / 3 = 20.3 \text{ kNm/m}$
Total overturning moment	$M_{ot_f} = M_{sur_f} + M_{m_a_f} = 23.1 \text{ kNm/m}$

Restoring moments

Wall stem	$M_{wall_f} = W_{wall_f} \times (l_{toe} + t_{wall} / 2) = 25.1 \text{ kNm/m}$
Wall base	$M_{base_f} = W_{base_f} \times l_{base} / 2 = 13.4 \text{ kNm/m}$
Surcharge	$M_{sur_r_f} = W_{sur_f} \times (l_{base} - l_{heel} / 2) = 1.4 \text{ kNm/m}$
Moist backfill	$M_{m_r_f} = (W_{m_w_f} \times (l_{base} - l_{heel} / 2) + W_{m_s_f} \times (l_{base} - l_{heel} / 3)) = 25.3 \text{ kNm/m}$
Soil in front of wall	$M_{p_r_f} = W_{p_f} \times l_{toe} / 2 = 3 \text{ kNm/m}$
Total restoring moment	$M_{rest_f} = M_{wall_f} + M_{base_f} + M_{sur_r_f} + M_{m_r_f} + M_{p_r_f} = 68.2 \text{ kNm/m}$

Factored bearing pressure

Total moment for bearing	$M_{total_f} = M_{rest_f} - M_{ot_f} = 45.1 \text{ kNm/m}$
Total vertical reaction	$R_f = W_{total_f} = 56.5 \text{ kN/m}$
Distance to reaction	$X_{bar_f} = M_{total_f} / R_f = 799 \text{ mm}$
Eccentricity of reaction	$e_f = \text{abs}((l_{base} / 2) - X_{bar_f}) = 101 \text{ mm}$

Reaction acts within middle third of base

Bearing pressure at toe	$p_{toe_f} = (R_f / l_{base}) + (6 \times R_f \times e_f / l_{base}^2) = 41.9 \text{ kN/m}^2$
Bearing pressure at heel	$p_{heel_f} = (R_f / l_{base}) - (6 \times R_f \times e_f / l_{base}^2) = 20.8 \text{ kN/m}^2$
Rate of change of base reaction	$\text{rate} = (p_{toe_f} - p_{heel_f}) / l_{base} = 11.73 \text{ kN/m}^2/\text{m}$
Bearing pressure at stem / toe	$p_{stem_toe_f} = \text{max}(p_{toe_f} - (\text{rate} \times l_{toe}), 0 \text{ kN/m}^2) = 29 \text{ kN/m}^2$
Bearing pressure at mid stem	$p_{stem_mid_f} = \text{max}(p_{toe_f} - (\text{rate} \times (l_{toe} + t_{wall} / 2)), 0 \text{ kN/m}^2) = 27 \text{ kN/m}^2$
Bearing pressure at stem / heel	$p_{stem_heel_f} = \text{max}(p_{toe_f} - (\text{rate} \times (l_{toe} + t_{wall})), 0 \text{ kN/m}^2) = 24.9 \text{ kN/m}^2$

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot		Job no. 22028	
	Calcs for External Retaining Wall - 1500mm High		Start page no./Revision 16	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022
			Approved by	Approved date

Design of reinforced concrete retaining wall toe (BS 8002:1994)

Material properties

Characteristic strength of concrete $f_{cu} = 35 \text{ N/mm}^2$
Characteristic strength of reinforcement $f_y = 500 \text{ N/mm}^2$

Base details


Minimum area of reinforcement $k = 0.13 \%$
Cover to reinforcement in toe $c_{toe} = 40 \text{ mm}$

Calculate shear for toe design

Shear from bearing pressure $V_{toe_bear} = (p_{toe_f} + p_{stem_toe_f}) \times l_{toe} / 2 = 39 \text{ kN/m}$
Shear from weight of base $V_{toe_wt_base} = \gamma_{fd} \times \gamma_{base} \times l_{toe} \times t_{base} = 9.1 \text{ kN/m}$
Total shear for toe design $V_{toe} = V_{toe_bear} - V_{toe_wt_base} = 29.9 \text{ kN/m}$

Calculate moment for toe design

Moment from bearing pressure $M_{toe_bear} = (2 \times p_{toe_f} + p_{stem_mid_f}) \times (l_{toe} + t_{wall} / 2)^2 / 6 = 30 \text{ kNm/m}$
Moment from weight of base $M_{toe_wt_base} = (\gamma_{fd} \times \gamma_{base} \times t_{base} \times (l_{toe} + t_{wall} / 2)^2 / 2) = 6.7 \text{ kNm/m}$
Total moment for toe design $M_{toe} = M_{toe_bear} - M_{toe_wt_base} = 23.3 \text{ kNm/m}$



Check toe in bending

Width of toe $b = 1000 \text{ mm/m}$
Depth of reinforcement $d_{toe} = t_{base} - c_{toe} - (\phi_{toe} / 2) = 205.0 \text{ mm}$
Constant $K_{toe} = M_{toe} / (b \times d_{toe}^2 \times f_{cu}) = 0.016$
Compression reinforcement is not required
Lever arm $z_{toe} = \min(0.5 + \sqrt{(0.25 - (\min(K_{toe}, 0.225) / 0.9))}, 0.95) \times d_{toe}$
 $z_{toe} = 195 \text{ mm}$
Area of tension reinforcement required $A_{s_toe_des} = M_{toe} / (0.87 \times f_y \times z_{toe}) = 275 \text{ mm}^2/\text{m}$
Minimum area of tension reinforcement $A_{s_toe_min} = k \times b \times t_{base} = 325 \text{ mm}^2/\text{m}$
Area of tension reinforcement required $A_{s_toe_req} = \text{Max}(A_{s_toe_des}, A_{s_toe_min}) = 325 \text{ mm}^2/\text{m}$
Reinforcement provided **A393 mesh**
Area of reinforcement provided $A_{s_toe_prov} = 393 \text{ mm}^2/\text{m}$

PASS - Reinforcement provided at the retaining wall toe is adequate

Check shear resistance at toe

Design shear stress $v_{toe} = V_{toe} / (b \times d_{toe}) = 0.146 \text{ N/mm}^2$
Allowable shear stress $v_{adm} = \min(0.8 \times \sqrt{f_{cu}} / 1 \text{ N/mm}^2, 5) \times 1 \text{ N/mm}^2 = 4.733 \text{ N/mm}^2$
PASS - Design shear stress is less than maximum shear stress

From BS8110:Part 1:1997 – Table 3.8

Design concrete shear stress $v_{c_toe} = 0.482 \text{ N/mm}^2$
 $v_{toe} < v_{c_toe}$ - No shear reinforcement required

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot		Job no. 22028	
	Calcs for External Retaining Wall - 1500mm High		Start page no./Revision 17	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022
			Approved by	Approved date

Design of reinforced concrete retaining wall heel (BS 8002:1994)

Material properties

Characteristic strength of concrete $f_{cu} = 35 \text{ N/mm}^2$
Characteristic strength of reinforcement $f_y = 500 \text{ N/mm}^2$

Base details


Minimum area of reinforcement $k = 0.13 \%$
Cover to reinforcement in heel $C_{heel} = 40 \text{ mm}$

Calculate shear for heel design

Shear from bearing pressure $V_{heel_bear} = (p_{heel_f} + p_{stem_heel_f}) \times l_{heel} / 2 = 8 \text{ kN/m}$
Shear from weight of base $V_{heel_wt_base} = \gamma_{fd} \times \gamma_{base} \times l_{heel} \times t_{base} = 2.9 \text{ kN/m}$
Shear from weight of moist backfill $V_{heel_wt_m} = w_{m_w_f} + w_{m_s_f} = 15.6 \text{ kN/m}$
Shear from surcharge $V_{heel_sur} = w_{sur_f} = 0.8 \text{ kN/m}$
Total shear for heel design $V_{heel} = -V_{heel_bear} + V_{heel_wt_base} + V_{heel_wt_m} + V_{heel_sur} = 11.3 \text{ kN/m}$

Calculate moment for heel design

Moment from bearing pressure $M_{heel_bear} = (2 \times p_{heel_f} + p_{stem_mid_f}) \times (l_{heel} + t_{wall} / 2)^2 / 6 = 3.2 \text{ kNm/m}$
Moment from weight of base $M_{heel_wt_base} = (\gamma_{fd} \times \gamma_{base} \times t_{base} \times (l_{heel} + t_{wall} / 2)^2 / 2) = 1.1 \text{ kNm/m}$
Moment from weight of moist backfill $M_{heel_wt_m} = w_{m_w_f} \times (l_{heel} + t_{wall}) / 2 + w_{m_s_f} \times (2 \times l_{heel} / 3 + t_{wall} / 2) = 5.5 \text{ kNm/m}$
Moment from surcharge $M_{heel_sur} = w_{sur_f} \times (l_{heel} + t_{wall}) / 2 = 0.3 \text{ kNm/m}$
Total moment for heel design $M_{heel} = -M_{heel_bear} + M_{heel_wt_base} + M_{heel_wt_m} + M_{heel_sur} = 3.8 \text{ kNm/m}$



Check heel in bending

Width of heel $b = 1000 \text{ mm/m}$
Depth of reinforcement $d_{heel} = t_{base} - C_{heel} - (\phi_{heel} / 2) = 205.0 \text{ mm}$
Constant $K_{heel} = M_{heel} / (b \times d_{heel}^2 \times f_{cu}) = 0.003$

Compression reinforcement is not required

Lever arm $Z_{heel} = \min(0.5 + \sqrt{(0.25 - (\min(K_{heel}, 0.225) / 0.9))}, 0.95) \times d_{heel}$
 $Z_{heel} = 195 \text{ mm}$
Area of tension reinforcement required $A_{s_heel_des} = M_{heel} / (0.87 \times f_y \times Z_{heel}) = 44 \text{ mm}^2/\text{m}$
Minimum area of tension reinforcement $A_{s_heel_min} = k \times b \times t_{base} = 325 \text{ mm}^2/\text{m}$
Area of tension reinforcement required $A_{s_heel_req} = \text{Max}(A_{s_heel_des}, A_{s_heel_min}) = 325 \text{ mm}^2/\text{m}$
Reinforcement provided **A393 mesh**
Area of reinforcement provided $A_{s_heel_prov} = 393 \text{ mm}^2/\text{m}$

PASS - Reinforcement provided at the retaining wall heel is adequate

Check shear resistance at heel

Design shear stress $v_{heel} = V_{heel} / (b \times d_{heel}) = 0.055 \text{ N/mm}^2$
Allowable shear stress $v_{adm} = \min(0.8 \times \sqrt{f_{cu}} / 1 \text{ N/mm}^2, 5) \times 1 \text{ N/mm}^2 = 4.733 \text{ N/mm}^2$

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1500mm High			Start page no./Revision 18	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

PASS - Design shear stress is less than maximum shear stress


From BS8110:Part 1:1997 – Table 3.8

Design concrete shear stress

$$V_{c_heel} = 0.482 \text{ N/mm}^2$$

$V_{heel} < V_{c_heel}$ - No shear reinforcement required

Design of cavity reinforced masonry retaining wall stem - BS5628-2:2000



Wall details

Thickness of outer leaf of wall

$$t_{outer} = 100 \text{ mm}$$

Thickness of inner leaf of wall

$$t_{inner} = 100 \text{ mm}$$

Thickness of reinforced cavity

$$t_{cavity} = t_{wall} - t_{outer} - t_{inner} = 150 \text{ mm}$$

Depth of stem reinforcement

$$d_{stem} = 225 \text{ mm}$$

Masonry details

Masonry type

Aggregate concrete blocks no voids

Compressive strength of units

$$p_{unit} = 7.3 \text{ N/mm}^2$$

Mortar designation

(ii)

Category of manufacturing control of units

Category I

Partial safety factor for material strength

$$\gamma_{mm} = 2.0$$

Characteristic compressive strength of masonry

Least horizontal dimension of masonry units

$$b_{unit} = 100.0 \text{ mm}$$

Height of masonry units

$$h_{unit} = 215.0 \text{ mm}$$

Ratio of height to least horizontal dimension

$$\text{ratio} = h_{unit} / b_{unit} = 2.2$$

From BS5628:2 Table 3d, mortar ii

Characteristic compressive strength

$$f_k = 6.4 \text{ N/mm}^2$$

Factored horizontal at-rest forces on stem

Surcharge

$$F_{s_sur_f} = \gamma_{f_l} \times K_0 \times \text{Surcharge} \times (h_{eff} - t_{base} - d_{ds}) = 2.4 \text{ kN/m}$$

Moist backfill above water table

$$F_{s_m_a_f} = 0.5 \times \gamma_{f_e} \times K_0 \times \gamma_m \times (h_{eff} - t_{base} - d_{ds} - h_{sat})^2 = 22.6 \text{ kN/m}$$

Calculate shear for stem design

Shear at base of stem

$$V_{stem} = F_{s_sur_f} + F_{s_m_a_f} = 25 \text{ kN/m}$$

Calculate moment for stem design

Surcharge

$$M_{s_sur} = F_{s_sur_f} \times (h_{stem} + t_{base}) / 2 = 2.3 \text{ kNm/m}$$

Moist backfill above water table

$$M_{s_m_a} = F_{s_m_a_f} \times (2 \times h_{sat} + h_{eff} - d_{ds} + t_{base} / 2) / 3 = 16.6 \text{ kNm/m}$$

Total moment for stem design

$$M_{stem} = M_{s_sur} + M_{s_m_a} = 18.9 \text{ kNm/m}$$

Check maximum design moment for wall stem

Width of wall

$$b = 1000 \text{ mm/m}$$

Maximum design moment

$$M_{d_stem} = 0.4 \times f_k \times b \times d_{stem}^2 / \gamma_{mm} = 64.8 \text{ kNm/m}$$

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot		Job no. 22028	
	Calcs for External Retaining Wall - 1500mm High		Start page no./Revision 19	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022
		Approved by	Approved date	

PASS - Applied moment is less than maximum design moment

Check wall stem in bending

Moment of resistance factor

$$Q = M_{\text{stem}} / d_{\text{stem}}^2 = \mathbf{0.374 \text{ N/mm}^2}$$

$$Q = 2 \times c \times (1 - c) \times f_k / \gamma_{\text{mm}}$$

$$c = \mathbf{0.938}$$

Lever arm factor

$$z_{\text{stem}} = \min(0.95, c) \times d_{\text{stem}} = \mathbf{211.0 \text{ mm}}$$

Lever arm

$$A_{s_stem_des} = M_{\text{stem}} \times \gamma_{\text{ms}} / (f_y \times z_{\text{stem}}) = \mathbf{206 \text{ mm}^2/\text{m}}$$

Area of tension reinforcement required

$$A_{s_stem_min} = k \times b \times t_{\text{wall}} = \mathbf{455 \text{ mm}^2/\text{m}}$$

Minimum area of tension reinforcement

$$A_{s_stem_req} = \text{Max}(A_{s_stem_des}, A_{s_stem_min}) = \mathbf{455 \text{ mm}^2/\text{m}}$$

Area of tension reinforcement required

Reinforcement provided

B785 mesh

Area of reinforcement provided

$$A_{s_stem_prov} = \pi \times \phi_{\text{stem}}^2 / (4 \times s_{\text{stem}}) = \mathbf{785 \text{ mm}^2/\text{m}}$$

PASS - Reinforcement provided at the retaining wall stem is adequate

Check shear resistance at wall stem

Design shear stress

$$v_{\text{stem}} = V_{\text{stem}} / (b \times d_{\text{stem}}) = \mathbf{0.111 \text{ N/mm}^2}$$

Basic characteristic shear strength of masonry

$$f_{\text{vbas}} = \min[0.35 + (17.5 \times A_{s_stem_prov} / (b \times d_{\text{stem}})), 0.7] \times 1 \text{ N/mm}^2$$

$$f_{\text{vbas}} = \mathbf{0.411 \text{ N/mm}^2}$$

Shear span

$$a = M_{\text{stem}} / V_{\text{stem}} = \mathbf{756.9 \text{ mm}}$$

Characteristic shear strength of masonry

$$f_v = \text{Min}(f_{\text{vbas}} \times \max(2.5 - 0.25 \times (a / d_{\text{stem}}), 1), 1.75 \text{ N/mm}^2)$$

$$f_v = \mathbf{0.682 \text{ N/mm}^2}$$

Allowable shear stress

$$v_{\text{adm}} = f_v / \gamma_{\text{mv}} = \mathbf{0.341 \text{ N/mm}^2}$$

PASS - Design shear stress is less than maximum shear stress

Check limiting dimensions

Limiting span/effective depth ratio

$$\text{ratio}_{\text{max}} = \mathbf{18.00}$$

Actual span/effective depth ratio

$$\text{ratio}_{\text{act}} = (h_{\text{stem}} + d_{\text{stem}} / 2) / d_{\text{stem}} = \mathbf{8.06}$$

PASS - Span to depth ratio is acceptable

Axial load check

Factored axial load on wall

$$N_{\text{wall}} = ([t_{\text{wall}} \times h_{\text{stem}} \times \gamma_{\text{wall}} + W_{\text{dead}}] \times \gamma_{\text{f_d}}) + (W_{\text{live}} \times \gamma_{\text{f_l}}) = \mathbf{19.7 \text{ kN/m}}$$


Limiting axial load

$$N_{\text{limit}} = 0.1 \times f_k \times t_{\text{wall}} = \mathbf{224.0 \text{ kN/m}}$$

Applied axial load may be ignored - calculations valid

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1500mm High			Start page no./Revision 20	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Indicative retaining wall reinforcement diagram




Toe mesh - A393 - (393 mm²/m)
Heel mesh - A393 - (393 mm²/m)
Stem mesh - B785 - (785 mm²/m)

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1000mm High			Start page no./Revision 21	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

RETAINING WALL ANALYSIS (BS 8002:1994)

TEDDS calculation version 1.2.01.08



Wall details

Retaining wall type
Height of retaining wall stem
Thickness of wall stem
Length of toe
Length of heel
Overall length of base
Thickness of base
Depth of downstand
Position of downstand
Thickness of downstand
Height of retaining wall
Depth of cover in front of wall
Depth of unplanned excavation
Height of ground water behind wall
Height of saturated fill above base
Density of wall construction
Density of base construction
Angle of rear face of wall
Angle of soil surface behind wall
Effective height at virtual back of wall

Unpropped cantilever

$h_{\text{stem}} = 1200 \text{ mm}$
 $t_{\text{wall}} = 350 \text{ mm}$
 $l_{\text{toe}} = 600 \text{ mm}$
 $l_{\text{heel}} = 0 \text{ mm}$
 $l_{\text{base}} = l_{\text{toe}} + l_{\text{heel}} + t_{\text{wall}} = 950 \text{ mm}$
 $t_{\text{base}} = 250 \text{ mm}$
 $d_{\text{ds}} = 0 \text{ mm}$
 $l_{\text{ds}} = 0 \text{ mm}$
 $t_{\text{ds}} = 250 \text{ mm}$
 $h_{\text{wall}} = h_{\text{stem}} + t_{\text{base}} + d_{\text{ds}} = 1450 \text{ mm}$
 $d_{\text{cover}} = 200 \text{ mm}$
 $d_{\text{exc}} = 200 \text{ mm}$
 $h_{\text{water}} = 0 \text{ mm}$
 $h_{\text{sat}} = \max(h_{\text{water}} - t_{\text{base}} - d_{\text{ds}}, 0 \text{ mm}) = 0 \text{ mm}$
 $\gamma_{\text{wall}} = 23.6 \text{ kN/m}^3$
 $\gamma_{\text{base}} = 23.6 \text{ kN/m}^3$
 $\alpha = 90.0 \text{ deg}$
 $\beta = 20.0 \text{ deg}$
 $h_{\text{eff}} = h_{\text{wall}} + l_{\text{heel}} \times \tan(\beta) = 1450 \text{ mm}$

Retained material details

Mobilisation factor
Moist density of retained material

$M = 1.5$
 $\gamma_m = 18.0 \text{ kN/m}^3$

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1000mm High			Start page no./Revision 22	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Saturated density of retained material $\gamma_s = 21.0 \text{ kN/m}^3$

Design shear strength $\phi' = 27.5 \text{ deg}$

Angle of wall friction $\delta = 21.3 \text{ deg}$

Base material details

Moist density $\gamma_{mb} = 18.0 \text{ kN/m}^3$

Design shear strength $\phi'_b = 27.5 \text{ deg}$

Design base friction $\delta_b = 21.3 \text{ deg}$

Allowable bearing pressure $P_{\text{bearing}} = 100 \text{ kN/m}^2$

Using Coulomb theory

Active pressure coefficient for retained material

$$K_a = \sin(\alpha + \phi')^2 / (\sin(\alpha)^2 \times \sin(\alpha - \delta) \times [1 + \sqrt{(\sin(\phi' + \delta) \times \sin(\phi' - \beta) / (\sin(\alpha - \delta) \times \sin(\alpha + \beta)))})]^2) = 0.474$$

Passive pressure coefficient for base material

$$K_p = \sin(90 - \phi'_b)^2 / (\sin(90 - \delta_b) \times [1 - \sqrt{(\sin(\phi'_b + \delta_b) \times \sin(\phi'_b) / (\sin(90 + \delta_b)))})]^2) = 5.571$$

At-rest pressure

At-rest pressure for retained material $K_0 = 1 - \sin(\phi') = 0.538$

Loading details

Surcharge load on plan Surcharge = **1.5 kN/m²**

Applied vertical dead load on wall $W_{\text{dead}} = 0.0 \text{ kN/m}$


Applied vertical live load on wall $W_{\text{live}} = 0.0 \text{ kN/m}$

Position of applied vertical load on wall $l_{\text{load}} = 0 \text{ mm}$

Applied horizontal dead load on wall $F_{\text{dead}} = 0.0 \text{ kN/m}$

Applied horizontal live load on wall $F_{\text{live}} = 0.0 \text{ kN/m}$

Height of applied horizontal load on wall $h_{\text{load}} = 0 \text{ mm}$



Loads shown in kN/m, pressures shown in kN/m²

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1000mm High			Start page no./Revision 23	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Vertical forces on wall

Wall stem	$W_{wall} = h_{stem} \times t_{wall} \times \gamma_{wall} = 9.9 \text{ kN/m}$
Wall base	$W_{base} = l_{base} \times t_{base} \times \gamma_{base} = 5.6 \text{ kN/m}$
Soil in front of wall	$W_p = l_{toe} \times d_{cover} \times \gamma_{mb} = 2.2 \text{ kN/m}$
Total vertical load	$W_{total} = W_{wall} + W_{base} + W_p = 17.7 \text{ kN/m}$

Horizontal forces on wall

Surcharge	$F_{sur} = K_a \times \cos(90 - \alpha + \delta) \times \text{Surcharge} \times h_{eff} = 1 \text{ kN/m}$
Moist backfill above water table	$F_{m_a} = 0.5 \times K_a \times \cos(90 - \alpha + \delta) \times \gamma_m \times (h_{eff} - h_{water})^2 = 8.4 \text{ kN/m}$
Total horizontal load	$F_{total} = F_{sur} + F_{m_a} = 9.3 \text{ kN/m}$

Calculate stability against sliding

Passive resistance of soil in front of wall	$F_p = 0.5 \times K_p \times \cos(\delta_b) \times (d_{cover} + t_{base} + d_{ds} - d_{exc})^2 \times \gamma_{mb} = 2.9 \text{ kN/m}$
Resistance to sliding	$F_{res} = F_p + W_{total} \times \tan(\delta_b) = 9.8 \text{ kN/m}$

PASS - Resistance force is greater than sliding force

Overturning moments

Surcharge	$M_{sur} = F_{sur} \times (h_{eff} - 2 \times d_{ds}) / 2 = 0.7 \text{ kNm/m}$
Moist backfill above water table	$M_{m_a} = F_{m_a} \times (h_{eff} + 2 \times h_{water} - 3 \times d_{ds}) / 3 = 4 \text{ kNm/m}$
Total overturning moment	$M_{ot} = M_{sur} + M_{m_a} = 4.7 \text{ kNm/m}$

Restoring moments

Wall stem	$M_{wall} = W_{wall} \times (l_{toe} + t_{wall} / 2) = 7.7 \text{ kNm/m}$
Wall base	$M_{base} = W_{base} \times l_{base} / 2 = 2.7 \text{ kNm/m}$
Soil in front of wall	$M_{p_r} = W_p \times l_{toe} / 2 = 0.6 \text{ kNm/m}$
Total restoring moment	$M_{rest} = M_{wall} + M_{base} + M_{p_r} = 11 \text{ kNm/m}$

Check stability against overturning

Total overturning moment	$M_{ot} = 4.7 \text{ kNm/m}$
Total restoring moment	$M_{rest} = 11.0 \text{ kNm/m}$

PASS - Restoring moment is greater than overturning moment

Check bearing pressure

Total moment for bearing	$M_{total} = M_{rest} - M_{ot} = 6.3 \text{ kNm/m}$
Total vertical reaction	$R = W_{total} = 17.7 \text{ kN/m}$
Distance to reaction	$X_{bar} = M_{total} / R = 354 \text{ mm}$
Eccentricity of reaction	$e = \text{abs}((l_{base} / 2) - X_{bar}) = 121 \text{ mm}$

Reaction acts within middle third of base

Bearing pressure at toe	$p_{toe} = (R / l_{base}) + (6 \times R \times e / l_{base}^2) = 32.8 \text{ kN/m}^2$
Bearing pressure at heel	$p_{heel} = (R / l_{base}) - (6 \times R \times e / l_{base}^2) = 4.4 \text{ kN/m}^2$

PASS - Maximum bearing pressure is less than allowable bearing pressure

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1000mm High			Start page no./Revision 24	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

RETAINING WALL DESIGN (BS 8002:1994)

TEDDS calculation version 1.2.01.08

Ultimate limit state load factors

Dead load factor	$\gamma_{f,d} = 1.4$
Live load factor	$\gamma_{f,l} = 1.6$
Earth and water pressure factor	$\gamma_{f,e} = 1.4$

Factored vertical forces on wall

Wall stem	$W_{wall,f} = \gamma_{f,d} \times h_{stem} \times t_{wall} \times \gamma_{wall} = 13.9 \text{ kN/m}$
Wall base	$W_{base,f} = \gamma_{f,d} \times l_{base} \times t_{base} \times \gamma_{base} = 7.8 \text{ kN/m}$
Soil in front of wall	$W_{p,f} = \gamma_{f,d} \times l_{toe} \times d_{cover} \times \gamma_{mb} = 3 \text{ kN/m}$
Total vertical load	$W_{total,f} = W_{wall,f} + W_{base,f} + W_{p,f} = 24.7 \text{ kN/m}$

Factored horizontal at-rest forces on wall

Surcharge	$F_{sur,f} = \gamma_{f,l} \times K_0 \times \text{Surcharge} \times h_{eff} = 1.9 \text{ kN/m}$
Moist backfill above water table	$F_{m,a,f} = \gamma_{f,e} \times 0.5 \times K_0 \times \gamma_m \times (h_{eff} - h_{water})^2 = 14.3 \text{ kN/m}$
Total horizontal load	$F_{total,f} = F_{sur,f} + F_{m,a,f} = 16.1 \text{ kN/m}$
Passive resistance of soil in front of wall kN/m	$F_{p,f} = \gamma_{f,e} \times 0.5 \times K_p \times \cos(\delta_b) \times (d_{cover} + t_{base} + d_{ds} - d_{exc})^2 \times \gamma_{mb} = 4.1$

Factored overturning moments

Surcharge	$M_{sur,f} = F_{sur,f} \times (h_{eff} - 2 \times d_{ds}) / 2 = 1.4 \text{ kNm/m}$
Moist backfill above water table	$M_{m,a,f} = F_{m,a,f} \times (h_{eff} + 2 \times h_{water} - 3 \times d_{ds}) / 3 = 6.9 \text{ kNm/m}$
Total overturning moment	$M_{ot,f} = M_{sur,f} + M_{m,a,f} = 8.2 \text{ kNm/m}$

Restoring moments

Wall stem	$M_{wall,f} = W_{wall,f} \times (l_{toe} + t_{wall} / 2) = 10.8 \text{ kNm/m}$
Wall base	$M_{base,f} = W_{base,f} \times l_{base} / 2 = 3.7 \text{ kNm/m}$
Soil in front of wall	$M_{p,r,f} = W_{p,f} \times l_{toe} / 2 = 0.9 \text{ kNm/m}$
Total restoring moment	$M_{rest,f} = M_{wall,f} + M_{base,f} + M_{p,r,f} = 15.4 \text{ kNm/m}$

Factored bearing pressure

Total moment for bearing	$M_{total,f} = M_{rest,f} - M_{ot,f} = 7.1 \text{ kNm/m}$
Total vertical reaction	$R_f = W_{total,f} = 24.7 \text{ kN/m}$
Distance to reaction	$x_{bar,f} = M_{total,f} / R_f = 288 \text{ mm}$
Eccentricity of reaction	$e_f = \text{abs}((l_{base} / 2) - x_{bar,f}) = 187 \text{ mm}$

Reaction acts outside middle third of base

Bearing pressure at toe	$p_{toe,f} = R_f / (1.5 \times x_{bar,f}) = 57.2 \text{ kN/m}^2$
Bearing pressure at heel	$p_{heel,f} = 0 \text{ kN/m}^2 = 0 \text{ kN/m}^2$
Rate of change of base reaction	$\text{rate} = p_{toe,f} / (3 \times x_{bar,f}) = 66.09 \text{ kN/m}^2/\text{m}$
Bearing pressure at stem / toe	$p_{stem,toe,f} = \text{max}(p_{toe,f} - (\text{rate} \times l_{toe}), 0 \text{ kN/m}^2) = 17.5 \text{ kN/m}^2$
Bearing pressure at mid stem	$p_{stem,mid,f} = \text{max}(p_{toe,f} - (\text{rate} \times (l_{toe} + t_{wall} / 2)), 0 \text{ kN/m}^2) = 6 \text{ kN/m}^2$
Bearing pressure at stem / heel	$p_{stem,heel,f} = \text{max}(p_{toe,f} - (\text{rate} \times (l_{toe} + t_{wall})), 0 \text{ kN/m}^2) = 0 \text{ kN/m}^2$

Design of reinforced concrete retaining wall toe (BS 8002:1994)

Material properties

Characteristic strength of concrete	$f_{cu} = 35 \text{ N/mm}^2$
Characteristic strength of reinforcement	$f_y = 500 \text{ N/mm}^2$

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot		Job no. 22028	
	Calcs for External Retaining Wall - 1000mm High		Start page no./Revision 25	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022
			Approved by	Approved date

Base details

Minimum area of reinforcement

$$k = 0.13 \%$$

Cover to reinforcement in toe

$$c_{toe} = 40 \text{ mm}$$

Calculate shear for toe design

Shear from bearing pressure

$$V_{toe_bear} = (p_{toe_f} + p_{stem_toe_f}) \times l_{toe} / 2 = 22.4 \text{ kN/m}$$

Shear from weight of base

$$V_{toe_wt_base} = \gamma_{f_d} \times \gamma_{base} \times l_{toe} \times t_{base} = 5 \text{ kN/m}$$

Total shear for toe design

$$V_{toe} = V_{toe_bear} - V_{toe_wt_base} = 17.5 \text{ kN/m}$$

Calculate moment for toe design

Moment from bearing pressure


$$M_{toe_bear} = (2 \times p_{toe_f} + p_{stem_mid_f}) \times (l_{toe} + t_{wall} / 2)^2 / 6 = 12 \text{ kNm/m}$$

Moment from weight of base

$$M_{toe_wt_base} = (\gamma_{f_d} \times \gamma_{base} \times t_{base} \times (l_{toe} + t_{wall} / 2)^2 / 2) = 2.5 \text{ kNm/m}$$

Total moment for toe design

$$M_{toe} = M_{toe_bear} - M_{toe_wt_base} = 9.6 \text{ kNm/m}$$



Check toe in bending

Width of toe

$$b = 1000 \text{ mm/m}$$

Depth of reinforcement

$$d_{toe} = t_{base} - c_{toe} - (\phi_{toe} / 2) = 205.0 \text{ mm}$$

Constant

$$K_{toe} = M_{toe} / (b \times d_{toe}^2 \times f_{cu}) = 0.007$$

Compression reinforcement is not required

Lever arm

$$z_{toe} = \min(0.5 + \sqrt{(0.25 - (\min(K_{toe}, 0.225) / 0.9))}, 0.95) \times d_{toe}$$

$$z_{toe} = 195 \text{ mm}$$

Area of tension reinforcement required

$$A_{s_toe_des} = M_{toe} / (0.87 \times f_y \times z_{toe}) = 113 \text{ mm}^2/\text{m}$$

Minimum area of tension reinforcement

$$A_{s_toe_min} = k \times b \times t_{base} = 325 \text{ mm}^2/\text{m}$$

Area of tension reinforcement required

$$A_{s_toe_req} = \text{Max}(A_{s_toe_des}, A_{s_toe_min}) = 325 \text{ mm}^2/\text{m}$$

Reinforcement provided

A393 mesh

Area of reinforcement provided

$$A_{s_toe_prov} = 393 \text{ mm}^2/\text{m}$$

PASS - Reinforcement provided at the retaining wall toe is adequate

Check shear resistance at toe

Design shear stress

$$v_{toe} = V_{toe} / (b \times d_{toe}) = 0.085 \text{ N/mm}^2$$

Allowable shear stress

$$v_{adm} = \min(0.8 \times \sqrt{f_{cu}} / 1 \text{ N/mm}^2, 5) \times 1 \text{ N/mm}^2 = 4.733 \text{ N/mm}^2$$

PASS - Design shear stress is less than maximum shear stress

From BS8110:Part 1:1997 – Table 3.8


Design concrete shear stress

$$v_{c_toe} = 0.482 \text{ N/mm}^2$$

$v_{toe} < v_{c_toe}$ - No shear reinforcement required

Tekla Tedds FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1000mm High			Start page no./Revision 26	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Design of cavity reinforced masonry retaining wall stem - BS5628-2:2000



Wall details

Thickness of outer leaf of wall
Thickness of inner leaf of wall
Thickness of reinforced cavity
Depth of stem reinforcement

$t_{\text{outer}} = 100 \text{ mm}$
 $t_{\text{inner}} = 100 \text{ mm}$
 $t_{\text{cavity}} = t_{\text{wall}} - t_{\text{outer}} - t_{\text{inner}} = 150 \text{ mm}$
 $d_{\text{stem}} = 225 \text{ mm}$

Masonry details

Masonry type
Compressive strength of units
Mortar designation
Category of manufacturing control of units
Partial safety factor for material strength

Aggregate concrete blocks no voids
 $p_{\text{unit}} = 7.3 \text{ N/mm}^2$
(ii)
Category I
 $\gamma_{\text{mm}} = 2.0$

Characteristic compressive strength of masonry

Least horizontal dimension of masonry units
Height of masonry units
Ratio of height to least horizontal dimension

$b_{\text{unit}} = 100.0 \text{ mm}$
 $h_{\text{unit}} = 215.0 \text{ mm}$
ratio = $h_{\text{unit}} / b_{\text{unit}} = 2.2$

From BS5628:2 Table 3d, mortar ii

Characteristic compressive strength

$f_k = 6.4 \text{ N/mm}^2$

Factored horizontal at-rest forces on stem

Surcharge
Moist backfill above water table

$F_{s_sur_f} = \gamma_{f_l} \times K_0 \times \text{Surcharge} \times (h_{\text{eff}} - t_{\text{base}} - d_{\text{ds}}) = 1.6 \text{ kN/m}$
 $F_{s_m_a_f} = 0.5 \times \gamma_{f_e} \times K_0 \times \gamma_m \times (h_{\text{eff}} - t_{\text{base}} - d_{\text{ds}} - h_{\text{sat}})^2 = 9.8 \text{ kN/m}$

Calculate shear for stem design

Shear at base of stem

$V_{\text{stem}} = F_{s_sur_f} + F_{s_m_a_f} = 11.3 \text{ kN/m}$

Calculate moment for stem design

Surcharge
Moist backfill above water table
Total moment for stem design

$M_{s_sur} = F_{s_sur_f} \times (h_{\text{stem}} + t_{\text{base}}) / 2 = 1.1 \text{ kNm/m}$
 $M_{s_m_a} = F_{s_m_a_f} \times (2 \times h_{\text{sat}} + h_{\text{eff}} - d_{\text{ds}} + t_{\text{base}} / 2) / 3 = 5.1 \text{ kNm/m}$
 $M_{\text{stem}} = M_{s_sur} + M_{s_m_a} = 6.3 \text{ kNm/m}$

Check maximum design moment for wall stem

Width of wall
Maximum design moment

$b = 1000 \text{ mm/m}$
 $M_{d_stem} = 0.4 \times f_k \times b \times d_{\text{stem}}^2 / \gamma_{\text{mm}} = 64.8 \text{ kNm/m}$

PASS - Applied moment is less than maximum design moment

Check wall stem in bending

Moment of resistance factor

$Q = M_{\text{stem}} / d_{\text{stem}}^2 = 0.123 \text{ N/mm}^2$

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1000mm High			Start page no./Revision 27	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Lever arm factor

$$Q = 2 \times c \times (1 - c) \times f_k / \gamma_{mm}$$

$$c = \mathbf{0.980}$$

Lever arm

$$Z_{stem} = \min(0.95, c) \times d_{stem} = \mathbf{213.8 \text{ mm}}$$

Area of tension reinforcement required

$$A_{s_stem_des} = M_{stem} \times \gamma_{ms} / (f_y \times Z_{stem}) = \mathbf{67 \text{ mm}^2/\text{m}}$$

Minimum area of tension reinforcement

$$A_{s_stem_min} = k \times b \times t_{wall} = \mathbf{455 \text{ mm}^2/\text{m}}$$

Area of tension reinforcement required

$$A_{s_stem_req} = \text{Max}(A_{s_stem_des}, A_{s_stem_min}) = \mathbf{455 \text{ mm}^2/\text{m}}$$

Reinforcement provided

B785 mesh

Area of reinforcement provided

$$A_{s_stem_prov} = \pi \times \phi_{stem}^2 / (4 \times s_{stem}) = \mathbf{785 \text{ mm}^2/\text{m}}$$

PASS - Reinforcement provided at the retaining wall stem is adequate

Check shear resistance at wall stem

Design shear stress

$$V_{stem} = V_{stem} / (b \times d_{stem}) = \mathbf{0.050 \text{ N/mm}^2}$$

Basic characteristic shear strength of masonry

$$f_{vbas} = \min[0.35 + (17.5 \times A_{s_stem_prov} / (b \times d_{stem})), 0.7] \times 1 \text{ N/mm}^2$$

$$f_{vbas} = \mathbf{0.411 \text{ N/mm}^2}$$

Shear span

$$a = M_{stem} / V_{stem} = \mathbf{552.4 \text{ mm}}$$

Characteristic shear strength of masonry

$$f_v = \text{Min}(f_{vbas} \times \max(2.5 - 0.25 \times (a / d_{stem}), 1), 1.75 \text{ N/mm}^2)$$

$$f_v = \mathbf{0.775 \text{ N/mm}^2}$$

Allowable shear stress

$$V_{adm} = f_v / \gamma_{mv} = \mathbf{0.388 \text{ N/mm}^2}$$

PASS - Design shear stress is less than maximum shear stress

Check limiting dimensions

Limiting span/effective depth ratio

$$\text{ratio}_{max} = \mathbf{18.00}$$

Actual span/effective depth ratio

$$\text{ratio}_{act} = (h_{stem} + d_{stem} / 2) / d_{stem} = \mathbf{5.83}$$

PASS - Span to depth ratio is acceptable

Axial load check

Factored axial load on wall

$$N_{wall} = ([t_{wall} \times h_{stem} \times \gamma_{wall} + W_{dead}] \times \gamma_{f_d}) + (W_{live} \times \gamma_{f_l}) = \mathbf{13.9 \text{ kN/m}}$$


Limiting axial load

$$N_{limit} = 0.1 \times f_k \times t_{wall} = \mathbf{224.0 \text{ kN/m}}$$

Applied axial load may be ignored - calculations valid

 FAR Structures Ltd Wayside, 30 Brynfield Road, Langland, Swansea, SA3 4SX t: +44 (0)7703 043 608 e:andrew@farstructures.uk	Project Plot 36, Forest Lodge Lane, Forest Lodge, Port Talbot			Job no. 22028	
	Calcs for External Retaining Wall - 1000mm High			Start page no./Revision 28	
	Calcs by AR	Calcs date 25/04/2022	Checked by AR	Checked date 25/04/2022	Approved by Approved date

Indicative retaining wall reinforcement diagram



Toe mesh - A393 - (393 mm²/m)
Stem mesh - B785 - (785 mm²/m)