

	Illuminated Fire Exit sign
	Break glass call point for fire alarm in accordance with BS5839
FD30	Fire door to provide min. 30 minutes fire protection
FD30S	Fire door to provide min. 30 minutes fire protection and where restricted smoke leakage at ambient temperatures is needed.

	Fire Alarm Control Panel
	Smoke detector
	Smoke detector/alarm
	Heat detector
	Alarm sounder

	Fire blanket 1m x 1m unless otherwise stated
	6 litre fire foam extinguisher

DP 10kg dry powder fire extinguisher

Total extent of licensed premises

FDKI Fire door keep locked

FDKC Fire door keep closed



SUDS areas
shown thus

concrete —
hardstandin
shown thus

Emergency Services
Access Route -
shown thus

1:500@A1, 1:1000@A3

© Crown Copyright and database right 2022. Ordnance Survey 100023392
© Hawlfraint a hawliau cronfa ddatawr Goron 2022. Rhestrwdded yr Arlowr Ordnance 100023392

C	20-01-23	DR	Layout updated, location plan added
B	08-12-22	FW	Barriers to external seating area included
A	30-11-22	FW	External seating area included
Rev	Date	Initials	Details

Purpose of Issue
APPLICATION FOR PREMISES LICENSING

RICHARD PEDLAR ARCHITECTS
ARCHITECTURE • CONSERVATION • URBAN DESIGN

RPCA St Brandon's House 29 Great George Street
Bristol BS1 5QT • 0117 974 2612
www.rpca.co.uk • info@rpca.co.uk

Project **CADNO LOUNGE** at
Unit 1 Water Street Neath

Client Loungers UK Limited

Title	Premises Licensing
-------	--------------------

Drawing No. LNG4668.05C

Scale 1:50@A1 Date OCT 2022
1:100@A3

Responsibility is not accepted for errors made by others in scaling from this drawing. All construction information to be taken from figured dimensions only.