

Good morning,

Further to my clients request for us to get involved with the odour control measures required please find attached method preferred with this existing installation.

There is mention of carbon filters but due to the airflow requirements and dwell time needed within the filters we do not feel this would suit site conditions. With Carbon filtration it creates a large pressure resistance on fans and once grease starts to clog up they become ineffective meaning site need to change them regularly. This would be extremely costly for my client so would you please consider the attached.

This style of odour control is now being used in many sites across the UK including MAB, Greene King, Whitbread as it offers a no hassle maintenance and has been provided to work much better than carbon filtration.

You'll see on the test of how the air is treated.

Please could you give me a call on [REDACTED] to discuss further as my client would like to proceed asap to ensure he is covered by council guidelines.

Many Thanks