




LLOYDS NEATH

24 Issues Identified



GF

Assigned To main banking hall

46no. 1200mm single fluorescent 36w/830*

5no. 600mm wall mounted single fluorescent 18w/830

2no. 600x600 recessed fluorescent 4x18w/830

1no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 4.8m

plasterboard ceiling

*all 1200mm fittings are hanging from ceiling

**GF**


Assigned To ATM room

3no. 1500mm single fluorescent 58w/830

1no. 28w 2d surface circular bulkhead

CH - 2.5m

plasterboard ceiling

**GF**

Assigned To administration

6no. 600x600 recessed fluorescent 4x18w/830

1no. 8w fluorescent emergency bulkhead non maintained

CH - 2.5m

600x600 ceiling grid tile



GF

Assigned To meeting room 1

1no. recessed downlight 230mm bezel 2x18w PLC 2pin

4no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 2.5m

600x600 ceiling grid tile



GF

Assigned To meeting room 2

1no. recessed downlight 230mm bezel 2x18w PLC 2pin

4no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 2.5m

600x600 ceiling grid tile



GF

Assigned To meeting room 3

1no. recessed downlight 230mm bezel 2x18w PLC 2pin

4no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 2.5m

600x600 ceiling grid tile



GF

Assigned To meeting room 4

4no. 600x600 recessed fluorescent 4x18w/840 T8

3no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 2.5m

600x600 ceiling grid tile



GF


Assigned To meeting room 5

1no. recessed downlight 230mm bezel 2x18w PLC 2pin

3no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 2.5m

600x600 ceiling grid tile



GF

Assigned To meeting room 6

1no. recessed downlight 230mm bezel 2x18w PLC 2pin

4no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 2.5m

600x600 ceiling grid tile



GF

Assigned To meeting room 7

1no. recessed downlight 230mm bezel 2x18w PLC 2pin

3no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 2.5m

600x600 ceiling grid tile



GF

Assigned To meeting room 8

1no. recessed downlight 230mm bezel 2x18w PLC 2pin

3no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 2.5m

600x600 ceiling grid tile



GF

Assigned To meeting room 9

1no. recessed downlight 230mm bezel 2x18w PLC 2pin

3no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 2.5m

600x600 ceiling grid tile



GF

Assigned To meeting room lobby

9no. recessed downlight 230mm bezel 2x18w PLC 2pin

5no. recessed downlight emergency maintained 230mm bezel
2x18w PLC 2pin

4no. 35w CDMT recessed adjustable spot 130mm bezel

CH - 2.5m

600x600 ceiling grid tile



1F

Assigned To staff room

6no. 1200x600 3x36w/830 recessed fluorescent

CH - 2.5m

600x600 plasterboard ceiling



1F

Assigned To mens wc

1no. 1800mm twin fluorescent 70w/830

2no. 16w 2D surface bulkhead

CH - 2.8m

plasterboard ceiling



1F

Assigned To womens wc

1no. 1800mm twin fluorescent 70w/830

2no. 16w 2D surface bulkhead

CH - 2.8m

plasterboard ceiling



1F

Assigned To hallway

1no. LED emergency maintained exit bulkhead

1no. 1800mm twin fluorescent 70w/830

plasterboard ceiling

CH - 2.8



1F

Assigned To business banking

2no. 1800mm twin fluorescent T8 70w/830

CH - 2.8m

plasterboard ceiling




B

Assigned To cash store

1no. 1200mm single fluorescent 36w/830

CH - 2.6m

plasterboard ceiling



B

Assigned To safe deposit

1no. 1200m single 36w/830

CH - 2.6m

plasterboard ceiling



B

Assigned To strong room

2no. 1500mm single fluorescent 58w/830

CH - 2.6m

plasterboard ceiling



B

Assigned To vouchers

1no. 1500mm single fluorescent T8 58w/830

CH - 2.6m

plasterboard ceiling



B

Assigned To boiler room

1no. 1200mm single fluorescent 36w/830

CH - 2.5m

concrete ceiling



1F

Assigned To hallway

2no. 1500mm single fluorescent 58w/830

CH - 2.8m

plasterboard ceiling