


Designed in accordance with BS5489-1:2020 to lighting class P5.

Assumed Environmental Zone - E3/E4 and 6 yearly cleaning regime lead to an MF value of 0.80.



Luminaire A - Proposed 6m mounting height column complete with post top mounted Thorn Isaro Pro S 12L55 RWT 740 CLO 90N7 CL1 UT7L42E GYS 3.27klm's. Luminaires to be installed at 0° tilt. Luminaires to be permanently dimmed to 50%

Grid 1
Results - Horizontal Illuminance (lux)
Eav= 4.33
Emin= 0.61
Emax= 9.28
Emin/Emax= 0.07
Emin/Eav= 0.14
Emax/Eav= 2.14

