

N

KEY

- Highway Rain Garden
- Highway Rain Garden Infiltration & high-level overflow
- Plot Rain Garden
- Porous Surface Finish (Infiltration) (Non-adoptable)
- Storm Drain (SAB Adoptable)
- Foul Sewer (S104 Adoptable)
- Storm Drain (Non-Adoptable)
- Carriageway Runoff Conveyance
- Orifice Control Chamber

INFILTRATION TESTING

Infiltration Testing undertaken February 2024 provided the following results:

TP01 - 1.45×10^{-5}
TP02 - 5.28×10^{-6}
TP03 - 9.21×10^{-6}
TP04 - 6.00×10^{-6}
TP05 - 2.18×10^{-5}

This drawing is copyright and its use or reproduction without the permission of Spring Design Consultancy Limited. All rights are reserved until invoices are paid in full. No responsibility will be taken for any design used for construction prior to receipt of relevant approvals.

rev	date	description	by
G	07.10.2024	Updated to latest site layout.	CSM
H	06.11.2024	Red line boundary amended.	MCC

Status: **PLANNING**

Drawn:	MCC
Checked:	MCC
Date:	January 2024
Scale:	1:250 (A0)

Client:	Tai Tarian
Project:	Tudor Inn, Cimla
Title:	Drainage Strategy Plan
Ref:	2617-501
Rev:	H

spring design
Unit 2 Chapel Barns | Merthyr Mawr
Bridgend | CF32 0LS | 01656 656267
mail@spring-consultancy.co.uk