

STEELWORK SPECIFICATIONS

THE SPECIFICATION FOR STRUCTURAL STEELWORK SHALL BE THE NATIONAL STRUCTURAL STEELWORK SPECIFICATION FOR BUILDING CONSTRUCTION 5TH EDITION PUBLISHED BY THE BRITISH CONSTRUCTION STEELWORK ASSOCIATION LIMITED.

ALL STRUCTURAL STEELWORK SHALL BE GRADE S275 / S275N / S275N IN ACCORDANCE WITH BS5950, COMPLYING WITH BS 4801:1986.

ALL STEELWORK TO BE SHOT BLASTED TO SA2.5 STANDARD TO REMOVE ALL MILLSCALE, LOOSE MATERIAL, ETC.

WHERE STEELWORK SPECIFIED AS GALVANISED, NO SHOT BLASTING REQUIRED, UNLESS IN ACCORDANCE WITH BS 5950.

ALL STEELWORK TO BE COATED WITH 1 COAT OF ZINC PHOSPHATE EPOXY PRIMER TO A THICKNESS OF 65µm (minimum), EXCEPT WHERE GALVANISED OR STAINLESS.

ALL WELDS TO BE 8mm FULL PROFILE FILLET, UNLESS NOTED OTHERWISE.


ALL BOLTS TO BE GRADE 8.8 TO BS 4190, UNLESS NOTED OTHERWISE.

STEEL BEAMS SUPPORTED ON 140mm DEEP PRECAST CONCRETE PADSTONE INSTALLED WITHIN EXISTING MASONRY WALL. - BOTH SIDES -

NEW BEAMS TO BE ENCASED IN 12.5mm GYPROC FIRE-LINE (or similar approved) PLASTERBOARD TO ACHIEVE 60min FIRE RESISTANCE.

ALL BEAM LENGTHS TO BE CHECKED ON SITE PRIOR TO MANUFACTURE.

BEAMS TO BE BOLTED TOGETHER AT 600mm c/c's WITH 12mm THREADED BAR ON WITH STEEL SPACERS - SEE SECTION



SECTION THROUGH BEAMS 001

Scale 1:10

200 x 50mm C24 SW TIMBER RAFTERS @ 400mm CENTRES (TRIMMED OUT AROUND OPENING WITH TRIPLE & DOUBLE JOISTS)

STEEL BEAMS SUPPORTED ON 140mm DEEP PRECAST CONCRETE PADSTONE INSTALLED WITHIN EXISTING MASONRY WALL.


B002 - 178 x 102 x 19kg UB

200 x 50mm C24 SW TIMBER RAFTERS @ 400mm CENTRES (TRIMMED OUT AROUND OPENING WITH TRIPLE & DOUBLE JOISTS)

NEW MASS CONCRETE FOUNDATION TO BE CAST DIRECTLY AGAINST EXISTING FOUNDATION AND TO SAME FOUNDING LEVEL.

NEW WALL TO BE TIED TO EXISTING WALL WITH CATINIC STRONGHOLD (or similar approved) BREAK THROUGH TO MAINTAIN CONTINUOUS CAVITY AND INSTAL VERTICAL DPC.

EXISTING UNTEL OVER OPENING TO REMAIN



NEW 300mm Ø PLASTIC CHAMBER


ALL DRAINS TO BE 100mm Ø OSSA OR EQUIVALENT. DRAINS WITHIN 1000mm OF EXTERNAL WALLS AND DRAINS BENEATH CONCRETE SLAB TO BE ENCASED IN A MINIMUM OF 150mm CONCRETE.

NEW PLASTIC MANHOLES TO BE USED AND INVERT DETERMINED TO ALLOW FOR A MINIMUM FALL OF 1:40 OF DRAINAGE PIPES.

ALL DRAINAGE ABOVE AND BELOW GROUND TO COMPLY WITH APPROVED DOCUMENT H

NOTE: DRAINAGE ROUTES SHOWN INDICATIVELY. (Exact routes to be determined to suit site constraints)

NEW RAINWATER GULLIES TO DISCHARGE TO NEW SOAKAWAY WITHIN SIDE GARDEN (5m away from building)



FOUNDATION / SLAB DETAIL

Scale 1:25

EXTENT OF GLAZED LANTERN ABOVE

200 x 50mm C24 SW TIMBER RAFTERS @ 400mm CENTRES (TRIMMED OUT AROUND OPENING WITH TRIPLE & DOUBLE JOISTS)

EXTERNAL WALL CONSTRUCTION:
102.5mm FACING BRICKWORK OUTER SKIN (to match existing)
100mm - 70mm BLOCKWORK OUTER LEAF (below ground).
50mm CLEAR AIR CAVITY.
100mm RIGID INSULATION BATTS.
100mm - 70mm BLOCKWORK INNER LEAF.
WITH 3mm PLASTER SKIN FINISH.

650mm x 300mm MASS CONCRETE STRIP FOUNDATION (depth to be approved by Building Control / Inspector)

Client:
Mr. L. Trenarne & Miss A. Fletcher
35 Rowan Tree Close
Bryncoch
Neath
SA10 7SU

Project Title:
PROPOSED SINGLE STOREY
REAR EXTENSION

General Notes:
1. Drawings are to be read in conjunction with the Building Regulations only.
2. Dimensions are to be taken from the centre line unless otherwise stated.
Drawing Title:
BUILDING REGULATIONS

Drawing Title:	PROPOSED PLAN & DETAILS
Drawing No:	CPD-005
Date:	12-03-2024
Scale(s):	1:25
Paper Size:	A2

PROPOSED PLAN

Scale 1:25