

The Commercial Kitchen Filtration Experts

Specification & EMAQ Report

Project: BK – Baglan Moor - MFG

Prepared for: MFG

Prepared by: Dan Franklyn

Date: 03/09/ 2025

Contact details:

M: 0797751450

T: 01708577951

Email: dan.franklyn@purifiedair.co.uk

Interpretation of Requirements

Following our conversation I am pleased to provide an equipment selection for an odour control solution.

As with any project we get involved in we always recommend to our clients that they should closely follow the DEFRA guide for guidance on odour control equipment selection.

This ensures that what they propose will be in line with local authority's requirements and if the system is maintained correctly they will not exhaust nuisance odours leading to complaints from nearby residents.

With this in mind I carried out a risk assessment as detailed in Annex C of the DEFRA Guide.

Taking into consideration the level of discharge, proximity of receptors, size of kitchen and cooking type your project requires a high level of odour control to comply.

We have scored as below and as taken from Annex C: Risk Assessment for Odour;

Dispersion = 10

Proximity of receptors = 5

Size of kitchen = 3

Cooking type 10

Total score = 28

The type of odour abatement system that complies is as below, taken directly from the DEFRA Guide and must be to a very high level of control;

Odour arrestment plant performance

High level odour control may include:

1. Fine filtration or ESP followed by carbon filtration (carbon filters rated with a 0.4 – 0.8 residence time).
2. Fine filtration or ESP followed by UV ozone system to achieve the same level of control as 1.
3. Fine filtration or ESP followed by UV ozone to achieve the same level of control as 1.
4. Fine filtration or ESP followed by wet scrubbing to achieve the same level of control as 1.

Impact Risk	Odour Control Requirement	Significance Score*
Low to Medium	Low level odour control	Less than 20
High	High level odour control	20 to 35
Very high	Very high level odour control	more than 35

* based on the sum of contributions from dispersion, proximity of receptors, size of kitchen and cooking type:

Criteria	Score	Score	Details
Dispersion	Very poor	20	Low level discharge, discharge into courtyard or restriction on stack.
	Poor	15	Not low level but below eaves, or discharge at below 10 m/s.
	Moderate	10	Discharging 1m above eaves at 10 -15 m/s.
	Good	5	Discharging 1m above ridge at 15 m/s.
Proximity of receptors	Close	10	Closest sensitive receptor less than 20m from kitchen discharge.
	Medium	5	Closest sensitive receptor between 20 and 100m from kitchen discharge.
	Far	1	Closest sensitive receptor more than 100m from kitchen discharge.
Size of kitchen	Large	5	More than 100 covers or large sized take away.
	Medium	3	Between 30 and 100 covers or medium sized take away.
	Small	1	Less than 30 covers or small take away.
Cooking type (odour and grease loading)	Very high	10	Pub (high level of fried food), fried chicken, burgers or fish & chips.
	High	7	Kebab, Vietnamese, Thai or Indian.
	Medium	4	Cantonese, Japanese or Chinese.
	Low	1	Most pubs, Italian, French, Pizza or steakhouse.

The Systems

The ESP's have been specifically designed for kitchen extract and not modified from industrial use, they have integral sumps to collect the oil, grease and smoke particles filtered out of the exhaust; this not only simplifies servicing but eradicates potentially dangerous spillage from the bottom of the units and greatly cuts down on flammable build-ups within the duct run.

The ionisation voltage has been designed to run at a negative potential which enhances the ionisation of particles and also produces more Ozone which is helpful in reducing odours in kitchen applications.

Our ESP units fit in-line with the kitchen ducting and can be configured modularly to cope with all extract volume requirements.

The Electrostatic Precipitator is a very efficient means for separating the particulate phase; operating efficiency when clean can be as high as 98% at particle sizes down to 0.01 micron.

The Electrostatic Precipitator does not present a high-pressure loss (175PA approx. dependant on air flow). This gives a specific advantage in that most standard Kitchen extractor fans will have the capability of overcoming this small differential.

This is particularly advantageous when it is considered that if the pressure loss were high larger noisier fans would probably be necessary resulting in potential noise pollution.

UVO

The UV-O units are located outside of the kitchen extract duct and are connected via a spigot and spiral ducting.

The UV-O 500 has been designed for smaller capacity commercial kitchens. The UV-O range uses UV-C technology to produce ozone and hydroxyl free radicals to oxidise cooking odours through a process of ozonolysis. Unlike other UV-C systems, our UV-O units are located outside of the kitchen extract duct and are connected via a spigot and small diameter ducting.

Specification To meet above DEFRA Criteria

1 No

ESP3000

Supply –

220-240v

Power consumption

– 40W Max airflow –

2.1m³/s

Dims – W1350 x H630 x

D640 Weight – 118kg

1 No

UVO500

Supply –

220-240v

Power consumption –

700W Max airflow –

2.5m³/s

Dims – W1568 x H350 x

D363 Weight – 50kg