

Written Statement confirming the length, voltage and confirmation wayleaves have been agreed

- 1.1.1 The length of the connection is 9km (5.1km as underground cable, and 3.9km as overhead line).
- 1.1.2 The voltage will be 66kV.
- 1.1.3 The applicant confirms that all necessary wayleaves have been agreed with owners and occupiers of land proposed to be crossed by the line.

Details of the generating station that is functionally linked to the proposed grid connection

- 1.1.1 Further to the email received from PEDW on 6th October 2025, please find below the requested details.
- 1.1.2 The consented 'Generating Station' that the proposed overhead line and underground cable would connect into is the Foel Trawsnant Wind Farm. That windfarm is located in the Neath Port Talbot local planning authority and will have an output of 33MW. As a result it was determined under the Town and Country Planning Act 1990 and therefore is classed as a devolved Welsh Generating Station.
- 1.1.3 The Foel Trawsnant windfarm was granted permission on 15 June 2022 under the planning reference: P2014/0825.
- 1.1.4 Construction is currently planned to commence in 2026.