

Luminaire Schedule									
Symbol	Ref	Qty	Config	Description	Mtg Height	Lumens	Cutoff Class	Total MF	Unit Watts
	A	5	Single	Kirium Pro S Mini 8LED 3K A2 500mA UMSUG 42 0012 0000 100	5	2123	Full Cutoff	0.920	12
	B	3	Single	Kirium Pro S Mini 8LED 3K C2 500mA UMSUG 42 0012 0000 100	5	2022	Semi-Cutoff	0.920	12
	C	2	Single	Kirium Pro S Mini (Shield) 8LED 3K B1 300mA UMSUG 42 0008 0000 100	5	1125	Full Cutoff	0.920	8

Luminous Flux Factor (LFF): BS5489-1:2020 [Annex D2] = 1.0 [CLO]

Survival Factor (SF): BS5489-1:2020 [Annex D2] = 1.0


Luminaire Maintenance Factor (LMF): BS5489-1:2020 [Table C1] = 72 Months:
Environmental Zone:

E1/E2 =~6M TLS = 0.92

[LFF] * [SF] * [LMF] = Total Maintenance Factor Value


Calculation Results Summary									
Grid Reference	Measurement	Units	Eav	Emax	Emin	Uo	Ud	X Pitch	Y Pitch
Crossing 1	Illuminance	Lux	14.06	24.7	5.3	0.38	0.21	1	1
Crossing 2	Illuminance	Lux	15.27	26.2	6.0	0.39	0.23	1	1
Roadway	Illuminance	Lux	6.29	26.4	1.0	0.16	0.04	1.5	1.5
Walkways	Illuminance	Lux	5.65	13.1	1.2	0.21	0.09	1	1

Luminaire Location Summary						
Col ID	Ref (Qty)	X	Y	Angle	Tilt	Dimming
1	A (1)	971.374	964.232	318.124	0	1.00
2	A (1)	988.914	986.384	324.774	0	1.00
3	A (1)	1009.411	997.766	139.33	0	1.00
4	B (1)	1011.286	1019.112	267.273	0	1.00
5	A (1)	1035.223	1026.806	139.973	0	1.00
6	B (1)	1047.002	1029.987	48.77	0	1.00
7	C (1)	1071.743	1043.892	139.588	0	1.00
8	A (1)	1041.371	1046.207	319.919	0	1.00
9	B (1)	1062.585	1052.26	141.399	0	1.00
10	C (1)	1072.415	1061.922	233.119	0	1.00




REF A:
Kirium Pro S Mini, Direct Post, 8 x 500mA 3K CLO LED Array,
A2 Optic, RAL7046 Grey Finish, 7 Pin Nema Socket

6m TLS Tubular Steel Rooted Neath CC Spec, Column,
Galvanised Finish



REF B:
Kirium Pro S Mini, Direct Post, 8 x 500mA 3K CLO LED Array,
C2 Optic, RAL7046 Grey Finish, 7 Pin Nema Socket

6m TLS Tubular Steel Rooted Neath CC Spec, Column,
Galvanised Finish



REF C:
Kirium Pro S Mini, Direct Post, 8 x 300mA 3K CLO LED Array,
B1 Optic, RAL7046 Grey Finish, 7 Pin Nema Socket + Rear Light Shield

5m TLS Tubular Steel Rooted Neath CC Spec, Column,
Galvanised Finish

BS EN 13201-2:2015

6.1 Requirements for pedestrians & pedal cyclists
Table 3 - P Lighting Classes

Class P4:

5.0 - 7.5lx Eav

1.0lux Emin

B 26/05/26 Lighting Class Revised To P4, Column Location Changes

A 20/11/25 Based on client CAD DWG

Issue: Date: Description:

CDM Statement:
Please note that this proposed lighting scheme is a lighting solution that has been designed with information provided by the client. The solution does not include site, installation engineering or any risk assessment considerations for CDM.



Pindar Road, Hoddesdon Herts, EN11 0DX, UK T: 01992 474600 E: info@dw-windsor.co.uk W: www.dw-windsor.com

Project:
**Caewern House,
Neath**

Client: Spring Consultancy Ltd Contact: Max Collis

Project Management: Steve Meredith Lighting Design: Michael Walker

All measurements in Metres & lux. Do not scale from this drawing.
All product images are indicative.

Filename: 25-449-1B - 1.1 Caewern House, Neath.AGI AG320® Version 22.3.2

Date: 26/05/2026 Scale: 1:300 @ A1

Project Ref: Page 1 of 1

25-449-1B