

General Environmental Health Planning Consultation Response

Planning Application Ref: P2026/0388

Address: Rownad Pontneathvaughan Road Glynneath Neath Port Talbot SA11 5NT

Planning Case Officer: Nia Ferris

Comments provided by: Edward Davis

Our Ref:

Date: August 3, 2026

The General Environmental Health Planning Consultation response to the above application has considered the following relevant areas:

Noise	☒	Air Quality	☐	Contaminated Land	☒
Odour	☐	Housing	☐	Other (please specify)	☐

The Environmental Heath Team, in responding to the above application, provides the following substantive response:

No Comment	☐
No Objection subject to conditions (see the specified conditions below)	☒
Requires further information (see details below)	☐
Objection (on the grounds set out below)	☐

Overall Recommendation

I recommend approval as this is a minor application with minimal impact on the local amenity.

Observations and Comments

Sensitive receptors may be affected by the building of the extension and Con. Land if identified should be dealt with accordingly

Recommendation:

Approval with suggested conditions:

Any unforeseen ground contamination encountered during development, to include demolition, shall be notified to the Local Planning Authority as soon as is practicable.

Unless otherwise agreed in writing by the Local Planning Authority as unnecessary, an appropriate ground investigation and/or remediation strategy shall be submitted to and approved in writing by the Local Planning Authority, and the approved strategy shall be implemented in full prior to further works on site. Following remediation and prior to the occupation of any building, a Completion/Verification Report, confirming the remediation has being carried out in accordance with the approved details, shall be submitted to and approved in writing by the Local Planning Authority.

Reason: *To ensure that any potential risks to human health or the wider environment which may arise as a result of potential land contamination are satisfactorily addressed.*

Construction and demolition works and associated activities at the development, audible beyond the boundary of the site should not be carried out other than between the hours of 08:00 – 18:00 Monday to Friday daily, 08:00 – 13:00 on Saturdays and at no other times, including Sundays and Public/Bank Holidays, unless otherwise agreed with the Environmental Health Officer.

At least 21 days prior to the commencement of any site works, all occupiers surrounding the site should be notified in writing of the nature and duration of works to be undertaken. The name and contact details of a person responsible for the site works should be made available for enquiries and complaints for the entire duration of the works and updates of work should be provided regularly. Any complaints should be properly addressed as quickly as possible.

All waste materials and rubbish associated with demolition and/or construction should be contained on site in appropriate containers which, when full, should be promptly removed to a licensed disposal site.